PLAINTIFF'S EXHIBIT

B&R-365

7

CONTRACTORS' RESPONSIBILITIES FOR SAFETY, PLANT SECURITY, AND TRAFFIC REGULATIONS

BAYTOWN PLANTS

January 2, 1975

SECTION 2

CONTRACTORS' RESPONSIBILITIES

INDEX

Page No.

I. DEFINITIONS

1. Owner 2
2. Contact Man 2
3. Basic Equipment Owner 2
4. Plant 3
5. Contractor 3

II. SAFETY REGULATIONS

A. GENERAL

1. Authorization to Start Work 3
2. Contractors' Equipment 3
3. Smoking 3
4A. Hot Work 4
4B. Cold Work 4
5. Explosives 4
6. Connecting into Existing Pipe Lines or Equipment 5
7. Connecting into Existing Sewers 5
8. Work on, Adjacent to or Connecting into Existing Electrical Power Circuits and Work on Electrically Operated Equipment 5
9. Entering Containers, Pits, Excavations 6
10. Work Involving the Use of Ionizing Radiation 6
11. Housekeeping 6
12. Use of Lines, Conduits or Structures as Supports 7
13. Use of Stanchions or Equipment for Anchors 7

14. Guy Lines 7
15. Working in the Vicinity of Electric Lines 7
16. Excavations 7
17. Moving Suspended Loads 8
18. Damage to Owner's Property 8
19. Warning and Caution Signs 8
20. Entering Operating Unit 8
21. Operating Owner's Equipment 8
22. Use of Special Vehicles 8
23. Fire Extinguishers 9
24. Compressed Gas Cylinders – Transportation, Storage, and Use 9
25. Railroad Obstructions 10
26. Guarding 10
27. Electrical Tools & Equipment 10
28. Welding and Burning 11
29. Plant Air 12
30. Machinery 12
31. Refueling Vehicles and Equipment 12
32. Protective Clothing, Protective Equipment and Safe Tools 12
33. Working Over or Near Water 12
34. Securing of Temporary Buildings 13

B. SUPERVISORY RESPONSIBILITY
1. Set a Good Example 13
2. Provide Adequate Instructions 13
3. Cooperate with Owner's Designated Representative 13
4. Provide Adequate Procedure for Specific Job 13

C. INDIVIDUAL RESPONSIBILITY
1. Contractor Employees' Basic Rules for Personal Safety 14
2. Clothing and Protective Equipment 14

3. Guarding 16
4. Housekeeping 16
5. Smoking and Matches 16
6. Hand Tools 16
7. Electrical Tools and Equipment 17
8. Power Tools – Machinery 17
9. Ladders and Scaffolds 17
10. Excavations and Trenches 18
11. Traffic and Railroad 18
12. Hoisting Equipment 19
13. Structures 19
14. Hazardous Materials 19
15. Compressed Air – Yard System 19
16. Compressed Gases 19
17. Fire Prevention–Fire Fighting 19

III. PLANT SECURITY REGULATIONS

1. Parking Locations 20
2. Entrance Gate 20
3. Walks and Roadways 20
4. Contractor Badges and Contractor Passes 20
5. Use of Subcontractors 21
6. Car Passes 21
7. Material Passes 21
8. Thefts 21
9. Gambling 22
10. Business Visitors, Applicants, and Delivery Trucks 22
11. [illegible] 22
12. [illegible] Boxes, [illegible] Motor Vehicles, etc. 22
13. Cameras and Photographs 23
14. Liquor, Drugs, Firearms and Explosives 23
15. Visiting and Loitering 23
16. Fingerprinting 23

IV. TRAFFIC REGULATIONS

1. Equipment Required on Motor Vehicles 23
2. Driver License 24
3. Warning Flags 24
4. Traffic Signs 24
5. Speed Limit 24
6. Driving and Parking 24
7. Right-of-Way 24
8. Passengers 25
9. Vehicles Prohibited 25
10. Windshield or Window Obstruction 25
11. "Road Closed" Signs 25
12. Obstructing Streets, Roads, Fire Equipment or Fire-Fighting Facilities 25

SECTION 2

CONTRACTORS' RESPONSIBILITIES FOR SAFETY, PLANT SECURITY, AND TRAFFIC REGULATIONS

Contractor shall fully comply with these Safety, Plant Security, and Traffic Regulations in the performance of work described in the contract. These regulations shall also fully apply to all Subcontractors and their employees, as well as to the Prime Contractor and its employees. Contractor shall notify its employees, its Subcontractors, and the employees of its Subcontractors of the provisions of the regulations and shall secure compliance therewith by all such parties; and Contractor shall not allow any of such persons to begin work inside Owner's Baytown Plants until such notification has been given them.

Contractor shall observe and comply with the Texas Occupational Safety Act (Art. 5182a, V.C.S.) and with all safety and health standards promulgated by the Secretary of Labor under Section 107 of the Contract Work Hours and Standards Act, published in 29 CFR Part 1926 and adopted by the Secretary of Labor as occupational safety and health standards under the Williams-Steiger Occupational Safety and Health Act of 1970, and to any other legislation enacted for the safety and health of contractor employees. Such safety and health standards shall apply to all Subcontractors and their employees as well as to the Contractor and its employees.

Contractor is and shall remain an independent Contractor as to all work performed under the contract. The detail manner, means, and methods of performing said work shall be under the control and direction of Contractor, the Owner being interested only in the results obtained.

These Safety, Plant Security, and Traffic Regulations are designed as minimum requirements for Contractor, and Contractor shall take any additional precaution necessary or proper under the circumstances to prevent injury or death to persons or damage to property. These regulations are to be considered as an addition to any safety rules or regulations of the Contractor. Neither compliance with the regulations by Contractor nor Owner's approval of any actions or procedures of Contractor as provided therein shall relieve Contractor of its obligation always to use due care in performing work.

Nothing contained in these regulations shall be interpreted to enlarge the legal duty of the Owner to the Contractor, his agents, employees, or Subcontractors.

I. DEFINITIONS

As used herein, the following definitions are applicable:

1. Owner

Since Exxon Chemical Company U.S.A., an operating division of Exxon Chemical Company, a division of Exxon Corporation, Exxon Company, U.S.A. (a division of Exxon Corporation), and Exxon Research and Engineering Company (ER&E) all have facilities located within the Baytown Refinery complex, these three parties have agreed upon these common safety, plant security, and traffic regulations to be applicable on each corporation's property within said complex. Therefore, for purposes of these regulations, "Owner" shall mean Exxon Chemical, Exxon, or ER&E, as applicable.

2. Contact Man

The Owner's representative assigned to the project by the Mechanical Division of Exxon Chemical Company U.S.A. (EMD), the Maintenance & Construction (M&C) Division of Exxon Company, U.S.A., the Maintenance and Construction Foreman of ER&E, or the individual designated by the Technical Division involved on contracts for engineering services. The Contact Man, on proper request, will assist the Contractor in obtaining all permits required hereunder and will be the normal contact between the Contractor and all of Owner's personnel.

3. Basic Equipment Owner

The Exxon Chemical Company U.S.A., Exxon Research and Engineering Company, or Exxon Company, U.S.A. representative primarily responsible for the safety of Exxon Chemical, ER&E, and Exxon personnel and equipment in the area in which the work is to be performed.

4. Plant

The facilities of Exxon Chemical Company U.S.A., Exxon Research and Engineering Company, or Exxon Company, U.S.A., Baytown, Texas, or any combination of such facilities on which work is to be performed.

5. Contractor

Designates "Contractor," "Contractor's Subcontractors," and all employees of each.

II. SAFETY REGULATIONS

A. GENERAL

1. Authorization to Start Work

Contractor and Subcontractors shall not start work until authorized by the Contact Man at the job site. Such authorization does not constitute authority to proceed with any work involving special permits as outlined herein. Contractor shall also secure approval from Contact Man before any materials are delivered to job site when material deliveries precede Contractor's arrival on site.

2. Contractors' Equipment

a. All equipment brought into the Plants by Contractors shall be in safe operating condition. Authorized Owner personnel at any time may inspect Contractors' equipment. Such inspections or failure to inspect shall not relieve Contractors of their responsibilities for the safe condition of their equipment.

b. All Contractors moving trailer-type equipment within the Plants shall use a hitch equal to Premier's automatic latching hitch No. 105 for one-ton loads, or No. 580 for one and one-half ton loads, except that properly rated ball hitches may be used when provided with safety chains.

c. Load limits for the San Jacinto Street overpass are as follows: maximum axle load - 32,000 pounds and maximum gross load - 72,000 pounds. A tandem axle vehicle shall be considered as being a single axle.

3. Smoking

Smoking within the Plant is prohibited, except at locations and times approved in writing by Owner. The Contact Man will obtain the required permission.

4A. Hot Work

"Hot work" is defined as any work requiring the use of burning or welding equipment, brazing equipment, explosives, open fires, portable grinders, internal combustion engines, soldering irons, nonexplosionproof electric motors (including motor chippers, drills, and saws), nonexplosionproof floor or string lights, sand blasting, explosive-actuated tools, electric hot plates, or any other flame or spark-producing equipment.

Contractors shall not use open fires or spark-producing equipment or do any "hot work" without a written permit on Form 541-0623 properly filled out and signed by (1) the Basic Equipment Owner in the space marked, (2) Owner's Safety Permit Inspector in the space marked "Gas Inspector," and (3) by the Contractor's authorized representative in the space marked "Mechanical Supervisor." Permits are valid for only the time and date specified on the face of permit. Owner will assign areas in which Contractor may do "hot work" on a job-duration basis and will give short-time permits in other locations when considered safe. Contractors shall stop any "hot work" upon request of any employee of Owner and shall not resume such work until authorized by the Contact Man. Contractor shall watch for conditions that make the use of "hot work" unsafe; and immediately upon observing such conditions, Contractor shall cease "hot work" and report the condition to the Contact Man.

4B. Cold Work

The Opening, Blanking, and Cold Work Permit is required to perform work inside operating areas or on operating equipment (not involving hot work or entry into vessels which is covered by other permits).

Contractors shall not enter any operating area (1) with mobilized equipment, (2) to perform "cold work," or (3) to blank or open equipment without a written permit on Form 541-0079A properly filled out and signed by Basic Equipment Owner and contractor's authorized representative.

5. Explosives

Explosives shall not be used without prior written approval of Owner.

6. Connecting Into Existing Pipe Lines or Equipment

a. Contractor shall not open or tie its work into Owner's existing pipe lines or equipment without a written permit on Form 541-0079A "Permit to Open and/or Blank And Cold Work", properly signed by Basic Equipment Owner in the space marked "Operating Man." After a tie-in has been made to Owner's existing lines or equipment, the whole piping or equipment system involved shall be considered the same as Owner's existing lines and equipment; and written approval on Form 541-0079A, mentioned above, shall be obtained from Owner before additional work can be done on any of these lines or equipment, unless a blank, approved by the Contact Man, has been installed separating the lines and equipment being worked on from the remainder of the system.

b. Permission must be obtained from the Contact Man prior to the use of company utilities, such as, but not limited to, water, steam and air systems, and fire hydrants. Each connection shall be guarded by a check valve. When taking water from fire hydrants, the main center valve shall be opened completely.

7. Connecting into Existing Sewers

Contractor shall not open or tie into or work on Owner's sewer system without a written permit on Form 541-0079A, "Permit to Open and/or Blank And Cold Work properly signed by the Basic Equipment Owner in the space marked "Operating Man." After sewers constructed by Contractor have been tied into Owner's sewer system, the "hot work" permit shall terminate. Contractor shall not perform any "hot work" in the area until a new "hot work" permit has been obtained.

8. Work on, Adjacent to, or Connecting into Existing Electrical Power Circuits and Work on Electrically Operated Equipment

Under no circumstances shall Contractor work on, adjacent to, or connect into Owner's electrical system or work on Owner's electrically operated equipment without obtaining prior written permission from Owner in accordance with Owner's "Electrical Tagout Procedures," latest edition. Contractor shall comply with said procedures in performing all work.

9. Entering Containers, Pits, Excavations, and Tanks

Contractor shall not enter any "Class A" Closed Container, as defined below, without a written permit on Form 541-0751, "Report of Gas Analysis" and "Permit to Enter," properly signed by (1) Owner's Safety Permit Inspector, (2) the Basic Equipment Owner in the space marked "Operating Head" and (3) Contractor's authorized representative in the space marked "Foreman Doing Work." The permit is valid for only the time and date shown on the face of the permit. "Class A" Closed Container is defined as any closed container (in custody and control of Owner) which has been in operation. This also includes furnaces, excavations, open top containers and sewers in care, custody and control of Owner where the head of a man working therein is below the top of the vessel, excavation, or sewer.

10. Work Involving the Use of Ionizing Radiation

Contractor shall not perform any work involving the use of ionizing radiation without written notification in duplicate to the Owner. Notification shall include the job reference, state time of entry, the type of ionizing radiation equipment and the strength of the ionizing source. Contractor shall comply with "Texas Regulations for Control of Radiation," latest edition, Texas State Department of Health, Division of Occupational Health and Radiation Control, Austin, Texas, together with all future amendments, additions, and revisions to said regulations and standards. Owner reserves the right to conduct independent and unannounced radiation surveys of Contractor's equipment and its uses on Owner's premises.

11. Housekeeping

At all times the job site shall be kept clean and free from debris, trash, and rubbish. Contractor shall store all materials in a neat and orderly fashion, and shall not store materials within four feet of any fence or along railroad tracks within a distance of seven feet and two inches horizontally from the edge of the nearest rail, and shall not construct temporary or permanent structures within this minimum clearance. Dismantled or surplus materials, trash, and debris (including earth, clay, lumber, concrete, metal, insulation, paper, etc.) that falls from Contractor's vehicles shall be promptly cleaned up by Contractor.

12. Use of Lines, Conduits or Structures as Supports

Contractor shall not use Owner's pipe lines, electrical conduits, handrails or structures as supports for loads, for ladders, or for scaffolds without authorization from the Contact Man.

13. Use of Stanchions or Equipment for Anchors

Contractor shall not use Owner's pipe stanchions or other equipment for attaching snatch blocks, guy lines, or for other services which apply loads on the equipment without written approval of the Contact Man.

14. Guy Lines

When it is necessary for Contractor to install guy lines across Owner's electric lines, Contractor shall construct guards of a type approved by Owner, to prevent guy lines from coming in contact with the electric lines. No guy lines shall be detached nor buried guy line anchors disturbed without prior approval of the Contact Man. Contractor shall not place any guy line, mooring line, or load line in such a position that it will tighten against operating equipment, pipe lines, tanks, or machinery.

15. Working in the Vicinity of Electric Lines

When it is necessary for a Contractor to operate cranes or derricks, or perform other work within 12 feet of open electric lines (vertically or horizontally), Contractor shall consult the Contact Man and determine whether the electric lines can be de-energized. Contractor shall not proceed with any work until the electric lines have been de-energized or until guards have been installed.

16. Excavations

All excavations made by the Contractor shall be adequately protected to prevent sloughing of earth by shoring or sloping and shall be fenced in or barred over to prevent personnel from slipping or falling into them. In excavations which employees may be required to enter, excavated or other material shall be effectively stored and retained at least two feet or more from the edge of the excavation. Contractor shall not permit anyone to work in an excavation which requires a person's head to be below the surface of the ground until a "Permit To Enter" has been secured.

WARNING-RED CONCRETE UNDERGROUND signifies the presence of an electrical circuit. Stop excavating and notify the Contact Man.

17. Moving Suspended Loads

Contractor shall not move loads suspended from mobile equipment without load being secured to prevent swinging. All chains, cables, ropes, etc., suspended from mobile equipment shall be properly fastened.

18. Damage to Owner's Property

If Contractor damages any of Owner's property, or property of any other Contractor or Subcontractor, the damage shall immediately be reported to the Contact Man.

19. Warning and Caution Signs

Contractors shall obey all safety warning signs posted by Owner and shall provide safety equipment required by signs.

20. Entering Operating Unit

Contractor shall not enter any operating unit or area with motorized equipment without permission of the Unit Chief Operator. Vehicles entering these areas may be required to have sparkproof mufflers or their equivalent.

21. Operating Owner's Equipment

Contractor shall not operate any of Owner's equipment, such as electric power switches, valves, etc., without prior specific approval of the Contact Man.

22. Use of Special Vehicles

No vehicle or piece of equipment having metallic-lugged wheels or tracks shall be operated on any hard surface street without adequate protection to the street, as approved by Contact Man. No tracked equipment having flat pavement treads shall be operated on a paved street without approval of the Contact Man.

23. Fire Extinguishers

Welding machines and tar pots shall have a 12-lb. CO_2 or 20-lb. dry chemical-type fire extinguisher in proper working condition located adjacent to the equipment. An extinguisher shall be located in each working area where "hot work" is being done.

Fire Hose – Where fixed hose reels are not available, the Contractor shall furnish and maintain a minimum of one fire hose in each working area where hot work is being done. Each hose shall be 1½" diameter with threaded coupling and NYC Fire Department threaded adapter suitable for 150 psi pressure. Each hose shall be equipped with a 1½" combination fog, straight stream, and shut-off nozzle equal to American LaFrance or Elkhart L-200. Hoses shall be connected to a hydrant. The Contractor shall be responsible for opening the water supply valve at the hydrant in full open position while hot work is in progress, but pressure is not to be left on hose over night.

24. Compressed Gas Cylinders—Transportation, Storage, and Use

a. Compressed gas cylinders, empty or full, shall be adequately secured in an upright, vertical position when in transportation, storage, or use. Do not store cylinders under pipe or power lines.

b. Protective caps must be kept in place when not in use.

c. Use holders, chains, or keepers to prevent overturning.

d. Secure cylinders in a vertical position with a suitable keeper while connected to equipment.

e. Do not allow pure oxygen to come in contact with hydrocarbons in any form.

f. Avoid any rough-type handling.

g. Contractor shall not use oxygen or acetylene for testing purposes.

h. Contractor shall not take oxygen or acetylene cylinders inside a vessel. (Exception – In storage tanks where door sheet has been removed.)

l. Oxygen cylinders in storage shall be separated from fuel-gas cylinders or combustible materials (especially oil or grease), a minimum distance of twenty (20) feet or by a noncombustiable barrier at least five (5) feet high having a fire-resistance rating of at least one-half hour.

25. Railroad Obstructions

Contractor shall not construct or place any permanent or temporary obstructions closer than seven feet, two inches horizontally, or twenty-three feet vertically from any railroad rail without specific authorization from the Contact Man.

26. Guarding

Contractor shall guard or place appropriate barricades around temporary openings in floors, handrails, etc., to prevent accidents. Contractor shall replace permanent handrails and guardrails immediately after need for opening has ended. Guards on moving machinery shall be in place or other protection provided before such machinery is operated.

Contractor shall guard or protect any area into which materials or tools are to be deliberately dropped or thrown.

27. Electrical Tools & Equipment

a. Contractor shall ground portable electrical tools, metal buildings, and electrical equipment.

b. Contractor may use general purpose flashlights provided they do not exceed three-cell (1.5v per cell), except at Docks where they shall meet Coast Guard requirements.

c. Explosionproof, approved portable lights (Underwriters Laboratory—or Bureau of Mines—approved) must be used where hot work is not authorized. This includes, but is not limited to, the following:

(1) Portable explosionproof hand lamps.

(2) Portable explosionproof floodlights.

(3) Extension cords (plug boards) with explosion-proof fixtures.

28. Welding and Burning in Confined Spaces

a. To prevent gas from escaping through leaking or improperly closed torch valves, the gas supply to the torch shall be positively shut off at some point outside the enclosed space or the hoses disconnected at the regulator whenever gas welding or burning is suspended for a substantial period of time or when the torch is left unattended such as during the lunch period, at shift change, etc.

The torch and hose shall be removed from the confined space, or if this is impractical, the hoses shall be disconnected at the regulators at the end of the shift when work is not to be continued on the next shift.

Open end fuel gas and oxygen hoses shall be immediately removed from the confined space when they are disconnected from the torch or other gas-consuming device.

b. Contractor shall vent and clear any hollow or partially hollow vessel or equipment which may be overpressured by the application of heat before heating or burning into it.

c. Contractor shall not weld on oil or gas lines or equipment in service unless there is an internal cooling agent to remove heat, such as flowing liquid or gas, and/or unless there is sufficient metal, as approved by the Contact Man, to prevent a burn-through.

Exception: No hot work is to be done on air lines in service between the reciprocating compressor discharge and the knockout drum or drier. Hot work can be done on air lines down-stream of knockout drum or drier, or on air lines pressured by centrifugal equipment, after a gas test shows the air in the line to have no hydrocarbons present.

29. Plant Air

Contractor shall not use plant system compressed air for breathing purposes.

30. Machinery

Contractor shall not work on any machinery while it is either in motion or operation without approval of the Contact Man.

31. Refueling Vehicles and Equipment

Whenever possible, gasoline and fuel should be dispensed through a pump and hose. If not possible, approved* safety cans with flexible spouts may be used. Transfer of fuel in nonapproved cans, open containers and glass containers is prohibited. Vehicles and equipment engines must be turned off during refueling.

*Underwriters Laboratory or Factory Mutual approved container for flammable liquid.

32. Protective Clothing, Protective Equipment, and Safe Tools

Every Contractor employee shall wear a shirt with long sleeves buttoned while within the Plant, except at certain locations specified by the Contact Man.

Contractor shall provide necessary protective clothing, protective equipment and safe tools.

33. Working Over or Near Water

a. Ring buoys with at least ninety (90) feet of line shall be provided and readily available for emergency rescue operations. Distance between ring buoys shall not exceed two hundred (200) feet.

b. At least one life saving skiff shall be immediately available at locations where employees are working over or adjacent to water.

14. Securing of Temporary Buildings

All temporary buildings shall be tied down by the Contractor in accordance with the Contact Man's instructions, and applicable Baytown Engineering Standards.

B. SUPERVISORY RESPONSIBILITY

1. Set a Good Example

Contractor Supervisory personnel shall at all times set a good example for Contractor employees in order to encourage compliance with these safety rules and regulations.

2. Provide Adequate Instruction

Contractor Supervisory personnel shall provide adequate instruction in and require compliance with:

a. Accident prevention aspects of each job.

b. Use and application of appropriate protective equipment and devices.

c. Use or application of tools and equipment.

3. Cooperate with Owner's Designated Representative

Contractor Supervisory personnel shall cooperate with Owner's designated representative where the safety aspects of a job require coordination. This includes, among others, the securing of permits for cold work, opening and blanking vessels and lines, entering vessels and excavations, hot work, and lock out of electrical equipment.

4. Provide Adequate Procedure for Specific Job

Contractor Supervisory personnel shall see that there is an adequate safety procedure for the specific job to be done and that all procedures are well understood and followed.

C. INDIVIDUAL RESPONSIBILITY

1. Contractor Employees' Basic Rules for Personal Safety

   a. Do not go to a Plant fire.

   b. Report all injuries to your supervisor immediately after they occur.

   c. Follow all safety procedures applicable to the job being performed, including the use of appropriate protective equipment.

   d. Do not enter any operating equipment area or work on operating equipment without the approval of the Supervisor.

   e. Do not indulge in horseplay.

   f. Use the right tool for the job—no makeshifts.

   g. Keep clear of suspended loads.

   h. Eliminate or guard against known hazardous conditions.

2. Clothing and Protective Equipment

   a. Do not wear clothing contaminated with oil, hazardous liquids, or chemicals. If contamination does occur, wash immediately with soap and water and report to your supervisor.

   b. Wear clothing which covers and protects the body when working or visiting in areas where the probability of exposure to hot liquids, flash fires, or skin irritants exists. This includes some type of arm covering. Wear a shirt with long sleeves buttoned at all times.

   c. Loose clothing, loose sleeves, neckties, or gloves shall not be worn where there is a probability of their being caught in moving machinery.

d. Wear the following safety protective equipment under the circumstances indicated below:

(1) Safety Hats, Safety Glasses, and shirts with long sleeves buttoned—In all areas of the Refinery and Chemical Plant except at certain locations specified by Contact Man.

(2) Contact lenses represent an increased industrial safety hazard and shall not be worn inside the Refinery and Chemical Plant.

(3) Goggles or face shields-Where flying objects exist.

(4) Chemical Goggles—Where chemical or liquid hazards exist.

(5) Respiratory Protection—Where atmosphere of the work area is contaminated by hazardous dust, toxic gases, excess vapors or fumes, or where an oxygen deficiency exists.

(6) Protective Clothing—Where there is a probability of exposure to acid, caustic, or other hazardous material.

(7) Safety Belts—attached to an independently supported lifeline:

(a) Where an oxygen deficiency exists; where the surrounding atmosphere is immediately hazardous to life; or where hazardous conditions exist.

(b) When working from scaffolds, platforms, or any other surface, which may not afford sufficient protection against falling.

(c) While working on any roof with a slope greater than one on four.

(d) When working within six feet of the edge of any roof.

(8) Life Preservers—When working over or near water.

(9) Ear Protection–While working in areas posted with noise warning signs, or while working with or near tools or equipment which generate sufficient noise to make normal conversation difficult, ear plugs, disposable plugs, Swedish wool, or ear muffs shall be worn. Cotton is not acceptable.

(10) Note the location of eyewash fountains and safety showers and know how they work.

3. Guarding

a. Guard or cover open excavations or manholes before leaving the job.

b. Do not perform work above open moving machinery.

c. Guard or protect any area onto which materials or tools are to be deliberately dropped or thrown.

4. Housekeeping

a. Keep aisles, passageways, stairs, platforms, and ladders clear of all unnecessary obstructions.

b. Remove or bend down all protruding nails that present a snag or puncture hazard.

c. Keep worksite clean and orderly.

5. Smoking and Matches

a. Do not smoke in the Refinery or Chemical Plant, except at locations approved by Owner.

b. Do not bring "strike-anywhere" matches into the Plants.

6. Hand Tools

a. Do not use defective tools.

b. Do not subject tools to undue stress or use them for purposes for which they are not designed.

7. Electrical Tools and Equipment

   a. Do not open or close an electrical switch without full knowledge of the results which can be expected.

   b. Do not remove vaporproof globes, except for cleaning, repairing, or replacing lamps.

   c. Do not open explosionproof fixtures without approval of the supervisor.

8. Power Tools—Machinery

   a. Do not work on any machinery while it is in motion.

      Exception: If it is impractical to shut the equipment down before working on it, secure supervisor's approval before proceeding.

   b. Keep abrasive wheel tool rest adjusted to within 1/8" maximum of the wheel. Do not use abrasive wheels which are visibly in bad order.

   c. Do not stand in line with high-speed abrasive wheels. Guards shall be provided.

9. Ladders and Scaffolds

   a. Use only ladders which are in good condition. Portable ladders in use shall be tied, blocked, or otherwise secured to prevent their being displaced. Where practical, the side rails shall extend not less than thirty-six (36) inches above the landing.

   b. Do not place any ladder where it can be bumped, such as in front of a door, in the street or aisles, etc., unless adequate precautions are taken to protect both the climber and others who may be in the area.

   c. Use good working techniques when climbing, working from, or descending from a ladder, such as holding with both hands and keeping the body within the side rails of the ladder.

d. Lower swing scaffolds to the ground at the end of the shift.

e. An access ladder or equivalent safe access shall be provided to all scaffolds.

f. Provide guard rails, midrails and toe boards on all scaffolds more than six feet (6') above the ground or floor.

g. Scaffolds and their components shall be capable of supporting without failure at least four times the maximum intended load.

h. Platform planks shall be laid with their edges close together so the platform will be tight with no space through which tools or fragments of materials can fall.

10. Excavations and Trenches

a. Do not enter or perform work in an excavation or trench which requires your head to be below the surface of the ground until:

(1) OK gas and oxygen tests have been secured and written "Permit to Enter" obtained.

(2) A ladder or stairway has been provided so as to require no more than twenty-five (25) feet of lateral travel for safe entrance and exit.

(3) Adequate shoring or sloping of excavation or trench walls has been provided.

11. Traffic and Railroad

a. Observe traffic control signs, markers, and regulations. Obey persons directing traffic.

b. Motorized vehicles and internal combustion engines are not permitted inside any tank firewall without permission of the Chief Operator in charge of storage facility.

c. Do not board or ride on railroad equipment.

12. Hoisting Equipment

a. Operate hoisting equipment so as not to endanger other people or damage equipment in the operating area.

b. Do not ride on blocks, hooks, balls or crane loads unless a safety belt, sling, or bosun chair is provided.

c. An insulating swivel shall be provided on all bosun chairs or baskets being used for welding.

13. Structures

Do not use handrails as a support for material or rigging.

14. Hazardous Materials

a. Do not use materials from, or place hazardous materials in, unlabeled containers.

b. Identify dismantled or relocated equipment which has been in "Hazardous Material" service.

c. Use for cleaning purposes only those solvents which are approved by your supervisor.

15. Compressed Air–Yard System

Do not use compressed yard air to clean clothing or personnel.

16. Compressed Gases

a. Do not release hazardous compressed gases into confined work spaces.

b. Do not use compressed gases to clean clothing or personnel.

17. Fire Prevention–Fire Fighting

a. Do not block fire-fighting equipment. (See Traffic Regulation–Item IV, page 23.)

b. Do not fight an electrical fire with a solid stream of water. Water fog may be applied to an electrical fire only by a qualified Fire Fighter.

III. PLANT SECURITY REGULATIONS

1. Parking Locations

Parking locations will be designated for each Contractor by Owner. If Contractor desires to park on Owner's property, all parking shall be in the lot, or area designated. Posted regulations governing the use of the lot shall be followed. All vehicles on Owner's property shall be at the risk of the vehicle owner and Owner accepts no responsibility for paint or other damage to or theft of or from such vehicles.

2. Entrance Gate

Owner will designate a gate or gates for the use of Contractor and for the delivery of its material and supplies. Contractor and vehicles serving the Contractor shall use only the designated gate for entrance and exit to and from the Contractor's job site. Contractor shall make arrangements so that vehicle drivers will know which gate to enter and the appropriate job site location.

3. Walks and Roadways

Walks and roadways will be as designated for the use of Contractor when entering or leaving the job site, when moving from one area to another, or when obtaining material from Owner. Contractor shall use only designated roadways and walks. The use of short cuts or nondesignated pathways is prohibited.

4. Contractor Badges and Contractor Passes

Contractor's employees shall wear their Contractor's badge at all times they are in the Plant. Badges shall bear the firm's name and each badge shall be numbered with a different number. Contractor shall supply these badges and maintain a record of badge numbers with employees' names. Employees engaged for engineering services shall be required to

wear badges furnished by Owner showing a number only. Badges must be shown to the gate Security Officer each time any employee of Contractor enters or leaves the Plant. When Subcontractors to the prime Contractor do not have their own badges, they may use the prime Contractor's badges.

5. Use of Subcontractors

The Contractor shall give the names of Subcontractors in writing to the appropriate Purchasing organization or the appropriate Technical Division prior to starting work.

6. Car Passes

Owner will issue car passes to Contractor's personnel who require a car in connection with the work. Requests for such passes shall be made to the Contact Man.

Contractor's vehicles, which bear the Contractor's name or insignia prominently displayed, will not require a car pass, providing the driver has a badge. Such vehicles shall be restricted to the use of designated street or streets and Plant entrance or entrances assigned for use of Contractor. All equipment on rubber tires, such as mobile cranes, back hoes, air compressors, welding machines, etc., must have Contractor's name prominently displayed on both sides when being used by Contractor.

7. Material Passes

All tools and materials, other than trash, that the Contractor removes from the Plant shall be accompanied by a material pass obtained from the Contact Man. The material pass shall be completely filled out and shall be signed by a designated representative of Contractor and the Contact Man. The Contact Man retains one copy, and the original and one copy shall accompany the material to the gate. Both copies are to be surrendered to the gate Security Officer.

8. Thefts

Owner accepts no responsibility or liability for the theft of any property or material belonging to Contractor or its employees. It shall be the responsibility of Contractor to furnish any police protection it deems necessary to supplement the guard and patrol service provided by Owner.

Owner maintains an investigative service and will cooperate with Contractor by assisting in the investigation of all reported thefts within the Plant. Thefts of property or automobiles from Owner's outside parking lots should be reported to local law enforcement officials. Contractor may obtain forms for reporting thefts from within the Plant from the Contact Man.

9. Gambling

All forms of gambling are prohibited on Owner's property.

10. Business Visitors, Applicants, and Delivery Trucks

Contractor shall furnish Plant Security with a list of persons who are authorized to pass business visitors, new employees, and delivery trucks to the job site. Plant Security will obtain authorization from one of these people before passing such individuals into the Plant. Special permission shall be obtained from the Contact Man to admit union business agents or safety inspectors other than contractor employed into the Plant.

11. Ambulance Service

Contractor, when working in Plant, shall make any arrangements Contractor deems necessary for ambulance service from an outside firm. Requests for an ambulance shall be called in to 427-5711, extension number 3600. Accident location, ambulance firm and hospital desired, and Contractor's name shall be given. Plant Security will escort the ambulance to the scene of the accident. All accidents shall be reported to the Contact Man as soon as possible, whether resulting in injury to a person or damage to the equipment of Owner or Contractor.

12. Inspection of Lunch Boxes, Packages, Motor Vehicles, etc.

Security Officers have the right to inspect lunch containers, packages, bundles, tools, equipment and motor vehicles in the Plant at any time.

13. Cameras and Photographs

Unauthorized individuals shall not be permitted to enter the Plant with a camera. When Contractor desires to have photographs taken in the Plant, approval must be obtained from Public Relations Department.

14. Liquor, Drugs, Firearms, and Explosives

Any person possessing intoxicating liquors or drugs, or who is under the influence of such, will not be permitted to enter the Plant or loiter on Owner's property.

Firearms and explosives will not be permitted in the plant.

15. Visiting and Loitering

Visiting and loitering by Contractor's employees at or around entrance gates or other places on Owner's property will not be permitted.

16. Fingerprinting

If requested by Owner, Contractor shall furnish the Owner two sets of fingerprints on each of his employees and each of his Subcontractor's employees.

IV. TRAFFIC REGULATIONS

1. Equipment Required on Motor Vehicles

All motor vehicles in the Plant must be in safe operating condition. When entering the Plant, all motor vehicles must display a valid state inspection sticker on the windshield. As a minimum, the following equipment must be in proper working condition for the vehicle to be considered safe: (1) brakes; (2) lights – two headlights, tail lights, brake light; (3) horn; (4) muffler; (5) safety glass; (6) windshield wiper and rear-view mirror. Vehicles having dual wheels shall be equipped with suitable flaps on each dual wheel so that objects will not be ejected past the flaps, to the rear, when the vehicle is in motion.

2. Driver's License

Motor vehicle drivers shall be qualified in accordance with driver's license regulations of the State of Texas.

3. Warning Flags

Red flags shall be used on any load that extends beyond the front, side, or rear of any vehicle.

4. Traffic Signs

All traffic signs and signals, whether fixed or portable, shall be obeyed, and drivers must cooperate with Owner's Security Officers and others appointed to direct traffic.

5. Speed Limit

All vehicles shall be operated within the Plant's speed limit of thirty miles per hour, unless otherwise posted.

6. Driving and Parking

Vehicles shall be driven on the right side of the street and parked on the right side of the street, except when parking in designated parking areas, or when directed otherwise by traffic signs or during emergencies. Vehicles shall not be parked on streets or roadways in such a manner as to slow down, hinder, or interfere with the free flow of traffic. Vehicles shall not be parked so as to block or interfere with the use of fire hydrants or fire equipment. The ignition key should be left in vehicles parked inside the Plants to permit moving of the vehicle to protect it from damage.

7. Right-of-Way

All motor vehicles shall give right-of-way to pedestrians, ambulances, fire-fighting equipment, and firemen (who will be identified by driving with lights on and horn sounding), and bicycles. Vehicles shall be pulled to one side and shall be brought to a complete stop when approached from either direction by an ambulance, or fire equipment and firemen (who will be identified by driving with their lights on and with horn sounding). Ordinary driving courtesy shall be practiced by all drivers of motor vehicles.

8. Passengers

a. Passengers shall be limited to a reasonable number determined by Owner and vehicle shall not be overcrowded.

b. Drivers of motor vehicles shall not permit passengers to ride on fenders, running boards, tops, or bumpers of motor vehicles. Passengers shall keep all parts of their bodies inside the cab or body of vehicles and shall be seated while vehicle is in motion.

c. Drivers of mobile equipment shall not permit passengers unless special accomodations have been provided.

d. Passengers shall not get on or off a vehicle while it is in motion.

9. Vehicles Prohibited

Motor bicycles or motorcycles are not permitted inside the Plants. Campers and recreational vehicles are not permitted in the Plant if loaded with gear or if they are otherwise difficult to inspect. Pressurized fuel containers shall be disconnected from refrigerators, stoves, etc. when the camper or recreational vehicle is in the Plant.

10. Windshield or Window Obstruction

Vehicles having nontransparent materials which interfere with clear visibility through any side window or windshield shall not be operated in the Plant. All vehicles shall be equipped with adequate rear-view devices.

11. "Road Closed" Signs

Areas blocked by traffic barriers, and/or "Road Closed" signs are closed to all traffic.

12. Obstructing Streets, Roads, Fire Equipment or Fire-Fighting Facilities

Contractor shall not block roads or streets without permission from the Contract Man. When Contractor's work obstructs a road or street, Contractor shall provide approved lights, barriers, warning devices, or signal men. Fire equipment, fire-fighting facilities, and fire hydrants shall not be blocked by parked vehicles.