

EXHIBIT IV

Synopsis of Results of Laboratory Tests
On Monokote, 1973 - 1983⁽¹⁾

<u>DATE</u>	<u>INDEPENDENT TESTING AGENCY</u>	<u>SUMMARY OF TEST RESULTS</u>
8/2/83	Environmental Sciences Laboratory, Mt. Sinai Medical Center, NY	Virtually free of asbestos form mineral fiber
7/12/83	Arthur D. Little, Inc.	A concentration of 9.8% characterization as to- tally insignificant
7/11/83	Mt. Sinai Medical Center	Virtually free of mineral fiber
7/11/83	Arthur D. Little, Inc.	No evidence for the pre- sence of amphibole (asbestos) fiber
6/27/83	Arthur D. Little, Inc.	Tremolite content estimated at 3.3 PPM (.0003%)
10/7/80	Pittsburgh Testing Laboratory	No asbestos fiber found
3/4/80	Arthur D. Little, Inc.	No asbestos fibers present
4/5/77	Arthur D. Little, Inc.	Tremolite content estimated at 5 PPM or less (.0005%)
4/76	Truesdail Laboratories, Inc.	Sample did not contain asbestos
5/5/71	Mt. Sinai Medical Center	Free of asbestos
10/70	Arthur D. Little, Inc.	No asbestos fibers observed

(1) Excludes results of a test reported by Mt. Sinai to a competitor on a
sample of unknown origin.