- I #7 Boilers

RECEIVED
SEP 25 1952
F. G. F., JR.

September 23, 1952

Bob B. Three things to do:
1/ Safety valve settings (particularly SH) must be same as present boilers. Check correspondence file + T.L.O.; The present settings aren't the original,
2/ What are the valves smaller than 1" doing.
3/ Why the 3 makes of valves. Omit the Vogt for Edward Unless there is some good reason.
F 9/25/52.

Mr. H. A. Thomas
Carbide & Carbon Chemicals Company
Construction & Purchasing Departments
South Charleston, West Virginia

Attention: Mr. J. Channing Hale

P. T. F.

CARBIDE & CARBON CHEMICALS COMPANY
DIVISION OF UNION CARBIDE & CARBON CORPORATION
INSTITUTE, WEST VIRGINIA - 9TH UNIT
RILEY CONTRACT B-2079 & A-5454

Gentlemen:

We are sending in the attached envelope four (4) prints each of the following drawings covering various valves and fittings. These drawings are for your information and files and do not require an approval. The reference numbers listed below refer to the numbers on our valves and fittings list, prints of which you have.

FOSTER ENGINEERING COMPANY

D33824 B3142A-1 C32258	Safety valves	Reference Nos. 1, 2 & 3

EDWARD VALVES INC.

AE-3413	1-1/2" & 2" Valves	Reference Nos. 12, 16, 22 & 23
AE-3372	3/8", 1/2", 3/4" and 1" Valves	" " 13, 15, 18, 19 & 24
AE-3414	1" Valves	" " 17.

MANNING, MAXWELL & MOORE INC.

A-5-2437	1" Valve	Reference No. 21
A-5-2230-WC	1-1/2" Valve	" " 20

Letter to J.C.H. 9/29/52 RHD

PLAINTIFF'S EXHIBIT
76041.00

UCASB01124274