

The correction factor for -20 F outside design temperature from Table 5 is 0.778. Solving, $0.778 \times 0.00476 = 0.00370$. Making a further correction for the heating value:

$$0.0037 \times \frac{140,000}{144,000} = 0.0036 \text{ gal per 1000 Btu per hr calculated heat loss per degree-day.}$$

From Table 1, the normal degree-days for Minneapolis are 7966. Since U is expressed in 1000 Btu, N is equal to 192. Substituting in Equation 4:

$$F = 0.0036 \times 7966 \times 192 = 5506 \text{ gal.}$$

Estimating Coal or Coke Consumption

Coal or coke consumption estimates are made by following exactly the same procedure as for oil. Values of U are given in Table 4 which only apply to an inside design temperature of 70 F and an outside design temperature of 0 F. A correction must be made for other conditions by use of the multiplying factors in Table 5. Data in Table 4 are based on 12,000 Btu per lb coal, and for other heating values of coal they must be multiplied by the ratio of 12,000 divided by the heating value of fuel used.

Example 7. A building in Marquette, Mich., has an hourly heat loss at design conditions of 240,000 Btu per hr. Based on an inside design temperature of 70 F and an outside design temperature of -20 F, what will be the estimated normal seasonal coal consumption for heating if 12,000 Btu per lb fuel is burned at a 50 per cent seasonal efficiency, and what part of the total will be used during November, December, and January?

Solution. From Table 4, U is 0.0666 lb of coal per 1000 Btu per hr heat loss. Correcting for the outside design temperature of -20 F from Table 5, the value of U is $0.778 \times 0.0666 = 0.0518$. From Table 1, D is 8745 and from the problem, N is 240.

Substituting in Equation 4:

$$F = 0.0518 \times 240 \times 8745 = 108,718 \text{ lb.}$$

Fuel used over any period is, according to the theory of the degree-day, proportional to the number of degree-days during the period. From Table 1, the average number of degree-days for November, December, and January in Marquette are 926, 1306, and 1465, a total of 3697. The yearly total is 8745, so that during these three months the estimated consumption is:

$$\frac{3697}{8745} \times 108,718 = 45,961 \text{ lb.}$$

Estimating Steam Consumption

In estimating steam consumption the efficiency is generally assumed at 100 per cent. If for low pressure steam an average heating value of 1000 Btu per pound of steam is used, no correction is necessary. In comparing values from different cities, correction should be made for design temperature (see Table 5) when the unit figures are in terms of square feet of radiation but not when the values are in terms of building volume or floor space.

Where the heat loss is calculated in Btu per (hour) (degree difference in temperature) the simple Equation 5 may be used:

$$F = \frac{H \times 24 \times D}{1000} \quad (5)$$

where

F = pounds of steam required for estimate period.

H = calculated heat loss, Btu per (hour) (degree difference).

D = number of degree days for the period of estimation.

1000 = Btu delivered per pound of steam condensed.

Estimating Fuel Consumption for Space Heating

In this method the number of degree-days automatically takes care of average inside and outside temperature difference. When degree days are taken from Table 1, an average inside temperature of approximately 65 F is assumed throughout the period. If an average inside temperature other than approximately 65 F is to be used, the number of degree-days should be obtained for the new base.

Example 8. An eight-story building in Pittsburgh maintains daytime temperatures of 70 F but allows night temperature to drop to not lower than 60 F. Its calculated heat loss is 10,500 Btu per (hr) (degree temperature difference). What is the estimated average yearly steam consumption for building heating?

Solution. Since the average inside temperature is approximately 65 F, the degree-days from Table 1, based on 65 F may be used. Therefore, from Table 1, Pittsburgh has 5430 degree-days per normal season. Inserting in Equation 5

$$F = \frac{10,500 \times 24 \times 5430}{1000} = 1,368,360 \text{ lb of steam.}$$

TABLE 6. STEAM CONSUMPTION OF BUILDINGS WITH VARIOUS TYPES OF OCCUPANCY*

TYPE OF BUILDING	No. BLDGS.	AVERAGE VOLUME HEATED SPACE 1000 CU FT	STEAM FOR HEATING	AVERAGE HOURS OF OCCUPANCY
			Lb per DD per 1000 Cu Ft	
Office.....	334	2160	0.685	12.1
Office and Bank.....	49	3000	0.577	13.1
Office and Printing.....	8	1895	1.230	17.7
Office and Theater.....	7	4950	0.412	12.9
Office and Stores or Shops.....	26	1615	0.617	13.2
Bank.....	16	806	0.786	11.7
Department Store.....	63	3400	0.385	11.1
Stores.....	73	310	0.624	10.4
Loft.....	63	865	0.588	10.0
Warehouse.....	24	2230	0.459	9.4
Hotel and Club.....	73	1795	0.990	22.3
Apartment or Residence.....	51	1425	0.962	21.8
Theater.....	22	1240	0.482	12.9
Garage.....	13	1540	0.202	21.4
Manufacturing.....	19	1350	0.808	9.5
Church.....	9	656	0.532	7.9
Hospital.....	4	3306	1.194	22.0
School.....	8	1115	0.592	11.5
Municipal or Federal.....	15	3215	0.587	15.6
Lodge, Gym, Hall or Auditorium.....	12	880	0.390	12.4
Miscellaneous.....	7	1387	0.479	21.4

* Principles of Economical Heating, National Association of Building Owners and Managers.

Consideration has been given to the difference in steam utilization of different types of buildings and Table 6 shows actual average units for these various types. These figures were obtained from operating results in 896 buildings located in all sections of the United States. Being averages, and for small groups in each type, the figures may need considerable modification to allow for local variations. It should be especially noted that the steam used for heating hot water is not included in the values given in Table 6.

Example 9. A store in Philadelphia with a heating system designed to maintain 70 F inside in 0 F weather has 250,000 cu ft of heated space. What would be the estimated average yearly steam consumption of purchased steam for heating?