
AMERICAN-Standard

APH

packaged oil-fired boilers


PLAINTIFF'S EXHIBIT

ASI-144



APH oil-fired packaged boiler — a compact, low-cost unit with big heating output

With the introduction of the new APH, American-Standard expands its line of light-weight, easy-to-install oil-fired boilers for low-cost residential hydronic heating systems. The APH will satisfy almost any home heating requirement—a most important factor in new construction. I=B=R approved outputs are rated at 115,000, 150,000 and 185,000 Btuh. The APH is available completely packaged in three sizes (4, 5, and 6 sections). For quick, easy installation, all controls are factory-mounted and pre-wired. For superior performance, the APH features: exclusive THERM-O-GRID section assembly; smooth-firing DH-5 Arcoflame burner and built-in air separation. The clean jacket lines are highlighted by attractive two-tone color scheme.



1—sturdy steel cabinet—is easily removable for servicing. Integral asbestos gasket forms gas-tight seal.


2—controls—are factory mounted, pre-wired and easily accessible for service. Two limit controls, with manual reset switch, offer an option for the maximum allowable leaving boiler water temperature of either 200°F or 250°F. Primary control features lightweight bimetallic actuator for instant response to ignition.


3—cast ceramic fiber refractory combustion chamber—is supported on a vermiculite-lined steel container sealed from suction assembly. Combustion chamber and container can be quickly and easily replaced as a single unit.

4—insulated steel jacket—features attractive two-tone styling with brown top and side panels, light beige front panel. Top and front are easily removable for access to section assembly and combustion area.

5—model DH-5 Arcoflame oil burner—is engineered to provide top operating efficiency. EXACT-AIRE control and special turbulators to combustion chamber insure proper air-oil mixture for clean, mechanical firing.

The exclusive THERM-O-GRID is a compact (15x15x3"), light weight (51 pound) cast iron section designed to produce a high ratio of heat output per pound, through the use of tubular-finned surfaces. When assembled in the boiler (far right) the tubes and fins oppose each other to increase flue gas turbulence and further improve heat transfer. Air removal is accomplished internally by using the ELIMINAIRE principle. Air is allowed to collect in the top section and pass directly to the expansion tank through a special tapping. No additional external device is necessary.





APH

packaged oil-fired boilers

APH ratings

boiler number	gross I=B=R output (Btu/hr)	net I=B=R ratings water (Btu/hr)	I=B=R burner capacity (gph)	chimney size (inches)	chimney height (feet)	water content (gallons)
APH-115	115,000	86,300	1.15	8 x 8	15	22
APH-150	150,000	112,500	1.45	8 x 8	15	24
APH-185	185,000	138,800	1.80	8 x 8	15	45


Note: Sizes, ratings furnished with APH packaged boilers: APH-115, 1.15-60° S; APH-150, 1.45-60° S; APH-185, 1.75-60° S.

Note: I=B=R ratings shown include allowance for normal piping and pick up load. American-Standard should be consulted before selecting a boiler for installations having unusual piping and pick up requirements.

Note: APH packaged boiler furnished for continuous forced hot water circulation only.

dimensions and tappings


boiler number	number of sections	tappings (inches) supply	tappings (inches) return	dimensions (inches) A	dimensions (inches) B
APH-115	3	1¼	1¼	37½	31⅛
APH-150	4	1¼	1¼	40½	34⅛
APH-185	5	1¼	1¼	43½	37⅛



crated dimensions

boiler number	dimensions (inches) H	W	L	approx. shipping weight* (pounds)
APH-115	39¼	27½	34	330
APH-150	42¼	27½	34	375
APH-185	45¼	27½	34	420

* Oil burner shipped in separate carton.



APH packaged oil-fired boilers are designed and built to comply with the American Society of Mechanical Engineer's Code, and bear their approval symbol. Ratings have been approved by the Institute of Boiler and Radiator Manufacturers. The Model DH-5 Arcoflame Oil Burner is listed by the Underwriters' Laboratories, Inc. for No. 1 and No. 2 fuel oil; complies with Commercial Standard CS-75; and is approved by the New York City Board of Standards and Appeals, by the State Fire Marshal of the Commonwealth of Massachusetts, and by the Department of State Police, State of Connecticut.


AMERICAN-Standard

HEATING AND PLUMBING DIVISION

APH

packaged oil-fired boilers

near boiler piping



■ for multiple zone or circuit operation

Procedure for filling series loop Heatrim System:

1. Close all zone valves except zone to be purged.
2. Open boiler drain valve.
3. Open fill valve.
4. Close purge valve.
5. Vent air from boiler by manually opening relief valve.
6. Open second valve to be purged. Close first zone. After second zone is purged, open third zone valve and close second zone. Repeat for as many zones as in system.


(Note: Always have one zone valve open.)

7. When all zones have been purged, close boiler drain valve.
8. When water appears at relief valve, release lever and allow to close.
9. Continue filling until pressure gauge reads approximately 12 lbs / sq. in. Close fill valve.
10. Open purge valve.

Note 1: Where multiple circuits are used, only one zone valve, balancing valves should be installed for balancing. These valves can be shut off to purge each circuit line individually.

Note 2: For a single loop Heatrim system, no additional zone valves, drains, or other accessories are required.

wiring diagrams



AMERICAN-Standard

PLUMBING AND HEATING DIVISION

AMERICAN RADIATOR & STANDARD SANITARY CORPORATION

40 WEST 40TH STREET • NEW YORK 18, NEW YORK