



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY

REGION 6
1445 ROSS AVENUE, SUITE 1200
DALLAS, TEXAS 75202-2733

APR 10 2012

CERTIFIED MAIL—RETURN RECEIPT REQUESTED: 7005 1820 0003 7453 8403

Ms. Linda E. Unger
Blueberry Hills Water Works
5902 Morningside Avenue
Dallas, TX 75206-5922

Re: PWS ID Number: TX0130018
Docket Number: SDWA-06-2012-1231

Dear Ms. Unger:

Enclosed is an Administrative Order (Order) issued to Blueberry Hills Water Works for violation of the Safe Drinking Water Act (Act), 42 U.S.C. § 300f, *et seq.*, and its implementing regulations, 40 C.F.R. Part 141. Specifically, this Order is issued for failure to provide drinking water that complies with the Maximum Contaminant Levels (MCL) for arsenic. The Environmental Protection Agency (EPA) finds that you own or operate the public water system (PWS) identified in the Order and are therefore subject to these regulations.

This Order requires immediate compliance with the MCL for Arsenic as set forth in Section 1412 of the Act, 42 U.S.C. § 300g-1. If compliance is not immediately possible, you must submit a treatment alternative with a construction and/or repair schedule that will achieve compliance no later than eighteen (18) months from the effective date of the enclosed Order. As described in the enclosed Order, Blueberry Hills Water Works is required to comply with the requirements to deliver drinking water that meets the national standard for arsenic and to conduct quarterly monitoring to ensure compliance with the MCL. Compliance with the MCL is based on a running annual average of the most recent four quarters. Please be aware that failure to comply with this Order may subject you to additional enforcement action by EPA, including the initiation of legal proceedings to seek monetary penalties.

EPA also wants you to be aware of a new process in place in Texas that was created to help facilities secure technical assistance and funding to address these types of issues. The Texas Water Infrastructure Coordination Committee (TWICC) was formed with representation from stakeholders, funding entities, and federal and state partners to identify water and wastewater infrastructure and compliance issues and to seek affordable, sustainable and innovative funding strategies for the protection of public health. If you feel your system could benefit from the TWICC, please let us know so that we can discuss the matter with you.


The PWS is also required to comply with all applicable Texas regulations in Title 30 Texas Administrative Code (TAC) Chapter 290, Subchapter D. Most treatment options require the submittal of engineering plans and specifications to the Texas Commission on Environmental Quality (TCEQ) for review and approval as indicated in 30 TAC § 290.39(j). The engineering plans and specifications and any pilot study report must be prepared by a Texas licensed professional engineer as required in 30 TAC §§ 290.39(d)(1) and 290.42(g), respectively. Please send engineering submittals to the TCEQ's Public Drinking Water section address referenced in paragraph J of the Order and include the EPA Docket Number.

Re: Blueberry Hills Water Works
Administrative Order

2

If you need assistance, or have questions regarding the Order, please contact Mr. Mehdi Taheri, of my staff, at (214) 665-2298. Please be aware that failure to comply with this Order may subject you to additional enforcement action by EPA, including the initiation of legal proceedings to seek monetary penalties.

Sincerely,


John Blevins
Director
Compliance Assurance and
Enforcement Division

Enclosure

cc: Mr. Bryan Sinclair
Director, Enforcement Division
Texas Commission on Environmental Quality

Ms. Linda Brookins
Director, Water Supply Division
Texas Commission on Environmental Quality

U. S. ENVIRONMENTAL PROTECTION AGENCY-REGION 6
FINDINGS OF VIOLATION AND COMPLIANCE ORDER
In the Matter of: Blueberry Hills Water Works Water System
Owned/Operated by Blueberry Hills Water Works, Respondent
Docket No. SDWA-06-2012-1231, PWS ID# TX0130018

STATUTORY AUTHORITY

The following findings are made and Order issued under the authority vested in the Administrator of the United States Environmental Protection Agency ("EPA"), by Section 1414(g) of the Safe Drinking Water Act ("Act"), 42 U.S.C. § 300g-3(g). The Administrator delegated the authority to issue this Order to the Regional Administrator of EPA Region 6, who further delegated such authority to the Director of the Compliance Assurance and Enforcement Division.

FINDINGS

1. Blueberry Hills Water Works ("Respondent") is a "person," as defined by Section 1401(12) of the Act, 42 U.S.C. § 300f(12).

2. At all times relevant to the violations alleged herein ("relevant time period"), Respondent owned or operated a public water system ("PWS"), as defined by Section 1401(4) of the Act, 42 U.S.C. § 300f(4), located in Dallas, Bee County, Texas ("facility"), and designated as PWS number TX0130018.

3. As a PWS and a "supplier of water," Respondent is subject to the regulations promulgated by EPA pursuant to Section 1412 of the Act, 42 U.S.C. § 300g-1, entitled "National Primary Drinking Water Regulations."

4. During the relevant time period, Respondent's PWS was a "Community water system" as defined by Section 1401(15) of the Act, 42 U.S.C. § 300f(15).

5. The Texas Commission on Environmental Quality ("TCEQ") and the EPA have enforcement authority for the PWS provisions of the Act in the State of Texas. TCEQ and EPA have consulted regarding this Order, and it has been agreed that EPA would initiate this enforcement action.

6. Respondent monitored for arsenic during each of the four quarters in 2011, resulting in a running annual average of 0.0113 mg/L at sampling point "EP002" and 0.0164 mg/L at sampling point "EP003" and 0.0139 mg/L at sampling point "EP005" that exceeded the arsenic

maximum contaminant level ("MCL") of 0.010 mg/L in violation of 40 C.F.R. § 141.62(b)(16).

7. Respondent is required to comply with the arsenic requirements of the Act, as set forth in Section 1412 of the Act, 42 U.S.C. § 300g-1.

ORDER

Based on these findings and pursuant to the authority of Section 1414(g) of the Act, 42 U.S.C. § 300g-3(g), EPA orders that Respondent immediately take the following actions:

A. In the event that public notice, as required by 40 C.F.R. § 141.201, has not been given by Respondent regarding the violations specified in paragraph 6, the Respondent shall, within thirty (30) days of issuance of this Order, provide a public notice of the violations as set forth in 40 C.F.R. § 141.201. Respondent shall submit a copy of the public notice to EPA and TCEQ within forty (40) days of issuance of this Order.

B. Within one hundred and twenty (120) days of the issuance date of this Order, Respondent shall submit to EPA a detailed plan to bring the PWS into compliance with the MCL for arsenic. The plan shall include: 1) a system modification proposal; 2) a cost analysis of system modifications; and 3) a construction schedule for the project. The schedule shall include specific milestone dates and a final compliance date that is no later than eighteen (18) months from the issuance date of this Order. The plans must be submitted to EPA for approval before construction can commence.

C. The approved schedule for construction and completion of modifications will be incorporated in a future administrative order.

D. Respondent must achieve and maintain compliance with 40 C.F.R. § 141.62(b)(16) by the date specified in the approved plan, or not later than eighteen (18) months after the issuance date of this Order.

E. Within ninety (90) days of the effective date of this Order, Respondent shall submit to EPA an initial report

on the progress made to bring the PWS into compliance with the arsenic MCL. Following the initial report, quarterly progress reports shall be due to EPA within ten (10) days after the end of each calendar quarter. Respondent shall notify EPA when all improvements have been completed.

F. The reporting required by this Order must be provided by the Respondent to EPA at the following address:

Mr. Mehdi Taheri
Water Enforcement Branch (6EN-W)
U.S. EPA, Region 6
1445 Ross Avenue, Suite 1200
Dallas, TX 75202-2733

G. Regarding part A in the Order section, Respondent shall submit a copy of the public notice to TCEQ at the following address:

Order Compliance Team
Enforcement Division, MC 149A
Texas Commission on Environmental Quality
P.O. Box 14087
Austin, TX 78711-3087

With a copy to:

Public Drinking Water Section
Water Supply Division, MC 155
Texas Commission on Environmental Quality
P.O. Box 13087
Austin, TX 78711-3087

H. Within fifteen (15) calendar days of the effective date of this Order, Respondent shall contact Mr. Mehdi Taheri in writing informing him whether Respondent will comply with the terms of this Order.

GENERAL PROVISIONS

This Order is effective upon receipt by Respondent.

This Order does not constitute a waiver, suspension, or modification of the requirements of 40 C.F.R. Part 141 or other applicable federal and state requirements, which remain in full force and effect. Issuance of this Order is not an election by EPA to forego any civil or any criminal action otherwise authorized under the Act.

Violation of any term of this Order may subject Respondent to an administrative civil penalty of up to \$32,500 under Section 1414(g) of the Act, 42 U.S.C. § 300g-3(g), or a civil penalty of not more than \$37,500 per day per violation, assessed by an appropriate United States District Court under Section 1414(g)(3)(A) of the Act, 42 U.S.C. § 300g-3(g)(3)(A).

This Order shall be binding on the PWS cited herein and all its successors, and assignees. No change in ownership of the PWS shall alter the responsibility of the PWS under this Order.

Date

4/10/12

John Blevins

Director

Compliance Assurance and
Enforcement Division