



Bell Laboratories

600 Mountain Avenue
Murray Hill, New Jersey 07974
Phone (201) 582-3000

August 22, 1980

Mr. A. B. Goetze
New Jersey Bell
540 Broad Street
Newark, NJ 07101

Dear Al:

The two bulk samples you delivered to me for asbestos analysis have been completed. Results are as follows:

281 Wash. Street Newark "Boiler Breech Undercoat-Slab"

An x-ray diffraction scan of this sample revealed that it contains an amphibole form of asbestos. Birefringent fibers with the optical and morphological characteristics of asbestos were seen in this sample when analyzed by dispersion staining optical light microscopy.

281 Wash. Street Newark "Boiler Breech Outer Coating"

An x-ray diffraction scan of this sample revealed that it contains chrysotile asbestos. Birefringent fibers with the optical and morphological characteristics of chrysotile asbestos were seen in this sample when analyzed by dispersion staining optical light microscopy.

If you have any questions regarding this analysis please give me a call at (201) 582-7512.

David Rainer
Field Industrial Hygienist

MH-1224-DR-dz

Copy to
See next page

CONFIDENTIAL

003625

Mr. A. B. Goetze - 2

Copy to
G. P. Bisgeier, M.D. - NJB

R. L. Beach - AT&T

J. M. Degen ← THIS COPY FOR ←

N. J. Decapua

R. W. Stone, M.D.

W. J. Schreibeis

G. M. Wilkening

CONFIDENTIAL

003626