

NOTICE: If the film image is less than 1/16 inch, it is due to the quality of the document being reproduced.

CONFIDENTIAL
46601 AB

(TYPE 46601AA)
MATERIAL 46601AA thru AB
HEAT INSULATING BLOCK, HIGH TEMPERATURE
FURNISHED BY -
(For 46601AA) (For PH) Suppliers
(For SU) D-E-F-G-H (For 46601AA) (For PH) Suppliers
C A-B-J

Feb 20, 1962

SUPPLIERS

- (A) Baldwin-Ehret-Hill, Inc. 1153 Araming Ave. Trenton 2, N J
- (B) Eagle-Picher Co. 1956 American Blvd. Cincinnati 1, Ohio
- (C) Fibreboard Paper Prod Corp. Pabco Ins. Co. San Francisco 19, Cal
- (D) Johns-Manville, 22 E 40th St. N Y 18, N Y
- (E) Reasbey & Mattison Co. 1956 Ambler, Pa
- (F) Owens-Corning Fiberglas Corp. Toledo, Ohio
- (G) Philip Carey Mfg Co. Wayne Ave at Cooper, Cincinnati 15, Ohio
- ORDER FROM SUPPLIER AS - (A) Baldwin Hill Mono Block Insulation*
- (B) Eagle Picher PV Supertech Block Insulation*
- (C) Prasco 15C High Temperature Block Insulation*; or Pabco Precision Molded Castemp Block Insulation*
- (D) Suprex M Block Insulation*
- (E) K & M Hy-Temp Block Insulation*
- (F) Kaylo 20 Block Insulation*
- (G) Carey Hi-Temp 12 Block Insulation*
- (H) Enduro Hi-Temp Block Insulation*
- (J) Banroc HT Block Insulation*

*NOTE: State size and shape
Printed in U.S.A. (Over)

PRODUCED
1/18/92
DALLAS COUNTY

PLAINTIFF'S
EXHIBIT
WH-75

DOCUMENTS PRODUCED DALLAS COUNTY CASES 3/18/92

NOTICE: If the film image is less clear than the
original, it is due to the quality of the document being imaged.

CONFIDENTIAL

CHARACTERISTICS - (46601AA)(Previous 7309-1)(Previous 7309)
(Users:PH,SU)Heat insulating block made of high temperature
calcium silicate or diatomaceous earth, asbestos and other con-
pounds bonded together, having high temperature resisting proper-
ties and desired heat insulating value. Standard sizes are 3" x
13" and 6" x 36", flat or curved and 1/4" to 4" thick.
(46601AB)(Previous 7309-2)(Users:PH,SU)Heat insulating block
made of bonded mineral wool. Resistant to water absorption.
Approved size is 2" x 6" x 13".

APPLICATION - (46601AA)Heat insulation for steam turbines and
steam piping for temperatures up to 1600 F.
(46601AB)Heat insulation for steam turbines for temperatures up
to 1700 F where resistance to moisture is required.

SPECIFY AS - INS BLOCK 46601AA or AB, whichever is applicable

Issues: Std. Dept., Matl. Labs., E. Pgh., Pa.

DOCUMENTS PRODUCED DALLAS COUNTY CASES 3/18/92