House Heating Load Characteristics as They Affect Wiring Costs, by Jack B. Cocbran (*Electrical World*, April 12, 1947).

Low-Voltage, High-Current Radiant House Heating (*Electrical World*, January 3, 1948, p. 39).

Radiant Heating by Electricity, by L. N. Roberson (*Heating and Ventilating*, September 1946, p. 89).

Radiant Heating, by F. M. Tiller (*Chemical Products*, March-April 1945).

Applications of Radiant Energy (Lighting Handbook, *Illuminating Engineering Society*, 1947, Section 16).

Industrial Applications of Infra-red, by J. D. Hall, (McGraw-Hill Book Co., 1947).

Faster Baking and Drying with Infra-red Heat, by Paul H. Goodell (*Electrical World*, June 21 and July 5, 1947).

Electric Radiant Heat vs. Steam Convection, by Douglas Dow (*Electrical World*, August 10, 1940, p. 61-62).

Infra-red vs. Convection Ovens for Drying Paint Coatings, by F. J. Gschwind (*Industrial Finishing*, September 1945).

Recent Advancements in Industrial Heating Processes and Equipment, by Eugene Mittelman (*Industrial Heating*, September 1944).

Heating of Non-magnetic Electric Conductors by Magnetic Induction, by R. M. Baker (*Electrical Engineering*, June 1944).

Operating Experience with HF Heating, by Henderson C. Gillespie (*Electronic Industries*, February 1944).

Unusual Methods of Applying Electronic Heat, by E. D. Tillson (*Electronics*, April 1945).

Dielectric Heating, by T. W. Dakin and R. W. Auxier (*Industrial and Engineering Chemistry*, March 1945).

Induction and Dielectric Heating, by Kennard Pinder (*Electrical Engineering*, February 1947).

High Frequency Heating in the Radio Spectrum by W. C. Rudd (*Electrical Engineering*, June 1947).

Standard Handbook for Electrical Engineers, McGraw Hill Book Co.

CHAPTER 31

PANEL HEATING AND RADIANT HEATING

Influence of Heat Radiation on Human Comfort, Objectives of Radiant Heating, Practical Problems of Radiant Heating from a Physiological Standpoint, Fundamental Computations, Application Methods, Calculation Principles, Measurement and Control

IT has been pointed out in Chapter 12 that the human body loses heat to its environment in three ways; by convection, radiation, and evaporation. The Effective Temperature Chart takes account of convection and evaporation, but does not provide for such radiative effects as occur when room air and its surrounding surfaces differ widely in temperature.

INFLUENCE OF HEAT RADIATION ON HUMAN COMFORT

When, however, the body is exposed to radiation from a hot surface or is radiating to a cold surface, the factor of radiative heat gain or heat loss may be important. This phenomenon is most marked in the case of exposure to the sun's radiative heat. On a cold day, with no wind blowing, while standing in the sunshine, one may feel perfectly comfortable but, when a cloud passes over the sun, one may instantly feel much cooler. The cloud acts as a shield to interrupt the radiant heat from the sun. The change in feeling of comfort is due to the instant change in rate of heat loss from the body caused by the shielding effect of the cloud. A shielded thermometer under the same condition would register no change in temperature.

The rate of heat loss by convection depends upon the average temperature difference between the surface of the body and the surrounding air, the shape and size of the body, and the rate of air motion over the body.

The rate of heat loss by radiation depends upon the exposed surface area of the body, and upon the difference between the mean surface temperature of the body and the mean surface temperature of the surrounding walls or other objects. This latter temperature is called the Mean Radiant Temperature (MRT).

Because these two types of heat loss supplement each other, a required rate of total heat loss can result either from a relatively low air temperature and a relatively high MRT, or vice versa.

At the temperature which produces comfort (and at all lower temperatures) the production of sweat is low and the heat loss by evaporation is relatively low and relatively constant, irrespective of the relative humidity of the atmosphere. Under such conditions the heat loss from the body is chiefly related to the combined effect of convection and radiation. For unclothed subjects in a reclining posture the heat demand of the environment, so far as these two factors of radiation and convection are concerned, may be measured by Operative Temperature, whichis defined by the following formula, modified from that of Gagge[1] by the expression of air velocity in feet per minute and the various temperatures in Fahrenheit degrees,