

TABLE 2. THERMODYNAMIC PROPERTIES OF MOIST AIR* (STANDARD ATMOSPHERIC PRESSURE, 29.921 IN. Hg) (Continued)

FAHR. TEMP. (°F)	HUMIDITY RATIO $W_a \times 10^3$	VOLUME CU FT/LB DRY AIR			ENTHALPY BTU/LB DRY AIR			ENTROPY BTU PER (°F) (LB DRY AIR)			CONDENSED WATER			FAHR. TEMP. (°F)
		v_a	v_{as}	v_s	h_a	h_{as}	h_s	s_a	s_{as}	s_s	Enthalpy Btu/Lb h_w	Entropy Btu/(Lb) (°F) s_w	Vap. Press In. Hg $p_s \times 10^3$	
7	1.130	11.756	0.021	11.777	1.681	1.202	2.883	0.00384	0.00271	0.00635	-155.61	-0.3172	5.4022	7
8	1.189	11.781	0.022	11.803	1.922	1.266	3.188	0.00415	0.00285	0.00700	-155.13	-0.3182	5.6832	8
9	1.251	11.806	0.024	11.830	2.162	1.332	3.494	0.00467	0.00299	0.00766	-154.65	-0.3152	5.9776	9
10	1.315	11.831	0.025	11.856	2.402	1.401	3.803	0.00518	0.00314	0.00832	-154.17	-0.3141	6.2858	10
11	1.383	11.857	0.026	11.883	2.642	1.474	4.116	0.00569	0.00330	0.00899	-153.69	-0.3131	6.6085	11
12	1.454	11.882	0.028	11.910	2.882	1.550	4.432	0.00620	0.00346	0.00966	-153.21	-0.3121	6.9462	12
13	1.528	11.907	0.029	11.936	3.123	1.630	4.753	0.00671	0.00363	0.01034	-152.73	-0.3111	7.2997	13
14	1.606	11.933	0.030	11.963	3.363	1.713	5.076	0.00721	0.00380	0.01101	-152.24	-0.3100	7.6696	14
15	1.687	11.958	0.032	11.990	3.603	1.800	5.403	0.00772	0.00399	0.01171	-151.76	-0.3090	8.0565	15
16	1.772	11.983	0.034	12.017	3.843	1.892	5.735	0.00822	0.00418	0.01240	-151.27	-0.3080	8.4612	16
17	1.861	12.009	0.035	12.044	4.083	1.988	6.071	0.00873	0.00438	0.01311	-150.78	-0.3070	8.8843	17
18	1.953	12.034	0.038	12.072	4.324	2.088	6.412	0.00923	0.00459	0.01382	-150.29	-0.3059	9.3267	18
19	2.051	12.059	0.040	12.099	4.564	2.192	6.758	0.00973	0.00481	0.01454	-149.80	-0.3049	9.7889	19
20	2.152	12.084	0.042	12.126	4.804	2.302	7.106	0.01023	0.00504	0.01527	-149.31	-0.3039	10.2732	20
21	2.258	12.110	0.044	12.154	5.044	2.416	7.460	0.01073	0.00528	0.01601	-148.82	-0.3029	10.777	21
22	2.369	12.135	0.046	12.181	5.284	2.536	7.820	0.01123	0.00553	0.01676	-148.33	-0.3018	11.305	22
23	2.485	12.160	0.049	12.209	5.525	2.661	8.186	0.01173	0.00579	0.01752	-147.84	-0.3008	11.855	23
24	2.606	12.186	0.051	12.237	5.765	2.792	8.557	0.01223	0.00607	0.01830	-147.34	-0.2998	12.431	24
25	2.733	12.211	0.054	12.265	6.005	2.929	8.934	0.01273	0.00635	0.01908	-146.85	-0.2988	13.032	25
26	2.865	12.236	0.057	12.293	6.245	3.072	9.317	0.01322	0.00665	0.01987	-146.35	-0.2977	13.659	26
27	3.003	12.262	0.059	12.321	6.485	3.221	9.706	0.01372	0.00696	0.02068	-145.85	-0.2967	14.313	27
28	3.147	12.287	0.062	12.349	6.728	3.377	10.103	0.01421	0.00728	0.02149	-145.36	-0.2957	14.966	28
29	3.297	12.312	0.065	12.377	6.968	3.540	10.508	0.01470	0.00761	0.02231	-144.86	-0.2947	15.709	29
30	3.454	12.338	0.068	12.406	7.206	3.709	10.915	0.01519	0.00796	0.02315	-144.36	-0.2936	16.452	30
31	3.617	12.363	0.071	12.434	7.446	3.887	11.333	0.01568	0.00832	0.02400	-143.86	-0.2926	17.227	31
32	3.788	12.388	0.075	12.463	7.686	4.072	11.758	0.01617	0.00870	0.02487	-143.36	-0.2916	18.035	32
32*	3.788	12.388	0.075	12.463	7.686	4.072	11.758	0.01617	0.00870	0.02487	0.04	0.0000	18.037	32*
33	3.944	12.413	0.079	12.492	7.927	4.242	12.189	0.01666	0.00904	0.02570	1.05	0.0020	18.778	33
34	4.107	12.438	0.082	12.520	8.167	4.418	12.658	0.01715	0.00940	0.02655	2.06	0.0041	19.546	34
35	4.275	12.464	0.085	12.549	8.407	4.601	13.068	0.01764	0.00977	0.02741	3.06	0.0061	20.342	35
36	4.450	12.489	0.089	12.578	8.647	4.791	13.438	0.01812	0.01016	0.02828	4.07	0.0081	21.166	36
37	4.631	12.514	0.093	12.607	8.887	4.987	13.874	0.01861	0.01056	0.02917	5.07	0.0102	22.020	37

* Compiled by John A. Goff and S. Gratch.

* Extrapolated to represent metastable equilibrium with undercooled liquid.

TABLE 2. THERMODYNAMIC PROPERTIES OF MOIST AIR* (STANDARD ATMOSPHERIC PRESSURE, 29.921 IN. Hg) (Continued)

FAHR. TEMP. (°F)	HUMIDITY RATIO $W_a \times 10^3$	VOLUME CU FT/LB DRY AIR			ENTHALPY BTU/LB DRY AIR			ENTROPY BTU PER (°F) (LB DRY AIR)			CONDENSED WATER			FAHR. TEMP. (°F)
		v_a	v_{as}	v_s	h_a	h_{as}	h_s	s_a	s_{as}	s_s	Enthalpy Btu/Lb h_w	Entropy Btu/(Lb) (°F) s_w	Vap. Press In. Hg p_s	
38	4.818	12.540	0.097	12.637	9.128	5.191	14.319	0.01909	0.01097	0.03006	6.08	0.0122	0.22904	38
39	5.012	12.565	0.101	12.666	9.368	5.403	14.771	0.01957	0.01139	0.03096	7.08	0.0142	0.23819	39
40	5.213	12.590	0.105	12.695	9.608	5.662	15.230	0.02005	0.01183	0.03188	8.09	0.0162	0.24767	40
41	5.421	12.616	0.109	12.725	9.848	5.949	15.697	0.02053	0.01228	0.03281	9.09	0.0182	0.25748	41
42	5.638	12.641	0.114	12.755	10.088	6.084	16.172	0.02101	0.01275	0.03376	10.09	0.0202	0.26763	42
43	5.860	12.666	0.119	12.785	10.329	6.328	16.657	0.02149	0.01323	0.03472	11.10	0.0222	0.27813	43
44	6.091	12.691	0.124	12.815	10.569	6.580	17.149	0.02197	0.01373	0.03570	12.10	0.0242	0.28899	44
45	6.331	12.717	0.129	12.846	10.809	6.841	17.650	0.02245	0.01425	0.03670	13.10	0.0262	0.30023	45
46	6.578	12.742	0.134	12.876	11.049	7.112	18.161	0.02293	0.01478	0.03771	14.10	0.0282	0.31185	46
47	6.835	12.767	0.140	12.907	11.289	7.391	18.680	0.02340	0.01534	0.03874	15.11	0.0302	0.32386	47
48	7.100	12.792	0.146	12.938	11.530	7.681	19.211	0.02387	0.01591	0.03978	16.11	0.0321	0.33629	48
49	7.374	12.818	0.151	12.969	11.770	7.981	19.751	0.02434	0.01650	0.04084	17.11	0.0341	0.34913	49
50	7.658	12.843	0.158	13.001	12.010	8.291	20.301	0.02481	0.01711	0.04192	18.11	0.0361	0.36240	50
51	7.952	12.868	0.164	13.032	12.250	8.612	20.862	0.02528	0.01774	0.04302	19.11	0.0381	0.37611	51
52	8.256	12.894	0.170	13.064	12.491	8.945	21.436	0.02575	0.01839	0.04414	20.11	0.0400	0.39028	52
53	8.569	12.919	0.178	13.097	12.731	9.289	22.020	0.02622	0.01906	0.04528	21.12	0.0420	0.40492	53
54	8.894	12.944	0.185	13.129	12.971	9.644	22.615	0.02669	0.01976	0.04646	22.12	0.0439	0.42004	54
55	9.229	12.970	0.192	13.162	13.211	10.01	23.222	0.02716	0.02047	0.04763	23.12	0.0459	0.43555	55
56	9.575	12.995	0.200	13.195	13.452	10.39	23.841	0.02762	0.02121	0.04883	24.12	0.0478	0.45176	56
57	9.934	13.020	0.208	13.228	13.692	10.79	24.48	0.02809	0.02197	0.05006	25.12	0.0497	0.46840	57
58	10.30	13.045	0.216	13.261	13.932	11.19	25.12	0.02855	0.02276	0.05131	26.12	0.0517	0.48558	58
59	10.69	13.071	0.224	13.295	14.172	11.61	25.78	0.02902	0.02357	0.05259	27.12	0.0536	0.50330	59
60	11.08	13.096	0.233	13.329	14.413	12.05	26.46	0.02948	0.02441	0.05389	28.12	0.0555	0.52159	60
61	11.49	13.121	0.242	13.363	14.653	12.50	27.15	0.02994	0.02527	0.05521	29.12	0.0574	0.54047	61
62	11.91	13.147	0.251	13.398	14.893	12.96	27.85	0.03040	0.02616	0.05656	30.12	0.0594	0.55994	62
63	12.35	13.172	0.261	13.433	15.134	13.44	28.57	0.03086	0.02708	0.05794	31.12	0.0613	0.58002	63
64	12.80	13.197	0.271	13.468	15.374	13.94	29.31	0.03132	0.02803	0.05935	32.12	0.0632	0.60073	64
65	13.26	13.222	0.282	13.504	15.614	14.45	30.06	0.03177	0.02901	0.06078	33.11	0.0651	0.62209	65
66	13.74	13.247	0.292	13.539	15.855	14.98	30.83	0.03223	0.03002	0.06225	34.11	0.0670	0.64411	66
67	14.24	13.273	0.303	13.576	16.095	15.53	31.62	0.03269	0.03106	0.06376	35.11	0.0689	0.66681	67
68	14.75	13.298	0.315	13.613	16.335	16.09	32.42	0.03314	0.03212	0.06527	36.11	0.0708	0.69019	68
69	15.28	13.323	0.327	13.650	16.576	16.67	33.25	0.03360	0.03323	0.06683	37.11	0.0727	0.71430	69

* Compiled by John A. Goff and S. Gratch.