



INTER-COMPANY AND OFFICE CORRESPONDENCE

To: G. D. Bevis

FROM: S. Cirelli

LOCATED AT: Leominster, MA

{ Dept.
Branch
Division
Company

SUBJECT: Plant EPA Construction

DATE: September 14, 1978

Request approval for the following punch list items:

1. For the centrifugal pumps in the recovery building, provide city water to pump seals instead of service water.
2. Hot D.I. water system - provide S.S. flex lines to absorb hammer in solid lines.
3. Calibrate Bacharach system in recovery building (manufacturer).
4. Repair steam leaks.
5. Install agitator in waste water transfer tank.

S. Cirelli
Senior Process Engineer

SC/sma

cc: W. Colonis
R. Slocumb
D. L. Young

BOR 002983