



## NPDES Compliance Sampling Inspection Report

Delhi POTW  
42032 State Hwy 10  
Delhi, NY 13753

Permit Number: NY0020265

Inspection date: 30 JUN 2022

### Participating Personnel:

#### US Environmental Protection Agency

Neal R. Johansen, Physical Scientist  
Robert Morrell, Professional Geologist  
Thuan Tran, Physical Scientist

#### Delhi POTW

David Hornbeck, Plant Chief

### Report Submitted By:

Johansen,  
Neal

Digitally signed by  
Johansen, Neal  
Date: 2022.08.25  
14:55:22 -04'00'

---

Neal R. Johansen, Physical Scientist

### Approved By:

PHILIP  
COCUZZA

Digitally signed by PHILIP  
COCUZZA  
Date: 2022.08.25  
15:01:56 -04'00'

---

Phil Cocuzza, Branch Chief  
Monitoring Assessments Branch

## **1.0 OBJECTIVE**

On June 30, 2022, at the request of the United States Environmental Protection Agency (US EPA), a National Pollution Discharge Elimination System (NPDES) Compliance Sampling Inspection (CSI) was conducted at the Delhi Public Owned Treatment Works (POTW) in Delhi, New York. The objective of the CSI was to determine the facility's compliance with the requirements and limitations of State Pollution Discharge Elimination System (SPDES) permit number NY0020265.

## **2.0 KEY PARTICIPANTS**

Listed below are key inspection participants and contact information, grouped by organization.

### U.S. Environmental Protection Agency

Neal R. Johansen, Physical Scientist (732) 321-6691  
Robert Morrell, Professional Geologist (732) 906-6804  
Thuan Tran, Physical Scientist (732) 321-4456

### Delhi POTW

David Hornbeck, Plant Chief, Phone: (607) 746-3638

## **3.0 FACILITY DESCRIPTION**

### 3.1 General Information

Delhi POTW is located at Route 10 Delhi, New York. The actual facility location can better be described as, 42032 State Hwy 10 Delhi. The facility is a moderately sized Public Owned Treatment Works. It is a multi-building, multi-level complex that began operations in 1971. The facility has been regularly upgraded throughout the years. The facility has full time staffing depending on the time of day and round-the-clock on call staffing as required by the computerized monitoring system. The specific North American Industrial Classification System (NAICS) code is 221320, for Sewage Treatment Facilities. The facility has multiple structures on an adequate amount of land with sufficient parking. It has three fulltime employees that maintain the plant regularly. The plant's most recent permit became effective on 13 April 2013. The permit expired on 31 March 2018, with no letter of extension on file. However, the facility does have a letter of explanation on file.

### 3.2 Process Information

The plant has an average water outflow that varies throughout the day per influent level requirements. During the time of inspection, the plant was being operated with full flow from both the industrial users and the municipality. An external lift pump is used to move influent up to the plant, for processing, from the municipality. The permit requires monitoring of the daily maximum discharge with reporting of monthly average flow. The maximum daily allowable discharge is 1.0 Million Gallons Daily (MGD). The permitted discharge location for outfall 001 is to the western branch of the Delaware River. Outfall 001 is required to be monitored during its constant discharge.

Influent water enters the plant system and is passed through a simple screening process. At this point excess grease, rags and debris are manually removed for disposal at the county landfill. The screened inlet water is then pumped to the plant's processing structure. The screened wastewater flows to an aeration tank. It then flows to a secondary clarifier, or an aerobic digester. The wastewater is then sent to a chlorination tank, a filter tank, and a dechlorination tank. It is then discharged through outfall 001. Storm water runoff from the facility is untreated, and gravity flows to the west branch of the Delaware River.

### 3.3 Facility Self-Monitoring Information

The wastewater from the Delhi POTW is analyzed on site by staff for flow, temperature, pH, chlorine, nitrogen, phosphorous, Total Suspended Solids (TSS), and settleable solids. The following parameters are analyzed by the Phoenix Laboratory for Carbonaceous Biological Oxygen Demand (CBOD<sub>5</sub>), TSS, phosphorus, nitrogen, ammonia, and fecal coliform bacteria. They are a state certified laboratory. They are located at 587 Middle Turnpike E, Manchester, CT 06040. Plant personnel collect grab samples and conduct onsite analysis during processing. Laboratory results are issued monthly on the Discharge Monitoring Reports (DMR) as required by permit number NY0020265.

## **4.0 EPA SAMPLING / INSPECTION ACTIVITIES**

### 4.1 Sampling Activities

Grab samples were collected from outfall 001 and the influent chamber. The effluent samples were analyzed onsite for, pH, chlorine, temperature, and settleable solids. Total flow for the 24-hour time period was obtained from the facility personnel. Additional grab samples were collected from the influent and also the effluent of outfall 001. These samples were delivered to the USEPA Edison, New Jersey Laboratory. They were analyzed for CBOD<sub>5</sub>, TSS, ammonia, turbidity, fecal coliform, and phosphorous. All sample containers, and preservation techniques conformed to

USEPA requirements specified in 40 CFR Part 136. A chain-of-custody was created on site for all samples and signed over to laboratory personnel upon delivery. The complete analytical data package is attached with the report.

4.2 Inspection Activities

On the day of the sampling inspection, a short opening conference and safety brief was conducted with the facility Plant Chief Mr. David Hornbeck. The inspectors presented identification and credentials and explained the nature of the inspection. Mr. David Hornbeck then provided a tour and explanation of the facility and its features. Grab samples were collected, and measurements were also gathered from the influent chamber and effluent of outfall 001. Multiple DMR's covering three different months were examined electronically.

**5.0 ANALYTICAL RESULTS**

**Delhi Public Owned Treatment Works, Delhi, NY  
CSI**

**June 30, 2022**

<b>Parameter</b>	<b>Units</b>	<b>Permit Limit</b>	<b>EPA Result Influent</b>	<b>EPA Result Effluent</b>	<b>Testing Result</b>
<b>pH</b>	S.U.	7 to 9	NA	7.1	Within Limit
<b>Temperature</b>	°F	70	NA	78.0	Monitor
<b>Flow</b>	MGD	1.0	0.6	0.6	Within Limit
<b>Chlorine, Free</b>	µg/L	32	NA	100	Exceeds Limit
<b>Settleable Solids</b>	ml/L	0.1	4.5	0.01	Within Limit
<b>Total Ammonia</b>	mg/L	7.7	7.83	0.102	Within Limit
<b>Carb. Biological Oxygen Demand (CBOD<sub>5</sub>)</b>	mg/L	25	57.3	4.02	Within Limit
<b>CBOD<sub>5</sub> Percent Removal</b>	%	85	NA	97.7	Within Limit
<b>Total Suspended Solids (TSS)</b>	mg/L	10	100	10 U	Within Limit
<b>TSS Percent Removal</b>	%	85	NA	90.0 U	Within Limit
<b>Phosphorous</b>	mg/L	0.11	1.69	0.05 U	Within Limit
<b>Fecal Coliform</b>	#/100 mL	200	NA	6.8	Within Limit
<b>Turbidity</b>	NTU	0.5	27.7	0.207	Within Limit

U: Not detected value is the reporting limit

## **6.0 FINDINGS**

### **6.1 Sampling Result Findings**

The DMR's examined did not show any reporting errors and appear to be submitted in the required time frame. Laboratory results indicate that the effluent limitations of SPDES permit number NY0020265 page 4 are being met with one exception. The chlorine discharge is exceeding the maximum allowed limit.

The clarifiers had algal growth in the clarifier weirs. However, staff were actively maintaining and cleaning the issue before and during the inspection. The plant appears to be in good condition and is upgraded regularly. It was requested that for this inspection the influent values would be obtained for ammonia, turbidity and phosphorous along with the standard influent sample collection. This was requested to help provide data points for additional pretreatment inspections that were happening in the area on the same day. The values are included in the data table above.

## **7.0 ATTACHMENTS**

Photographs (#1- #4)  
Laboratory Data Report  
Chain of Custody

PHOTO LOG

Photo #1: Influent



Photo #2: Effluent Outfall 001



**Photo #3:** Delhi Plant



**Photo #4:** Delhi Plant





**UNITED STATES ENVIRONMENTAL PROTECTION AGENCY**

**Region 2 Laboratory  
2890 Woodbridge Avenue  
Edison, New Jersey 08837  
732-906-6886 Phone  
732-906-6165 Fax**

July 14, 2022

Neal Johansen  
Monitoring & Assessment Branch  
LSASD/MAB  
Edison, NJ 08837

RE: Delhi, NY - 2206022

Enclosed are the results of analyses for samples received by the laboratory on 06/30/2022. The signature below reflects the laboratory's approval of the reported results. If you have any questions concerning this report, please refer to Project Number 2206022 and contact the laboratory.

Sincerely,

John R. Bourbon  
Chief, LSASD/LB



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY  
Region 2 Laboratory

Final Report  
Project: Delhi, NY - 2206022  
Project Number: 2206022

**Project Narrative:**

The National Environmental Laboratory Accreditation Conference Institute (TNI) is a voluntary environmental laboratory accreditation association of State and Federal agencies. TNI established and promoted a National Environmental Laboratory Accreditation Program (NELAP) that provides a uniform set of standards for the generation of environmental data that are of known and defensible quality. The EPA Region 2 Laboratory is NELAP accredited. The Laboratory tests that are accredited have met all the requirements established under the TNI Standards.

Condition Comments

None

Comment(s):

The "Sample Analysis Date and Time" is included in the results section for any analyte with a prescribed holding time of 72 hours or less.

Data Qualifier(s):

- U- The analyte was not detected at or above the Reporting Limit.
- J- The identification of the analyte is acceptable; the reported value is an estimate.
- K- The identification of the analyte is acceptable; the reported value may be biased high.
- L- The identification of the analyte is acceptable; the reported value may be biased low.
- NJ- There is presumptive evidence that the analyte is present; the analyte is reported as a tentative identification. The reported value is an estimate.

---

U.S.E.P.A Region 2 Laboratory

**NOTE:** The results recorded in this report relate only to the samples as received on the date and at the time noted  
Reported: 7/14/2022

Page 1 of 10



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY  
Region 2 Laboratory

Final Report  
Project: Delhi, NY - 2206022  
Project Number: 2206022

Reporting Limit(s):

The Laboratory was able to achieve the appropriate limit for each analyte requested.

SUMMARY REPORT FOR SAMPLES

Field ID	Laboratory ID	Matrix	Date Sampled	Date Received
220220630 A I	2206022-01	Aqueous	06/30/2022 10:47	06/30/2022 15:00
220220630 A E	2206022-02	Aqueous	06/30/2022 10:49	06/30/2022 15:00
220220630 CBOD I	2206022-03	Aqueous	06/30/2022 10:50	06/30/2022 15:00
220220630 CBOD E	2206022-04	Aqueous	06/30/2022 10:52	06/30/2022 15:00
220220630 P I	2206022-05	Aqueous	06/30/2022 10:54	06/30/2022 15:00
220220630 P E	2206022-06	Aqueous	06/30/2022 10:56	06/30/2022 15:00
220220630 TSS I	2206022-07	Aqueous	06/30/2022 10:57	06/30/2022 15:00
220220630 TSS E	2206022-08	Aqueous	06/30/2022 10:58	06/30/2022 15:00
220220630 T I	2206022-09	Aqueous	06/30/2022 10:59	06/30/2022 15:00
220220630 T E	2206022-10	Aqueous	06/30/2022 11:00	06/30/2022 15:00
220220630 COL E	2206022-11	Aqueous	06/30/2022 11:02	06/30/2022 15:00

---

U.S.E.P.A Region 2 Laboratory

**NOTE:** The results recorded in this report relate only to the samples as received on the date and at the time noted  
Reported: 7/14/2022



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY  
Region 2 Laboratory

**Final Report**  
Project: Delhi, NY - 2206022  
Project Number: 2206022

SUMMARY REPORT FOR METHODS

Analysis	Method	Certification	Matrix
Ammonia [As N]	EPA 350.1 SOP C-80 Rev 2.7	NELAP	Aqueous
Biochemical Oxygen Demand, Carb.	SM 5210B SOP C-21 Rev 2.7	NELAP	Aqueous
Coliform, Fecal	SM 9221B,E SOP B-8 Rev 2.7	NELAP	Aqueous
Phosphorus	EPA 365.1 SOP C-68 Rev 2.7	NELAP	Aqueous
Residue, Non-Filterable	SM 2540D SOP C-33 Rev 3.7	NELAP	Aqueous
Turbidity	EPA 180.1 SOP C-81 Rev 2.7	NELAP	Aqueous

---

U.S.E.P.A Region 2 Laboratory

**NOTE:** The results recorded in this report relate only to the samples as received on the date and at the time noted  
Reported: 7/14/2022

Page 3 of 10



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY  
 Region 2 Laboratory

Final Report  
 Project: Delhi, NY - 2206022  
 Project Number: 2206022

Analyte	Result	Qualifier	Reporting Limit	Units	Batch	Date and Time of Analysis*
<b>Field ID: 220220630 A I</b>		<b>Sample ID: 2206022-01</b>				
Sanitary						
Ammonia [As N]	7.83		0.100	mg/L	B207008	
<b>Field ID: 220220630 A E</b>		<b>Sample ID: 2206022-02</b>				
Sanitary						
Ammonia [As N]	0.102		0.100	mg/L	B207008	
<b>Field ID: 220220630 CBOD I</b>		<b>Sample ID: 2206022-03</b>				
Sanitary						
Biochemical Oxygen Demand, Carb.	57.3		2.00	mg/L	B207002	07/06/2022 07:44
<b>Field ID: 220220630 CBOD E</b>		<b>Sample ID: 2206022-04</b>				
Sanitary						
Biochemical Oxygen Demand, Carb.	4.02		2.00	mg/L	B207002	07/06/2022 07:44
<b>Field ID: 220220630 P I</b>		<b>Sample ID: 2206022-05</b>				
Sanitary						
Phosphorus	1.69		0.0500	mg/L	B207039	
<b>Field ID: 220220630 P E</b>		<b>Sample ID: 2206022-06</b>				
Sanitary						
Phosphorus	---	U	0.0500	mg/L	B207039	
<b>Field ID: 220220630 TSS I</b>		<b>Sample ID: 2206022-07</b>				
Sanitary						
Total Suspended Solids	100		10.0	mg/L	B207005	
<b>Field ID: 220220630 TSS E</b>		<b>Sample ID: 2206022-08</b>				
Sanitary						
Total Suspended Solids	---	U	10.0	mg/L	B207005	
<b>Field ID: 220220630 T I</b>		<b>Sample ID: 2206022-09</b>				
Sanitary						

U.S.E.P.A Region 2 Laboratory

NOTE: The results recorded in this report relate only to the samples as received on the date and at the time noted  
 Reported: 7/14/2022



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY  
 Region 2 Laboratory

Final Report  
 Project: Delhi, NY - 2206022  
 Project Number: 2206022

Analyte	Result	Qualifier	Reporting Limit	Units	Batch	Date and Time of Analysis*
Field ID: 220220630 T I			Sample ID: 2206022-09			
Sanitary						
Turbidity	27.7		0.100	NTU	B207003	07/01/2022 08:40
Field ID: 220220630 T E			Sample ID: 2206022-10			
Sanitary						
Turbidity	0.207		0.100	NTU	B207003	07/01/2022 08:40
Field ID: 220220630 COL E			Sample ID: 2206022-11			
Microbiology, MPN						
Coliform, Fecal	6.8		1.8	MPN/100 mL	B206155	07/01/2022 14:00

U.S.E.P.A Region 2 Laboratory

NOTE: The results recorded in this report relate only to the samples as received on the date and at the time noted  
 Reported: 7/14/2022



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY  
 Region 2 Laboratory

Final Report  
 Project: Delhi, NY - 2206022  
 Project Number: 2206022  
 Sanitary - Quality Control

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit
<b>Batch B207002</b>									
<b>Blank (B207002-BLK1)</b>									
Biochemical Oxygen Demand, Carb.	--- U	2.00	mg/L						
<b>LCS (B207002-BS1)</b>									
Biochemical Oxygen Demand, Carb.	176		mg/L	198.0		88.8	84.6-115.4		
<b>LCS (B207002-BS2)</b>									
Biochemical Oxygen Demand, Carb.	172		mg/L	198.0		86.7	84.6-115.4		
<b>LCS (B207002-BS3)</b>									
Biochemical Oxygen Demand, Carb.	179		mg/L	198.0		90.5	84.6-115.4		
<b>Duplicate (B207002-DUP1) Source: 2206033-01</b>									
Biochemical Oxygen Demand, Carb.	2.32	2.00	mg/L		2.10			9.87	25
<b>Matrix Spike (B207002-MS1) Source: 2206022-03</b>									
Biochemical Oxygen Demand, Carb.	512	2.00	mg/L	396.0	57.3	115	75-125		
<b>Matrix Spike Dup (B207002-MSD1) Source: 2206022-03</b>									
Biochemical Oxygen Demand, Carb.	460	2.00	mg/L	396.0	57.3	102	75-125	10.5	200
<b>Batch B207003</b>									
<b>Blank (B207003-BLK1)</b>									
Turbidity	--- U	0.100	NTU						
<b>Blank (B207003-BLK2)</b>									
Turbidity	--- U	0.100	NTU						

U.S.E.P.A Region 2 Laboratory

NOTE: The results recorded in this report relate only to the samples as received on the date and at the time noted  
 Reported: 7/14/2022



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY  
 Region 2 Laboratory

**Final Report**  
**Project: Delhi, NY - 2206022**  
**Project Number: 2206022**  
**Sanitary - Quality Control**

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit
<b>Batch B207003</b>									
<b>LCS (B207003-BS1)</b>									
Turbidity	19.7	0.100	NTU	19.90		99.0	90-110		
<b>LCS Dup (B207003-BSD1)</b>									
Turbidity	19.6	0.100	NTU	19.90		98.5	90-110	0.509	20
<b>Duplicate (B207003-DUP1) Source: 2206022-10</b>									
Turbidity	0.215	0.100	NTU		0.207			3.79	20
<b>Batch B207005</b>									
<b>Blank (B207005-BLK1)</b>									
Residue, Non-Filterable	--- U	10.0	mg/L						
<b>Blank (B207005-BLK2)</b>									
Residue, Non-Filterable	--- U	10.0	mg/L						
<b>LCS (B207005-BS1)</b>									
Residue, Non-Filterable	53.0	10.0	mg/L	54.30		97.6	85-115		
<b>LCS (B207005-BS2)</b>									
Residue, Non-Filterable	56.0	10.0	mg/L	54.30		103	85-115		
<b>LCS Dup (B207005-BSD1)</b>									
Residue, Non-Filterable	56.0	10.0	mg/L	54.30		103	85-115	5.50	20
<b>LCS Dup (B207005-BSD2)</b>									
Residue, Non-Filterable	54.0	10.0	mg/L	54.30		99.4	85-115	3.64	20

U.S.E.P.A Region 2 Laboratory

**NOTE:** The results recorded in this report relate only to the samples as received on the date and at the time noted  
 Reported: 7/14/2022



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY  
 Region 2 Laboratory

Final Report  
 Project: Delhi, NY - 2206022  
 Project Number: 2206022  
 Sanitary - Quality Control

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit
<b>Batch B207005</b>									
<b>Duplicate (B207005-DUP1)</b> Source: 2206033-01									
Residue, Non-Filterable	--- U	10.0	mg/L		4.00				20
<b>Batch B207008</b>									
<b>Blank (B207008-BLK1)</b>									
Ammonia [As N]	--- U	0.100	mg/L						
<b>Blank (B207008-BLK2)</b>									
Ammonia [As N]	--- U	0.100	mg/L						
<b>LCS (B207008-BS1)</b>									
Ammonia [As N]	14.7	1.00	mg/L	14.90		99	90-110		
<b>LCS (B207008-BS2)</b>									
Ammonia [As N]	14.6	1.00	mg/L	14.90		98	90-110		
<b>LCS Dup (B207008-BSD1)</b>									
Ammonia [As N]	14.6	1.00	mg/L	14.90		98	90-110	0.7	20
<b>LCS Dup (B207008-BSD2)</b>									
Ammonia [As N]	14.8	1.00	mg/L	14.90		99	90-110	1	20
<b>Matrix Spike (B207008-MS1)</b> Source: 2206022-01									
Ammonia [As N]	9.88	0.100	mg/L	5.000	7.83	41	90-110		
<b>Matrix Spike (B207008-MS2)</b> Source: 2206033-01									
Ammonia [As N]	5.00	0.100	mg/L	5.000	0.0795	98	90-110		

U.S.E.P.A Region 2 Laboratory

NOTE: The results recorded in this report relate only to the samples as received on the date and at the time noted  
 Reported: 7/14/2022



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY  
 Region 2 Laboratory

Final Report  
 Project: Delhi, NY - 2206022  
 Project Number: 2206022  
 Sanitary - Quality Control

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit
<b>Batch B207008</b>									
<b>Matrix Spike (B207008-MS3)</b>		<b>Source: 2206034-01</b>							
Ammonia [As N]	4.97	0.100	mg/L	5.000	0.164	96	90-110		
<b>Batch B207039</b>									
<b>Blank (B207039-BLK1)</b>									
Phosphorus	--- U	0.0500	mg/L						
<b>Blank (B207039-BLK2)</b>									
Phosphorus	--- U	0.0500	mg/L						
<b>LCS (B207039-BS1)</b>									
Phosphorus	2.23	0.250	mg/L	2.220		100	90-110		
<b>LCS (B207039-BS2)</b>									
Phosphorus	2.27	0.250	mg/L	2.220		102	90-110		
<b>LCS Dup (B207039-BSD1)</b>									
Phosphorus	2.24	0.250	mg/L	2.220		101	90-110	0.4	20
<b>LCS Dup (B207039-BSD2)</b>									
Phosphorus	2.26	0.250	mg/L	2.220		102	90-110	0.4	20
<b>Matrix Spike (B207039-MS1)</b>		<b>Source: 2206034-01</b>							
Phosphorus	1.31	0.0500	mg/L	1.000	0.344	97	90-110		
<b>Matrix Spike (B207039-MS2)</b>		<b>Source: 2206022-05</b>							
Phosphorus	2.50	0.250	mg/L	1.000	1.69	81	90-110		

U.S.E.P.A Region 2 Laboratory

NOTE: The results recorded in this report relate only to the samples as received on the date and at the time noted  
 Reported: 7/14/2022



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY  
 Region 2 Laboratory

Final Report

Project: Delhi, NY - 2206022

Project Number: 2206022

Sanitary - Quality Control

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit
<b>Batch B207039</b>									
<b>Matrix Spike (B207039-MS3)</b>									
Source: 2206033-01									
Phosphorus	2.28	0.250	mg/L	1.000	1.41	87	90-110		

U.S.E.P.A Region 2 Laboratory

**NOTE:** The results recorded in this report relate only to the samples as received on the date and at the time noted  
 Reported: 7/14/2022

US EPA REGION 2 LABORATORY  
**CHAIN OF CUSTODY/ FIELD DATA FORM**

Page 1 of 2 pages

PROJECT LEADER Neal Johnson  
 PROGRAM RESULTS CODE

PROJECT NAME & LOCALITY Delhi  
 PROGRAM SF  : SITE ID \_\_\_\_\_ OPERABLE UNIT \_\_\_\_\_  
 RCRA D210  RCRA ENF D307  NPDES B304  SDWA C215  AM B224  CAA A305  TSCA  OO  FIFRA  CRIMINAL ENF   
 L305 B253

Permit #: \_\_\_\_\_  
 AB ID/ FIELD ID \_\_\_\_\_

DESCRIPTION & INSTRUCTIONS INCLUDING LOCATION, ESTIMATED CONCENTRATIONS, SPECIAL REPORTING LIMITS.

AB ID/ FIELD ID	MATRIX	CHECK IF SPLIT SAMPLE	PRESERVATIVE (circle)	Collection Time (24hr clock)		Collection Date (mm/dd/yy)
				Begin	End	
022.06.30 AE	1 A	<input type="checkbox"/>	0	10:45	10:47	06/30/22
022.06.30 AE	1 A	<input type="checkbox"/>	0	10:45	10:47	06/30/22
022.06.30 C&P	1 A	<input type="checkbox"/>	0	10:45	10:47	06/30/22
022.06.30 C&P	2 A	<input type="checkbox"/>	0	10:51	10:54	06/30/22
022.06.30 PI	1 A	<input type="checkbox"/>	0	10:51	10:54	06/30/22
022.06.30 PE	1 A	<input type="checkbox"/>	0	10:51	10:54	06/30/22
022.06.30 TSS	1 A	<input type="checkbox"/>	0	10:56	10:57	06/30/22
022.06.30 TSS	1 A	<input type="checkbox"/>	0	10:57	10:58	06/30/22
022.06.30 TI	1 A	<input type="checkbox"/>	0	10:58	10:59	06/30/22
022.06.30 TB	1 A	<input type="checkbox"/>	0	10:59	11:00	06/30/22

COMMENTS & SPECIAL REQUIREMENTS:

Res CL Checked  Preservative Added & Checked

0-ice 7-FAS  
 1-H2SO4 pH<2 8-ZnAc  
 2-HNO3 pH<2 9-NaOH pH>12  
 3-HCl pH<2 10-NH4Cl  
 4-Na2S2O3  
 5-NaOH pH>9  
 6-Ascorbic Acid

Person Assuming Responsibility for Sample(s):  
Neal Johnson  
 Received By: \_\_\_\_\_  
 Received By: \_\_\_\_\_  
 Received By: \_\_\_\_\_

Relinquished By: \_\_\_\_\_  
 Relinquished By: \_\_\_\_\_  
 Relinquished By: \_\_\_\_\_

Matrix:  F-multiphasic  
 G-solvent  
 H-bioa  
 I-ocl  
 J-other

Survey Complete? Y  N

US EPA REGION 2 LABORATORY  
 CHAIN OF CUSTODY/ FIELD DATA FORM

Page 2 of 2 pages

SURVEY NAME & LOCALITY: Delhi  
 PROGRAM: SF  : SITE ID: \_\_\_\_\_ OPERABLE UNIT: \_\_\_\_\_  
 PROJECT LEADER: Axel Johansen  
 PROGRAM RESULTS CODE: \_\_\_\_\_

Decision Unit Code: Y206 RCRA D210 RCRA D307 RCRA ENF  NPODES B304  SDWA C215 AM  CAA A305  
 TSCA  L306 OD  FIFRA  CRIMINAL ENF  B253

Permit #: \_\_\_\_\_  
 LAB ID/ FIELD ID: 2022-0630-064E / A

DESCRIPTION & INSTRUCTIONS INCLUDING LOCATION, ESTIMATED CONCENTRATIONS, SPECIAL REPORTING LIMITS:  
COLLECTOR

LAB ID/ FIELD ID	MATRIX	CHECK IF SPLIT SAMPLE	RES GL CHECKED	PRESERVATIVE (circle)	COLLECTION TIME (24hr clock)		COLLECTION DATE
					Begin	End	
<u>2022-0630-064E / A</u>		<input type="checkbox"/>	<input checked="" type="checkbox"/>	<u>012345678910</u>	<u>1101</u>	<u>1102</u>	<u>06/30/22</u>
		<input type="checkbox"/>	<input type="checkbox"/>	<u>012345678910</u>			
		<input type="checkbox"/>	<input type="checkbox"/>	<u>012345678910</u>			
		<input type="checkbox"/>	<input type="checkbox"/>	<u>012345678910</u>			
		<input type="checkbox"/>	<input type="checkbox"/>	<u>012345678910</u>			
		<input type="checkbox"/>	<input type="checkbox"/>	<u>012345678910</u>			
		<input type="checkbox"/>	<input type="checkbox"/>	<u>012345678910</u>			
		<input type="checkbox"/>	<input type="checkbox"/>	<u>012345678910</u>			
		<input type="checkbox"/>	<input type="checkbox"/>	<u>012345678910</u>			
		<input type="checkbox"/>	<input type="checkbox"/>	<u>012345678910</u>			
		<input type="checkbox"/>	<input type="checkbox"/>	<u>012345678910</u>			

COMMENTS & SPECIAL REQUIREMENTS:

Matrix: A-aqueous B-aqueous (chlorinated) C-soil D-sediment E-sludge	Matrix: F-multiphasic G-solvent H-bioa I-oil J-other	Person Assuming Responsibility for Sample(s): <u>Axel Johansen</u>	Time <u>1102</u>	Date <u>06/30/22</u>
Relinquished By: _____	Relinquished By: _____	Received By: _____		
Relinquished By: _____	Relinquished By: _____	Received By: _____		
Relinquished By: _____	Relinquished By: _____	Received By: _____		

Survey Complete? Y  N