

Monsanto

FROM (NAME & LOCATION)

Leonard Hamilton - Texas City (Ext. 3518)

PLAINTIFF'S EXHIBIT

MON-1228

DATE

May 17, 1985

CC

SUBJECT

Safety and Housekeeping Inspection
2nd Quarter 1985

REFERENCE

TO

:

D. A. Barfoot
✓ R. T. Hammann

51D
0-22

In response to the comments on the Fire Station from the 2nd Quarter 1985 inspection, one utility hose was found to need an inspection and appropriate marking. This has been done. Crowsfoot clips were installed where needed. The nitrogen cylinders were stenciled - nitrogen labels were not available for this purpose.

L. Hamilton/d

Leonard Hamilton

/dgb

SC

000317

LAM001514