7093756

PLAINTIFF'S EXHIBIT WRG-567

WRG 000364

CONFIDENTIAL

September 23, 1970

TO: R. L. Asher/Zono-Boca Raton (P)
R. E. Dunham/Zono-Minneapolis Office
W. G. Gray/Zono-Dearborn
L. P. Hollis/Zono-High Point
J. A. McEachern/Zono-St. Louis
C. R. Lowe/Zono-Atlanta (V)
C. H. Wendel/Zono-Los Angeles Office

FROM: T. F. Egan

cc: R. M. Vining
K. W. Harrison
R. W. Sterrett
B. R. Williams
J. N. Beveridge

Gentlemen:

On Friday, September 18, we tested a blend floor deck and beam assembly protected with MK-4, non-asbestos fireproofing. The deck reached limiting temperature at two hours two minutes (122 minutes) but had drop off on the flat plate sections. The test ran for four hours, and the beam temperatures appeared equal to or better than MK-3. This is encouraging, but we must wait for the UL engineers to complete the study of test data.

I recommend and urge a restrained attitude on our part. We will not have total equivalency from this test, but we may have enough to satisfy particular air pollution and code officials for particular projects

Our research team is continuing their efforts for the best product that will get total UL equivalency.

I will be in touch on or about October 1, to clarify our position, UL ratings, pricing and other pertinent data.

Yours truly,

Thomas F. Egan

TFE/jac

25052981

ZONOLITE
CONSTRUCTION PRODUCTS DIVISION

CONFIDENTIAL

September 23, 1970

TO: R. L. Asher/Zono-Boca Raton (P)
R. E. Dunham/Zono-Minneapolis Office
W. G. Gray/Zono-Dearborn
L. P. Hollis/Zono-High Point
J. A. McEachern/Zono-St. Louis
C. R. Lowe/Zono-Atlanta (V)
C. H. Wendel/Zono-Los Angeles Office

FROM: T. F. Egan

cc: R. M. Vining
K. W. Harrison
R. W. Sterrett
B. R. Williams
J. N. Beveridge

Gentlemen:

On Friday, September 18, we tested a blend floor deck and beam assembly protected with MK-4, non-asbestos fireproofing. The deck reached limiting temperature at two hours two minutes (122 minutes) but had drop off on the flat plate sections. The test ran for four hours, and the beam temperatures appeared equal to or better than MK-3. This is encouraging, but we must wait for the UL engineers to complete the study of test data.

I recommend and urge a restrained attitude on our part. We will not have total equivalency from this test, but we may have enough to satisfy particular air pollution and code officials for particular projects

Our research team is continuing their efforts for the best product that will get total UL equivalency.

I will be in touch on or about October 1, to clarify our position, UL ratings, pricing and other pertinent data.

Yours truly,

Thomas F. Egan

PLAINTIFF'S EXHIBIT
Eschenbach 69
8-7-86

TFE/jac