



REGION 8
1595 Wynkoop Street
Denver, CO 80202-1129

February 5, 2025

Ref: 8WD-SDR

SENT VIA EMAIL

Tom Lewis, Managing Member
Cedar Springs Meadows
P.O. Box 905
Thayne, Wyoming 83127
telewis@silverstar.com

Re: Notice of Noncompliance
Lead and Copper Rule
Failure to Perform Lead Consumer Notice
PWS ID# WY5601720 C

Dear Tom Lewis:

The purpose of this letter is to inform you that the Cedar Springs Meadows Public Water System submitted the lead consumer notification for the monitoring period of June 1 to September 30, 2024 late. According to 40 C.F.R. § 141.85(d) of the National Primary Drinking Water Regulations (NPDWR), all water systems are required to provide a consumer notice of the individual lead tap water results to the persons served by the System as soon as practical, but no later than 30 days after the System learns of the tap monitoring results. Certification of consumer notification was due to the EPA 90 days after the end of the monitoring period, or by December 29, 2024 (40 C.F.R. § 141.90).

This is to inform you that the EPA received the lead consumer notice documents late on January 18, 2025, and the system has been returned to compliance.

You should be aware that repeated violations of the NPDWR may result in formal enforcement action taken against the System. If formal enforcement action were to be necessary, the Safe Drinking Water Act provides for civil judicial penalties of up to \$71,545 per day of violation. We prefer to address problems before such formal enforcement is necessary, and we ask for your cooperation to resolve them quickly and effectively.

If you have questions, please contact the Lead and Copper Rule Compliance Manager, Bolor Bertelmann directly at (303) 312-6233, or by email at bertelmann.bolor@epa.gov.

Sincerely,

**SETH
TOURNEY**

Digitally signed by SETH
TOURNEY
Date: 2025.02.05 11:19:52
-07'00'

Seth Tourney, P.E.
Supervisor, Rule Implementation Section
Drinking Water Program

cc:

Jason Mavy, Contract Operator
Star Valley Water
jason@starvalleywater.com

Steve Heath, Project Engineer
steveh@hleinc.com