

Standard⁹ in the formulation of its ratings and has compiled a tentative standard of heating effect allowances for various enclosure heights to be included in the ratings by its members.

All published ratings bearing the title *C.M.C. Ratings (Convactor Manufacturers Certified Ratings)* indicate that the convectors have been tested in accordance with the A.S.H.V.E. Code by an impartial and disinterested laboratory and that the ratings have been approved by the Standardization Committee of the *Convactor Manufacturers Association*.

Concealed heaters or convectors are generally sold as completely built-in units. The enclosing cabinet should be designed with suitable air inlet and outlet grilles to give the heating element its best performance. Tables of capacities are catalogued for various lengths, depths and heights, and combinations are available in several styles for installations, such as the wall-hung type, free-standing floor type, recess type set flush with wall or offset, and the completely concealed type. Most of these types may be arranged with a top outlet grille in a plane parallel with the floor, although the front outlet is practically standard. In cases where enclosures are to be used but are not furnished by the heater manufacturer, it is important that the proportions of the cabinet and the grilles be so designed that they will not impair the performance of the assembled convector. It is important that the enclosure or housing for the convector fit as snugly as possible so that the air to be heated must pass through the convector and cannot be by-passed in the enclosure.

The output of a convector, for any given length and depth, is a variable of the height. Published ratings are generally given in terms of equivalent square feet, corrected for heating effect. However, an extended surface heating unit is entirely different structurally and physically from a direct radiator and, since it has no area measurement corresponding to the heating surface of a radiator, many engineers believe that the performance of convectors should be stated in Btu. For steam convectors, as for radiators, 240 Btu per hour may be taken as an equivalent square foot of radiation. When more than one heating unit is used, one mounted above the other in the same cabinet, the output of the upper unit or units will be materially less than that of the bottom unit.

RADIATOR AND CONVECTOR SELECTION

The capacity of a radiator varies as the 1.3 power, and that of a convector¹⁰ as the 1.5 power of the temperature difference between the heating medium and the surrounding air in the case of the radiators, and the entering air in the case of the convector. It is obvious that for conditions other than the basic ones with the heating medium at a temperature of 215 F, and the room temperature at 70 F in the case of a radiator, and the inlet air temperature at 65 F in the case of a convector, the heat emission will be other than 240 Btu per square foot of rating.

Table 4 shows factors by which radiation requirements, as determined by dividing heat load by 240, shall be multiplied to obtain proper radiator

⁹A.S.H.V.E. Standard Code for Testing and Rating Concealed Gravity Type Radiation (Steam). (A.S.H.V.E. TRANSACTIONS, Vol. 37, 1931, p. 367); (Hot Water). (A.S.H.V.E. TRANSACTIONS, Vol. 39, 1933, p. 237).

¹⁰A.S.H.V.E. RESEARCH REPORT No. 998—Factors Affecting the Heat Output of Convectors, by A. P. Kratz, M. K. Fahnestock, and E. L. Broderick (A.S.H.V.E. TRANSACTIONS, Vol. 40, 1934, p. 443).

TABLE 4. CORRECTION FACTORS FOR DIRECT CAST-IRON RADIATORS AND CONVECTOR HEATERS^a

STEAM PRESS. APPROX.	HEATING MEDIUM TEMP. F STEAM OR WATER	FACTORS FOR DIRECT CAST-IRON RADIATORS								FACTORS FOR CONVECTORS							
		ROOM TEMPERATURE F								INLET AIR TEMPERATURE F							
		80	75	70	65	60	55	50		80	75	70	65	60	55	50	
Gage Vacuum In. Hg.	Abs. Lb per Sq In.																
22.4	3.7	150	2.58	2.36	2.17	2.00	1.86	1.73	1.62	3.14	2.83	2.57	2.35	2.15	1.98	1.84	
20.3	4.7	160	2.17	2.00	1.86	1.73	1.62	1.52	1.44	2.57	2.35	2.15	1.98	1.84	1.71	1.59	
17.7	6.0	170	1.86	1.73	1.62	1.52	1.44	1.35	1.28	2.15	1.98	1.84	1.71	1.59	1.49	1.40	
14.6	7.5	180	1.62	1.52	1.44	1.35	1.28	1.21	1.15	1.84	1.71	1.59	1.49	1.40	1.32	1.24	
10.9	9.3	190	1.44	1.35	1.28	1.21	1.15	1.10	1.05	1.59	1.49	1.40	1.32	1.24	1.17	1.11	
6.5	11.5	200	1.28	1.21	1.15	1.10	1.05	1.00	0.96	1.40	1.32	1.24	1.17	1.11	1.05	1.00	
Lb per Sq In.																	
1	15.6	215	1.10	1.05	1.00	0.96	0.92	0.88	0.85	1.17	1.11	1.05	1.00	0.95	0.91	0.87	
6	21	230	0.96	0.92	0.88	0.85	0.81	0.78	0.76	1.00	0.95	0.91	0.87	0.83	0.79	0.76	
15	30	250	0.81	0.78	0.76	0.73	0.70	0.68	0.66	0.83	0.79	0.76	0.73	0.70	0.68	0.65	
27	42	270	0.70	0.68	0.66	0.64	0.62	0.60	0.58	0.70	0.68	0.65	0.63	0.60	0.58	0.56	
52	67	300	0.58	0.57	0.55	0.53	0.52	0.51	0.49	0.56	0.54	0.53	0.51	0.49	0.48	0.47	

^aTo determine the size of a radiator or a convector for a given space, divide the heat loss in Btu per hour by 240 and multiply the result by the proper factor from the above table.

To determine the heating capacity of a radiator or a convector under conditions other than the basic ones with the heating medium at a temperature of 215 F, and the room temperature at 70 F in the case of a radiator, and the inlet air temperature at 65 F in the case of a convector, divide the heating capacities at the basic conditions by the proper factor from the above table.

or convector sizes from published rating tables for room temperatures ranging between 50 and 80 F as well as for steam or water temperatures from 150 to 300 F. For other room and heating medium temperatures the factor is determined by the following formulae:

For radiators:

$$C_s = \left(\frac{215 - 70}{t_s - t_r} \right)^{1.3}$$

where

C_s = correction factor.

t_s = steam temperature, degrees Fahrenheit.

t_r = room temperature, degrees Fahrenheit.

t_i = average inlet air temperature, degrees Fahrenheit.

For convectors:

$$C_s = \left(\frac{215 - 65}{t_s - t_i} \right)^{1.5}$$

As previously indicated, the output of radiators and convectors is still designated by the terms of older practice, but this is gradually giving place to an engineering method of designating heat emission. The A.S.H.V.E. has adopted the following standards: Code for Testing Radiators (1927); Codes for Testing and Rating Concealed Gravity Type Radiation (Steam), 1931, and (Hot Water), 1933, (see also A.S.H.V.E. TRANSACTIONS, Vol. 41, 1935, p. 38).

For steam services the actual condensation weight is taken without any allowance for heating effect; for hot water services the weight of circulated water is used without allowance for heating effect. In all cases the total heat transmission varies as the 1.3 power for radiators¹¹ and the 1.5 power for convectors¹² of the temperature difference between that inside the radiator and the air in the room, and is expressed in Btu or Mb per hour.

¹¹Loc. Cit. Note 9.

¹²Loc. Cit. Notes 9 and 10.