




TER COMPANY CORRESPONDENCE

TO - NAME		DEPT	DIVISION	FILE CODE	DATE April 8, 1969
Mr. D. L. Eschelbach		Chief Industrial Hygiene Department	Personnel		PLANT OFFICE Highland Park
FROM - NAME		DEPT	DIVISION		PLANT OFFICE
Mr. F. E. Repucci		Personnel Manager	Chemical		Trenton
SUBJECT <u>ASBESTOS DUST</u>					



The recommendations of the Industrial Hygiene department regarding the two areas found to be above the maximum allowable concentration for asbestos dust by the State of Michigan Department of Public Health dust study on February 13, 1969 were discussed with you on your visit to the Trenton plant on March 25, 1969. (1). The exhaust ventilation system at B6 was checked by you and is in operable condition. (2). The exhaust ventilation at the chute opening on the Ripel disc brake pad preform press will be revised as you suggested with a hood larger than the chute opening so that the operator's hand with the container will be within the hood when the contents are dumped into the chute. This should provide satisfactory control. Mr. Hasselkus and Mr. Lombard will make certain that the installation is completed before the equipment is returned to production which at the present time is not scheduled for two or three months.

F. E. Repucci
F. E. Repucci

FER/mh

cc: W. F. Ravinger
R. F. Bowers
S. C. Enders
K. L. Hasselkus
E. R. Lombard
N. A. Trombley

RECEIVED

APR 11 1969

INDUSTRIAL HYGIENE
DEPARTMENT