

ELECTRICAL SAFETY AND RELIABILITY AUDIT CHECK LIST
FOR
MOTOR CONTROL CENTERS (MCC'S)

MCC LOCATION I.D. #: MCC G
MCC EQUIPMENT I.D. #: _____

MCC's -----	Yes	No	N/A
1. Is the MCC equipped with a main disconnect?	_____	☒	_____
2. Is the MCC equipped with molded case circuit breakers?	☒	_____	_____
3. Is the working space clear in front of all MCC's?	☒	_____	_____
4. Are all MCC's properly grounded?	☒	_____	_____
5. Are all holes in doors or panels in MCC's covered with approved coverings that would withstand fault pressures and temperatures?	☒	_____	_____
6. Are all required bolts or fasteners on cubicle doors?	☒	_____	_____
7. Is the MCC free of corrosion?	_____	☒	_____*
8. Is the equipment designed to prevent exposure to energized bus when doors are open or closed?	☒	_____	_____
9. Are tall indicating lamps functional?	_____	_____	☒
10. Is the manufacturer nameplate in place and legible?	☒	_____	_____
11. Does the MCC have provisions to lock-out the equipment?	☒	_____	_____
12. Is the MCC on a PPM Program?	☒	_____	_____
13. Are the fuse sizes and relay settings according to standards?	☒	_____	_____
14. Does the working clearance in front of all MCC's meet local code requirements?	☒	_____	_____

THE DOW CHEMICAL COMPANY
ELECTRICAL TECHNOLOGY
GLOBAL

ADMINISTRATIVE GUIDELINE
G7A-0099-04
14-JUN-1996
PAGE 2 OF 2

Yes No N/A

15. Is control voltage 120 volt?

☒ ☐ ☐

16. Is bus system insulated or covered?

☒ ☐ ☐

MCC's Index Score:

3