



SOUTHWESTERN

INDUSTRIAL CONTRACTORS AND RIGGERS, INC.

1730 Bassett Ave.
P. O. Box 1611
El Paso, Texas 79948
(915) 532-3491

1330 South 26th Place
P. O. Box 20865
Phoenix, Arizona 85036
(602) 273-1371

527 Wyoming Blvd., S.E.
P. O. Box 8057
Albuquerque, New Mexico 87108
(505) 265-7691

PLAINTIFF'S EXHIBIT

ASA-1597

July 14, 1972

American Smelting and Refining Company
P.O. Box 1111
El Paso, Texas 79999

Attention: J. W. English
Project Manager

Re: Converter Gas Acid Plant
Insulation

Dear Sir,

Under paragraph titles, Pipe Insulation, we believe that you should delete the following - "metal reinforced fiberglass blanket" and insert - "48 series MF Pipe Insulation, etc".

As we talked on July 13, 1972, the 2" fiberglass insulation for all flue insulation should be flat 2" fiberglass insulation, 3 lb. density, applied over 10 ga. studs, a coating of insulating cement, weatherproof, breather type mastic reinforced with poultry netting. All stiffeners to be insulated.

If this meets with your approval I will include this in the bid package.

Very truly yours,

H. E. Wickes
Project Manager

HEW/jm

Approved 7/14/72