

Example 1. A certain fan delivers 12,000 cfm at a static pressure of 1 in. of water when operating at a speed of 400 rpm and requires an input of 4 hp. If in the same installation 15,000 cfm are desired, what will be the speed, static pressure, and horsepower?

$$\text{Speed} = 400 \times \frac{15,000}{12,000} = 500 \text{ rpm}$$

$$\text{Static pressure} = 1 \times \left(\frac{500}{400}\right)^2 = 1.56 \text{ in.}$$

$$\text{Horsepower} = 4 \times \left(\frac{500}{400}\right)^3 = 7.81 \text{ hp}$$

When the density of the air varies the following laws apply:

4. At constant speed and capacity the pressure and horsepower vary directly as the density.

Example 2. A certain fan delivers 12,000 cfm at 70 F and normal barometric pressure (density 0.07495 lb per cubic foot) at a static pressure of 1 in. of water when operating at 400 rpm, and requires 4 hp. If the air temperature is increased to 200 F (density 0.06018 lb) and the speed of the fan remains the same, what will be the static pressure and horsepower?

$$\text{Static pressure} = 1 \times \frac{0.06018}{0.07495} = 0.80 \text{ in.}$$

$$\text{Horsepower} = 4 \times \frac{0.06018}{0.07495} = 3.20 \text{ hp}$$

5. At constant pressure the speed, capacity and horsepower vary inversely as the square root of the density.

Example 3. If the speed of the fan of Example 2 is increased so as to produce a static pressure of 1 in. of water at the 200 F temperature, what will be the speed, capacity, and horsepower?

$$\text{Speed} = 400 \times \sqrt{\frac{0.07495}{0.06018}} = 446 \text{ rpm}$$

$$\text{Capacity} = 12,000 \times \sqrt{\frac{0.07495}{0.06018}} = 13,392 \text{ cfm (measured at 200 F)}$$

$$\text{Horsepower} = 4 \times \sqrt{\frac{0.07495}{0.06018}} = 4.46 \text{ hp}$$

6. For a constant weight of air:

(a) the speed, capacity, and pressure vary inversely as the density.

(b) the horsepower varies inversely as the square of the density.

Example 4. If the speed of the fan of the previous examples is increased so as to deliver the same weight of air at 200 F as at 70 F, what will be the speed, capacity, static pressure, and horsepower?

$$\text{Speed} = 400 \times \frac{0.07495}{0.06018} = 498 \text{ rpm}$$

$$\text{Capacity} = 12,000 \times \frac{0.07495}{0.06018} = 14,945 \text{ cfm (measured at 200 F)}$$

$$\text{Static pressure} = 1 \times \frac{0.07495}{0.06018} = 1.25 \text{ in.}$$

$$\text{Horsepower} = 4 \times \left(\frac{0.07495}{0.06018}\right)^2 = 6.20 \text{ hp}$$

FAN EFFICIENCY

The efficiency of a fan may be defined as the ratio of the work done in moving the air (air horsepower) to the horsepower input to the fan. The work done in moving the air may be computed on the basis of either the static or the total pressure. When the static pressure is used in the computation it is assumed that this represents the useful pressure and that the velocity pressure is lost in the piping system and in the air which leaves the system. Since in most installations a higher velocity exists at the fan outlet than at the point of delivery into the atmosphere, some of the velocity pressure at the fan outlet may be utilized by conversion to static pressure within the system, but owing to the uncertainty of friction losses which occur at the places where changes in velocity take place, the amount of velocity pressure which is actually utilized is seldom known, and the static pressure alone may best represent the useful pressure.

The efficiency based upon static pressure is known as the static efficiency and may be expressed as follows:

$$\text{Static efficiency}^1 = \frac{\text{cfm} \times \text{static pressure in inches of water}}{6369 \times \text{horsepower input}}$$

Different fans may develop the same capacity against the same static pressure and with the same power input, and therefore operate at the same static efficiency, while maintaining different outlet velocities. Where a high outlet velocity is desirable or can be utilized effectively, the static efficiency fails to be a satisfactory measurement of the performance. In many applications of propeller fans, air is circulated without encountering resistance and no static pressure is developed. The static efficiency is zero and its calculation is meaningless. Because of such situations where the static efficiency fails to indicate the true performance, many engineers prefer to base the calculation of efficiency upon the total or dynamic pressure. This efficiency is variously known as the total, dynamic, or mechanical efficiency, and may be expressed as follows:

$$\text{Total efficiency} = \frac{\text{cfm} \times \text{total pressure in inches of water}}{6369 \times \text{horsepower input}}$$

CHARACTERISTIC CURVES

In the operation of a fan at a fixed speed the static and total efficiencies vary with any change in the resistance which is imposed. With different designs the peak of efficiency occurs when the fans deliver different percentages of their wide-open capacity. Variations in efficiency accompany variations in pressures and power consumption which are characteristic of the individual designs and which are influenced particularly by the shape and angularity of the blades. Such variations in pressure, power, and efficiency are shown by characteristic curves.

Characteristic curves of fans are determined by tests performed in accordance with the Standard Test Code for Disc and Propeller Fans,

¹See Standard Test Code for Disc and Propeller Fans, Centrifugal Fans and Blowers, Edition of 1932.