PLAINTIFF'S EXHIBIT WH-876

PENGAD-Bayonne,N.J.

W. E. JOHNSON

TO N-2 Order Service Sam Violetti 4-24-72

LOCATION DEPT. NAME DATE

SUBJECT Con Edison, 15A3242 ASTORIA STATION #6 15A3242

This is in response to your letter of 1-28-72 which transmitted a copy of Con Edison's letter of 12-21-71 in which they require that no asbestoes or ~~asbestos~~ asbestos based materials be used for insulation.

Westinghouse will comply with this request and will ~~use~~ furnish asbestos free materials for insulation of the boiler feed pump turbines.

72192
63A5A



40022701

S. V. Violetti

STEAM TURBINE DIVISION NV

FROM N-2 S.T. Engrg John Sim

LOCATION DEPT. NAME

Produced 3/93