

The Borough Of Sayreville

WATER DEPARTMENT

167 MAIN STREET • SAYREVILLE, N.J. 08872

TEL. (732) 390-7060 • FAX (732) 238-2147

RECEIVED

2008 APR -8 AM 9:19

BUREAU OF SAFE
DRINKING WATER

April 1, 2008

State of New Jersey
Department of Environmental Protection
Bureau of Safe Drinking Water
P.O. Box 426
Trenton, New Jersey, 08625-0426

Attn: Ms. Betty Boros-Russo

Re: PFOA Sampling

Dear Ms. Boros-Russo:

Enclosed are the results required according to sampling procedures. Should you require further information relative to the above, please do not hesitate to contact me at 732-390-7067.

Very truly yours,

Santo Triolo
Santo Triolo,
Director

ST:js

Succeed in Sayreville

Sayreville is an Equal Opportunity Employer

www.sayreville.com

DEP2-SDWB-000216

Sayreville Water & Sewer

Client Sample ID: #1 BORDENTOWN PLANT

HPLC

Lot-Sample #....: D8B290281-001 **Work Order #....:** KHVQJ1AA **Matrix.....:** WATER
Date Sampled....: 02/28/08 08:30 **Date Received...:** 02/29/08
Prep Date.....: 03/03/08 **Analysis Date...:** 03/09/08
Prep Batch #....: 8063447 **Analysis Time...:** 08:20
Dilution Factor: 1

Method.....: DEN -LC-0012

PARAMETER	RESULT	REPORTING		
		LIMIT	UNITS	MDL
PFOA	0.0075 J	0.015	ug/L	0.0031
PFOS	0.0042 J	0.010	ug/L	0.0020
		PERCENT	RECOVERY	
SURROGATE		RECOVERY	LIMITS	
13C4 PFOA	101		(50 - 200)	
13C4 PFOS	82		(50 - 200)	

NOTE(S) :

J Estimated result. Result is less than RL.

Sayreville Water & Sewer

Client Sample ID: #2 MIDDLESEX INTER CONNECTION

HPLC

Lot-Sample #....: D8B290281-002 Work Order #....: KHVQK1AA Matrix.....: WATER
 Date Sampled....: 02/28/08 08:40 Date Received...: 02/29/08
 Prep Date.....: 03/03/08 Analysis Date...: 03/09/08
 Prep Batch #....: 8063447 Analysis Time...: 08:59
 Dilution Factor: 1

Method.....: DEN -LC-0012

PARAMETER	RESULT	REPORTING		
		LIMIT	UNITS	MDL
PFOA	0.0070 J	0.015	ug/L	0.0031
PFOS	0.0034 J	0.010	ug/L	0.0020
SURROGATE	PERCENT RECOVERY	RECOVERY		
		LIMITS		
13C4 PFOA	95	(50 - 200)		
13C4 PFOS	82	(50 - 200)		

NOTE(S) :

J Estimated result. Result is less than RL.

Sayreville Water & Sewer

Client Sample ID: #3 MELROSE FIRE HOUSE

HPLC

Lot-Sample #....: D8B290281-003 Work Order #....: KHVQL1AA Matrix.....: WATER
Date Sampled....: 02/28/08 08:55 Date Received...: 02/29/08
Prep Date.....: 03/03/08 Analysis Date...: 03/09/08
Prep Batch #....: 8063447 Analysis Time...: 09:51
Dilution Factor: 1

Method.....: DEN -LC-0012

PARAMETER	RESULT	REPORTING		
		LIMIT	UNITS	MDL
PFOA	0.0075 J	0.015	ug/L	0.0031
PFOS	0.0049 J	0.010	ug/L	0.0020
SURROGATE	PERCENT RECOVERY	RECOVERY		
		LIMITS		
13C4 PFOA	31 *	(50 - 200)		
13C4 PFOS	29 *	(50 - 200)		

NOTE(S) :

* Surrogate recovery is outside stated control limits.

J Estimated result. Result is less than RL.

Sayreville Water & Sewer

Client Sample ID: #4 WEST MARINE

HPLC

Lot-Sample #....: D8B290281-004 **Work Order #....:** KHVQM1AA **Matrix.....:** WATER
Date Sampled....: 02/28/08 09:05 **Date Received...:** 02/29/08
Prep Date.....: 03/03/08 **Analysis Date...:** 03/09/08
Prep Batch #....: 8063447 **Analysis Time...:** 10:31
Dilution Factor: 1
Method.....: DEN -LC-0012

PARAMETER	RESULT	REPORTING LIMIT	UNITS	MDL
PFOA	0.0090 J	0.015	ug/L	0.0031
PFOS	0.0040 J	0.010	ug/L	0.0020

SURROGATE	PERCENT RECOVERY	RECOVERY LIMITS
13C4 PFOA	76	(50 - 200)
13C4 PFOS	65	(50 - 200)

NOTE(S) :

J Estimated result. Result is less than RL.