

To: All Plant Managers

Date: April 14, 1977

From: T. M. Faas *Jmf*

Copies: G. C. Eggleston, S. Lane, W. E. Volwiler, S. B. Gillespie,
C. J. Mulholland, P. D. Morrell, T. P. Jackson, file/chrono

Subject: BAGHOUSE, DUST COLLECTOR CONDITION REPORT

APR 21 1977

There has been a push on to eliminate paperwork and reduce reports. To help achieve this end, the monthly dust collector condition report is eliminated. This is not meant to imply that baghouses need not be inspected, nor is it meant that the condition of those baghouses should deteriorate. Please continue to inspect baghouses as frequently as necessary.

ma

To:	W. P. Stevens	Augusta
	A. W. Swanson	Billerica
	H. G. Kopp	Butner
	L. I. Richards	Denison
	D. W. Andrews	Franklin
	A. W. Spedding	Fresno
	C. G. Stelchek	Green Cove Springs
	D. A. Baker	Jackson
	D. E. Guy	Laurinburg
	W. A. Ford	Long Beach
	J. A. Lawrence	McNary
	A. W. Jung	Manville IP
	R. F. Henry	Manville Pipe
	C. G. Guerin	Manville SC
	E. J. Derichsweiler	Pueblo
	J. W. Bird	Stockton
	J. W. Christopher	Waukegan
	C. H. Royer	Wilton
	R. G. Frederick	Zelienople

I still want to see the noted conditions of inspections -
RL

PLAINTIFF'S
EXHIBIT
JMMC-206

BAGHOUSE CONDITION RATING - VISUAL

040 -
Feed by
9/5
L. R.

<u>Condition</u>	<u>Description</u>
I.	Absolutely no visible dust anywhere. No dust picked up on fingers.
II.	Slight visible dust - general overall. Dust picked up on fingers.
III.	1 - 3 local accumulations of dust. No ruptured or blown-off bags. Dust visible - general overall Dust picked up on fingers in general areas, but heavy accumulations well localized.
IV.	More than 3 local accumulations. 1 or more bags ruptured or blown-off. Mechanical failure of shaker or structural parts. Generally heavy accumulations of dust on horizontal surfaces.
V.	Visible external emissions from exhaust stack, external plating and seals, doors, hopper discharge (unless fully enclosed).

Rules: Collector to be rated on basis of condition of its worst compartment.

Example: (3) compartments of a (4) compartment collector
at rating "I" and (1) compartment at "III"
causes collector to be rated "III".

DUST COLLECTION LIMITED ENTRY

Plant DEVISON

Date 7-7-80

COLLECTION IDENTIFICATION	RATING	INSP. DATE	INSP. INITIAL	REMARKS
FORMING DEPT. FIBER SIDE	# 2	7/9/80	BC	Small amount of Fiber in #2 Compartment. No ruptured bags noted
FORMING DEPT. DUST SIDE	# 2	7/9/80	BC	Visible dust floor in #1 & # 3 Compartment. Dust going thru bags
FINISHING DEPT. OLD DUST HOUSE				
WEST	#4	7/7/80	@	DUST ACCUMULATIONS ON FLOOR. ONE BAG ON FLOOR
EAST	#3	7/7/80	@	NO ACCUMULATIONS FROM ANY DAMAGED BAGS GOOD CONDITION
VIEW DUST HOUSE				
NORTH WEST	#2	7/7/80	@	DUST PICKED UP ON FINGERS ONLY. NO ACC.
NORTH EAST	#2	7/7/80	@	" " "
SOUTH EAST	#2	7/7/80	@	" " "
SOUTH WEST	#2	7/7/80	@	" " "
				COMMENTS OLD DUST HOUSE. WEST SIDE DUST ACC. ON FLOOR FOR 1 YR OR MORE

~~W. D. Dugan~~

C. Smith

DUST COLLECTOR CREDITED RATING

Plant DEWISONDate 6-2-80

COLLECTOR IDENTIFICATION	RATING	INSP. DATE	INSP. INITIAL	REMARKS
FORMING DEPT. FIBER SIDE	# 2	6/6/80	BC	Slight amount of Dust in # 3 compartment. Overall all compartments in good shape
FORMING DEPT. DUST SIDE	# 3	6/6/80	BC	Dust visible - general overall in compartment 1 and 3. No ruptured bags noted.
FINISHING DEPT. OLD DUST HOUSE				
WEST	# 4	6/2/80	@	DUST ACCUMULATIONS ON FLOOR. ONE BAG ON FLOOR
EAST	# 3	6/2/80	@	NO ACCUMULATIONS FROM ANY DAMAGED BAG GOOD CONDITION
NEW DUST HOUSE				
NORTH WEST	2	6/2/80	@	DUST PICKED UP ON FINGERS ONLY NO ACC ANY PLACE
NORTH EAST	2	6/2/80	@	" " "
SOUTH EAST	2	6/2/80	@	" " "
SOUTH WEST	2	6/2/80	@	" " "
				COMMENTS CONTINUE TO HAVE A PROBLEM WITH WEST END OF OLD DUST HOUSE LEAKING WELL OVER NOTE → 11.2"

C. Smith

DUST COLLECTION CREDITED RATING

Plant DENISON

Date 5-1-80

COLLECTOR IDENTIFICATION	RATING	INSP. DATE	INSP. INITIAL	REMARKS
FORMING DEPT. FIBER SIDE	# 2	5/1/80	BC	Slight visible dust in all 4 compartments. No fiber noted on rupture bags. Compartments generally overall look good
FORMING DEPT. DUST SIDE	# 5	5/1/80	BC	heavy accumulation of dust on horizontal surface in 1-3-4 compartments. No rupture bags noted
FINISHING DEPT. OLD DUST HOUSE				
WEST	# 4	5/1/80	@	DUST ACCUMULATIONS ON FLOOR ONE BAG DOWN WORK ORDER WRITTEN
EAST	# 3	5/1/80	@	NO ACCUMULATIONS FROM ANY DAMAGED BAGS GOOD CONDITION
NEW DUST HOUSE				
NORTH WEST	2	5/1/80	@	DUST PICKED UP ON FINGERS ONLY NO ACC. ANY PLACE
NORTH EAST	2	5/1/80	@	" " "
SOUTH EAST	2	5/1/80	@	" " "
SOUTH WEST	2	5/1/80	@	" " "
		NOTE FOR ABOUT 11 AM		COMMENTS CONTINUE TO HAVE A PROBLEM WITH WEST END OF OLD DUST HOUSE ONE SACK DOWN

COLLECTION IDENTIFICATION	RATING	INSP. DATE	INSP. INITIAL	REMARKS
FORMING DEPT. FIBER SIDE	# ₁	4/11/80	BC	all 4 Compartments in good shape; no visible fibers noted.
FORMING DEPT. DUST SIDE	# ₂	4/11/80	BC	Slight visible dust on floor in #1 compartment. No ruptured bags noted.

DUST COLLECTOR CONDITION REPORT

Plant DEWISON

Date 4-2-80

COLLECTOR IDENTIFICATION	RATING	INSP. DATE	INSP. INITIAL	REMARKS
FORMING DEPT. FIBER SIDE				
FORMING DEPT. DUST SIDE				
FINISHING DEPT. OLD DUST HOUSE				
WEST	# 4	4/2/80	ⓐ	DUST ACCUMULATIONS ON FLOOR NO VISIBLE BAG RUPTURE
EAST	# 3	4/2/80	ⓐ	NO ACCUMULATIONS FROM ANY DAMAGED BAG. GOOD CONDITION
NEW DUST HOUSE				
NORTH WEST	# 2	4/2/80	ⓐ	DUST PICKED UP ON FINGERS ONLY NO ACC ANY PLACE
NORTH EAST	# 2	4/2/80	ⓐ	" " "
SOUTH EAST	# 2	4/2/80	ⓐ	" " "
SOUTH WEST	# 2	4/2/80	ⓐ	" " "
				COMMENTS W.O.U.2 CONTINUE TO HAVE A PROBLEM WITH WEST EN OF OLD DUST HOUSE (LEAKING) DUST ON

~~A. Hobart~~ 
C. Smith 

DUST COLLECTION CONDITION REPORT

Plant DEWISON

Date 3-3-80

COLLECTION IDENTIFICATION	RATING	INSP. DATE	INSP. INITIAL	REMARKS
FORMING DEPT. FIBER SIDE	#1	3/10/80	SC	all 4 compartments in very good shape Sigh out in # 2 compartment
FORMING DEPT. DUST SIDE	#3	3/10/80	SC	one local accumulation of dust in #1 compartment no ruptured bags noted will submit work order to ECL to ck for leaks.
FINISHING DEPT. OLD DUST HOUSE				
WEST	#4	3/3/80	ⓐ	DUST ACCUMULATIONS ON FLOOR NO VISIBLE BAG RUPTURE DUST ACCUMULATIONS ON FLOOR NO VISIBLE BAG RUPTURE
EAST	#4	3/3/80	ⓐ	
NEW DUST HOUSE				
NORTH WEST	#2	3/3/80	ⓐ	DUST PICKED UP ON FINGERS ONLY NO ACC ANY PLACE
NORTH EAST	#2	3/3/80	ⓐ	" " "
SOUTH EAST	#2	3/3/80	ⓐ	" " "
SOUTH WEST	#2	3/3/80	ⓐ	" " "
				COMMENTS OLD DUST HOUSE BOTH SIDES LEAKING

Wm. L. G. Smith

Plant Denison

Date 2-7-80

[illegible]

C. Smith

DUST COLLECTOR INSPECTION REPORT

Plant DENISON

Date 11-12-79

COLLECTOR IDENTIFICATION	RATING	INSP. DATE	INSP. INITIAL	REMARKS
FORMING DEPT. FIBER SIDE	# 2	11/12/79	BC	Slight visible Fiber in # 3 compartment
FORMING DEPT. DUST SIDE	# 4	11/12/79	BC	Heavy Dust accumulations on horizontal surface in # 1 & # 2 compartment all were vacuumed this date
FINISHING DEPT. OLD DUST HOUSE				
WEST	# 4	11/5/79	(C)	DUST ACCUMULATIONS ON FLOOR NO VISIBLE BAG INTURB
EAST	# 3	11/5/79	(C)	NO ACCUMULATIONS FROM ANY DAMAGED BAGS GOOD CONDITION
NEW DUST HOUSE				
NORTH WEST	# 2	11/5/79	(C)	DUST PICKED UP ON FINGERS ONLY NO ACC. ANY PLACE
NORTH EAST	# 2	11/5/79	(C)	" " "
SOUTH EAST	# 2	11/5/79	(C)	" " "
SOUTH WEST	# 2	11/5/79	(C)	" " "
				COMMENTS OLD DUST HOUSE WEST SIDE CONTINUES TO HAUF

DUST COLLECTION IDENTIFICATION TABLE

Plant DENISON

Date 10-1-79

COLLECTOR IDENTIFICATION	RATING	INSP. DATE	INSP. INITIAL	REMARKS
<u>FORMING DEPT.</u> <u>FIBER SIDE</u>				
COMPARTMENT #1	#3	10/2/79	PH	DUST PICK UP ON FINGERS NO ACCUMULATION ANY PLACE
" #2	#3	10/2/79	RB	NO ACCUMULATION ANY PLACE DUST PICK UP ON FINGERS
" #3	#4	10/2/79	RB	FIBER ON FLOOR NO BAG RUPTURE
" #4	#4	10/2/79	RB	FIBER ON FLOOR NO BAG RUPTURE
<u>FORMING DEPT.</u> <u>DUST SIDE</u>				
COMPARTMENT #1	#4	10/2/79	RB	SOCK LOOSE AT FLOOR ACCUMULATION OF DUST AROUND SOCK
" #2	#4	10/2/79	RB	3-4 SOCKS LOOSE AT FLOOR ACCUMULATION OF DUST ON FLOOR
" #3	#2	10/2/79	RB	NO ACCUMULATION OF DUST ON FLOOR DUST PICKED UP ON FINGERS
" #4	#2	10/2/79	RB	NO ACCUMULATION OF DUST ON FLOOR DUST PICKED UP ON FINGERS
<u>FINISHING DEPT.</u> <u>OLD DUST HOUSE</u>				
<u>WEST</u>	#4	10/1/79	(C)	DUST ACCUMULATIONS ON FLOOR NO. VISIBLE BAG RUPTURE
<u>EAST</u>	#3	10/1/79	(C)	NO ACCUMULATIONS FROM ANY DAMAGED BAGS GOOD CONDITION
<u>NEW DUST HOUSE</u>				
<u>NORTH WEST</u>	#2	10/1/79		DUST PICKED UP ON FINGERS ONLY NO ACC. ANY PLACE
<u>NORTH EAST</u>	#2	10/1/79		" " "
<u>SOUTH EAST</u>	#2	10/1/79		" " "
<u>SOUTH WEST</u>	#2	10/1/79		" " "
				COMMENTS CANT SEEM TO KEEP DUST OFF FLOOR IN OLD DUST HOUSE

1200000

~~1. B. J. Smith~~

C. Smith

DUST COLLECTOR CONDITION TABLE

Plant DEXISONDate July '79

COLLECTOR IDENTIFICATION	RATING	INSP. DATE	INSP. INITIAL	REMARKS
FORMING DEPT. FIBER SIDE	# 3	8/9/79	BC	one local accumulation of fiber in both #1 and #4 compartments No ruptured bags noted. will vacuum up soon as possible
FORMING DEPT. DUST SIDE	# 4	8/9/79	BC	Heavy accumulation of dust on horizontal surface in all 4 compartments. No rupture bags noted. will vacuum all 4 compartments
FINISHING DEPT. OLD DUST HOUSE				
WEST	#4	7/2/79	@	DUST ACCUMULATIONS ON FLOOR. NO VISIBLE BAG RUPTURE
EAST	#3	7/2/79	@	NO ACCUMULATIONS FROM ANY DAMAGED BAGS GOOD CONDITION
NEW DUST HOUSE				
NORTH WEST	#2	7/2/79	@	DUST PICKED UP ON FINGERS ONLY. NO ACC ANY PLACE
NORTH EAST	#2	7/2/79	@	" " "
SOUTH EAST	#2	7/2/79	@	" " "
SOUTH WEST	#2	7/2/79	@	" " "
				COMMENTS 3RD MONTH DUST ACCUMULATION IN SAME AREA. WROTE

C. SMITH

DUST COLLECTION IDENTIFICATION

Plant DEWISON

Date 6-4-79

COLLECTION IDENTIFICATION	RATING	INSP. DATE	INSP. INITIAL	REMARKS
FORMING DEPT. FIBER SIDE	# 2	6/5/79	BP	Slight visible Fiber in #3 compartment. Overall the four compartments are in good shape
FORMING DEPT. DUST SIDE	# 2	6/5/79	BP	Slight visible Dust in #1 & #4 compartments all compartments vacuum this date after inspection
FINISHING DEPT. OLD DUST HOUSE	#			
WEST	# 4	6/4/79	@	DUST ACCUMULATIONS ON FLOOR. NO DISIBLE BAG RUPTURE (SAME AS
EAST	# 3	6/4/79	@	NO ACCUMULATIONS FROM ANY DAMAGED BAGS GOOD CONDITION
NEW DUST HOUSE				
NORTH WEST	# 2	6/4/79	@	DUST PICKED UP ON FINGERS ONLY. NO ACC. ANY PLACE
NORTH EAST	# 2	6/4/79	@	" " "
SOUTH EAST	# 2	6/4/79	@	" " "
SOUTH WEST	# 2	6/4/79	@	" " "
				COMMENTS WORK ORDER WRITTEN FOR DUST LEAK 5-1-79 STILL LEAKING

C. Smith

DUST COLLECTION WITNESS REPORT

Plant DEPISON

Date 5/79

COLLECTION IDENTIFICATION	RATING	INSP. DATE	INSP. INITIAL	REMARKS
FORMING DEPT. FIBER SIDE	# 2	5/14/79	BC	Slight Visible Fiber in # 2 Compartments. No ruptured Bags noted.
FORMING DEPT. DUST SIDE	# 2	5/14/79	BC	Slight Visible Dust in # 3 & # 4 Compartments. No ruptured Bags noted.
FINISHING DEPT. OLD DUST HOUSE				
WEST	# 4	5/1/79	@	DUST ACCUMULATIONS ON FLOOR NO VISIBLE BAG RUPTURE (WORK ORDER WRITTEN)
EAST	# 3	5/1/79	@	NO ACCUMULATIONS FROM ANY DAMAGED BAGS GOOD CONDITION
NEW DUST HOUSE				
NORTH WEST	# 2	5/1/79	@	DUST PICKED UP ON FINGERS ONLY NO ACC. FROM ANY PLACE
NORTH EAST	# 2	5/1/79	@	" " "
SOUTH EAST	# 2	5/1/79	@	" " "
SOUTH WEST	# 2	5/1/79	@	" " "
				COMMENTS WORK ORDER WRITTEN FOR DUST LEAK

C. Smith

DUST COLLECTION COLLECTED DATA

Plant DEWISONDate 4-3-79

COLLECTOR IDENTIFICATION	RATING	INSP. DATE	INSP. INITIAL	REMARKS
FORMING DEPT. FIBER SIDE	# 2	4/12/79	BC	Slight visible Fiber in # 3 Compartment
FORMING DEPT. DUST SIDE	# 4	3/12/79	BC	Heavy accumulation of dust in all 4 compartments No ruptured bags noted. Will have all compartments vacuumed
FINISHING DEPT. OLD DUST HOUSE				
WEST	# 3	4/3/79	@	GOOD CONDITION NO ACCUMULATIONS FROM ANY DAMAGED BAGS
EAST	# 3	4/3/79	@	" " "
NEW DUST HOUSE				
NORTH WEST	# 2	4/3/79	@	NO ACCUMULATIONS DUST PICKED UP ON FINGERS ONLY
NORTH EAST	# 2	4/3/79	@	" "
SOUTH EAST	# 2	4/3/79	@	" "
SOUTH WEST	# 2	4/3/79	@	" "
				COMMENTS SOME ONE LEFT THROW AWAY PAPER SHITS IN OLD DUST

12 Copies

C. Smith

DUST COLLECTION MAINTENANCE REPORT

Plant DENISONDate 3-2-79

COLLECTION IDENTIFICATION	RATING	INSP. DATE	INSP. INITIAL	REMARKS
FORMING DEPT. FIBER SIDE	# 2	3-1-79	BC	Slight visible Fiber in #1 Compartment - cleaned this date
FORMING DEPT. DUST SIDE	# 4	3-1-79	BC	Heavy accumulation in #3 compartment. Had E.R. replace 2 ruptured bags. all compartments cleaned this date.
FINISHING DEPT. OLD DUST HOUSE				
WEST	#4	3/1/79	@	ONE SOCK ON RIGHT HAND SIDE (BOTTOM) 1ST ROW OF SOCKS
EAST	#3	3/1/79	@	GOOD CONDITION NO ACCUMULATIONS FROM ANY DAMAGED BAGS
NEW DUST HOUSE		3/1/79		
NORTH WEST	#2	3/1/79	@	NO ACCUMULATIONS DUST PICKED UP ON FINGERS ONLY
NORTH EAST	#2	3/1/79	@	" "
SOUTH EAST	#2	3/1/79	@	" "
SOUTH WEST	#2	3/1/79	@	" "
				COMMENTS WORK ORDER WRITTEN TO REPAIR LEAKING SOCK

C. Smith

DUST COLLECTOR CONDITION REPORT

Plant DEVISONDate 2-2-79

COLLECTOR IDENTIFICATION	RATING	INSP. DATE	INSP. INITIAL	REMARKS
FORMING DEPT. FIBER SIDE	# 2	2-12-79	LC	Slight visible Fiber in # 2 compartment
FORMING DEPT. DUST SIDE	# 4	2-12-79	LC	Heavy accumulation of dust on horizontal- surface in all 4 compartment. Ser has change out some bags in all 4 compartments will have all compartments vacuumed.
FINISHING DEPT. OLD DUST HOUSE				
WEST	# 3	2/2/79	Q	GOOD CONDITION. NO ACCUMULATIONS FROM ANY DAMAGED BAGS
EAST	# 3	2/2/79	Q	" " "
NEW DUST HOUSE				
NORTH WEST	# 2	2/2/79	Q	NO ACCUMULATIONS DUST PICKED UP ON FINGERS ONLY
NORTH EAST	# 2	2/2/79	Q	" "
SOUTH EAST	# 2	2/2/79	Q	" "
SOUTH WEST	# 2	2/2/79	Q	" "
				COMMENTS

DUST COLLECTOR CONDITION RATING

Plant Denison

Date 1-12-79

COLLECTION IDENTIFICATION	RATING	INSP. DATE	INSP. INITIAL	REMARKS
FORMING DEPT. FIBER SIDE	# 2	1-12-79	B.C.	Slight visible fiber in #3 Compartment. Light out in #2 Compartment
FORMING DEPT. DUST SIDE	# 4	1/12/ 79	B.C.	Heavy accumulation of dust on horizontal surface in all 4 Compartments. no ruptured bags noted.

12/1/79

C. Smith ←

DUST COLLECTION SYSTEMS

Plant DEWISONDate FINISHING 1-2-79

COLLECTION IDENTIFICATION	RATING	INSP. DATE	INSP. INITIAL	REMARKS
FORMING DEPT. FIBER SIDE				
FORMING DEPT. DUST SIDE				
FINISHING DEPT. OLD DUST HOUSE				
WEST	# 3	1/2/79	(Cw)	GOOD CONDITION NO ACCUMULATIONS FROM ANY DAMAGED BAGS
EAST	# 3	1/2/79	(Cw)	GOOD CONDITION NO ACCUMULATIONS FROM ANY DAMAGED BAGS
NEW DUST HOUSE				
NORTH WEST	# 2	1/2/79		NO ACCUMULATIONS DUST PICKED UP ON FINGERS ONLY
NORTH EAST	# 2	1/2/79		" "
SOUTH EAST	# 2	1/2/79		" "
SOUTH WEST	# 2	1/2/79		" "
				COMMENTS

C. Smith

DUST COLLECTION CONDITION REPORT

Plant DEVISON

Date 12-1-78

COLLECTION IDENTIFICATION	RATING	INSP. DATE	INSP. INITIAL	REMARKS
FORMING DEPT. FIBER SIDE	# 2	12/2/78	BC	Slight visible Fiber in # 3 compartment. light out in # 3 compartment
FORMING DEPT. DUST SIDE	# 4	12/2/78	BC	Generally heavy accumulation of dust on horizontal surfaces in all 4 compartments. No ruptured bags noted.
FINISHING DEPT. OLD DUST HOUSE				
WEST	# 4	12/1/78	@	DUST ACCUMULATIONS ON FLOOR - NO VISIBLE BAG RUPTURE (WORK ORDER TURNED)
EAST	# 3	12/1/78	@	NO ACCUMULATIONS FROM ANY DAMAGED BAG. GOOD CONDITION
NEW DUST HOUSE				
NORTH WEST	# 2	12/1/78	@	DUST PICKED UP ON FINGERS ONLY NO ACC. AM PLACIE
NORTH EAST	# 2	12/1/78	@	" " "
SOUTH EAST	# 2	12/1/78	@	" " "
SOUTH WEST	# 2	12/1/78	@	" " "
				COMMENTS OLD DUST HOUSE WEST SIDE DUST ACCUMULATION ON FLOOR 3 MONTHS IN A ROW. WORK ORDER TURNED IN

C. Smith

DUST COLLECTION WITNESS REPORT

Plant DEWISON

Date 11/1/78

COLLECTION IDENTIFICATION	RATING	INSP. DATE	INSP. INITIAL	REMARKS
FORMING DEPT. FIBER SIDE	# 2	11/13/78	BC	Small accumulation of Fiber in # 3. No ruptured bags noted
FORMING DEPT. DUST SIDE	# 3	11/13/78	BC	Large accumulation noted in all 4 compartments. E & R replaced a number of bags during inventory. Had all compartments vacuumed this date.
FINISHING DEPT. OLD DUST HOUSE				
WEST	# 4	11/1/78	C	DUST ACCUMULATIONS ON FLOOR NO VISIBLE BAG RUPTURE. (WORK ORDER THRUED IN)
EAST	# 3	11/1/78	C	NO ACCUMULATIONS FROM ANY DAMAGED BAGS. GOOD CONDITION
NEW DUST HOUSE				
NORTH WEST	# 2	11/1/78	C	DUST PICKED UP ON FINGERS ONLY NO ACC ANY PLACE
NORTH EAST	# 2	11/1/78	C	" " "
SOUTH EAST	# 2	11/1/78	C	" " "
SOUTH WEST	# 2	11/1/78	C	" " "
				COMMENTS

C. Smith

DUST COLLECTION CONDITION SURVEY

Plant DEWISONDate 10-2-78

COLLECTION IDENTIFICATION	RATING	INSP. DATE	INSP. INITIAL	REMARKS
FORMING DEPT. FIBER SIDE	# 2	10/ 7/78	BC	1 small accumulation of Fiber in #4 compartment.
FORMING DEPT. DUST SIDE	# 3	10/ 7/78	BC	Generally heavy accumulation of Dust on horizontal surface in all 4 compartments. No rupture bags noted.
FINISHING DEPT. OLD DUST HOUSE				
WEST	# 4	10/2/78	(C)	DUST ACC. ON FLOOR NO VISIBLE BAG RUPTURE WORK ORDER TURNED IN
EAST	# 3	10/2/78	(C)	NO ACCUMULATIONS FROM ANY DAMAGED BAGS GOOD CONDITION
NEW DUST HOUSE				
NORTH WEST	#2	10/2/78	(C)	DUST PICKED UP ON FINGERS ONLY, NO ACC. ANY PLACE.
NORTH EAST	#2	10/2/78	(C)	" " "
SOUTH EAST	#2	10/2/78	(C)	" " "
SOUTH WEST	#2	10/2/78	(C)	" " "
				COMMENTS LIGHTS BURNED OUT IN HALL. WORK ORDER TURNED IN

C. Smith

DUST COLLECTION CONDITION REPORT

Plant DEWISON

Date 9-1-78

COLLECTION IDENTIFICATION	RATING	INSP. DATE	INSP. INITIAL	REMARKS
<u>FORMING DEPT.</u> <u>FIBER SIDE</u>	# 2	9/2/78	BC	Slight Visible Fiber in #4 Compartment. Will Vacuum This compartment Today.
<u>FORMING DEPT.</u> <u>DUST SIDE</u>	# 3	9/2/78	BC	accumulation of Dust in all four Compartments. Two Bags down in #1 compartment. will have this corrected today.
<u>FINISHING DEPT.</u> <u>OLD DUST HOUSE</u>		9/1/78		
<u>WEST</u>	#3	9/1/78	(C)	GOOD CONDITION NO ACCUMULATIONS FROM ANY DAMAGED BAGS
<u>EAST</u>	#3	9/1/78	(C)	" " "
<u>NEW DUST HOUSE</u>		9/1/78		
<u>NORTH WEST</u>	#2	9/1/78	(C)	NO ACCUMULATIONS DUST PICKED UP ON FINGERS ONLY
<u>NORTH EAST</u>	#2	9/1/78	(C)	" "
<u>SOUTH EAST</u>	#2	9/1/78	(C)	" "
<u>SOUTH WEST</u>	#2	9/1/78	(C)	" "
				COMMENTS

C. Smith

DUST COLLECTION COMPLETION REPORT

Plant DENISON

Date 8-5-78

COLLECTION IDENTIFICATION	RATING	INSP. DATE	INSP. INITIAL	REMARKS
FORMING DEPT. FIBER SIDE	# 2	8/5/ 78	BC	# 3 & 4 Compartments, small amount of fiber in each compartment
FORMING DEPT. DUST SIDE	# 3	8/5/ 78	BC	accumulation of dust on horizontal surface in all four compartments. Two bags down in #1 Compartments.
FINISHING DEPT. OLD DUST HOUSE				
WEST	#4	8/2/78	(C)	DUST ACC. ON FLOOR NO VISIBLE BAG RUPTURE
EAST	#3	8/2/78	(C)	GOOD CONDITION NO ACCUMULATIONS FROM ANY DAMAGED BAGS
NEW DUST HOUSE				
NORTH WEST	#2	8/2/78	(C)	NO ACCUMULATIONS DUST PICKED UP FIBERS ONLY
NORTH EAST	#2	8/2/78	(C)	" "
SOUTH EAST	#2	8/2/78	(C)	" "
SOUTH WEST	#2	8/2/78	(C)	" "
				COMMENTS WORK ORDER WRITTEN AGAIN FOR LEAKS IN WEST SIDE.

C. SMITH ←

DUST COLLECTION (MULTIPLE PASSAGE)

Plant DEWISON

Date 7-15-78

COLLECTION IDENTIFICATION	RATING	INSP. DATE	INSP. INITIAL	REMARKS
FORMING DEPT. FIBER SIDE	# 2	7/15/78	BC	Slight Visible Fiber in # 3 & 4 Compartment. Generally, the four Fiber Compartments are in good condition.
FORMING DEPT. DUST SIDE	# 4	7/15/78	BC	#1 & #2 Compartments, large accumulation over all. #1 has bag down. #2 light out. Webber Submitted.
FINISHING DEPT. OLD DUST HOUSE				
WEST	#4	7/7/78	Q	ACCUMULATIONS ON FLOOR FROM LEAKING BAGS. WORK ORDER WRITTEN
EAST	#3	7/7/78	Q	NO ACCUMULATIONS FROM ANY DAMAGED BAGS GOOD CONDITION
NEW DUST HOUSE				
NORTH WEST	#2	7/7/78	Q	DUST PICKED UP ON FINGERS ONLY. NO ACC- UMULATIONS ANY PLACE
NORTH EAST	#2	7/7/78	Q	" "
SOUTH EAST	#2	7/7/78	Q	" "
SOUTH WEST	#2	7/7/78	Q	" "
				COMMENTS WEST SIDE FINISHING OLD DUST HOUSE DUST ON FLOOR WORK ORDER WRITTEN

C. SMITH ←

DUST COLLECTION COLLECTION REPORT

Place DEWISONDate: 6-2-78

COLLECTOR IDENTIFICATION	RATING	INSP. DATE	INSP. INITIAL	REMARKS
FORMING DEPT. FIBER SIDE	# 2	6-17-78	BC	Slight Visible Dust in #1 Compartment all four compartments overall in good condition
FORMING DEPT. DUST SIDE	# 4	6-17-88	BC	#1 Compartment Large accumulation overall. Submit another work order to replace old Bags -
FINISHING DEPT. OLD DUST HOUSE				
WEST	#3	6/1/78	CW	GOOD CONDITION NO ACCUMULATIONS FROM ANY DAMAGED BAGS
EAST	#3	6/1/78	CW	GOOD CONDITION NO ACCUMULATIONS FROM ANY DAMAGED BAGS
NEW DUST HOUSE				
NORTH WEST	#2	6/1/78	CW	NO ACCUMULATIONS DUST PICKED UP ON FINGERS ONLY
NORTH EAST	#2	6/1/78	CW	" "
SOUTH EAST	#2	6/1/78	CW	" "
SOUTH WEST	#2	6/1/78	CW	" "
				COMMENTS LIGHT BURNED OUT (NEW) WORK ORDER SUBMITTED

C. Smith

DUST COLLECTOR A GRINDING PLANT

Plant DENISON

Date 5/1/78

COLLECTOR IDENTIFICATION	RATING	INSP. DATE	INSP. INITIAL	REMARKS
FORMING DEPT. FIBER SIDE	#3	5/13/78	BC	#1 Compartment 1-2 Local accumulation. no visible rupture. will submit another work order.
FORMING DEPT. DUST SIDE	#3	5/13/78	BC	#1 Compartment large accumulation of dust generally small. will submit work order to inspect bags.
FINISHING DEPT. LD DUST HOUSE				
WEST	#3	5/1/78		GOOD CONDITION NO ACCUMULATIONS FROM ANY DAMAGED BAGS
EAST	#3	5/1/78		" " "
NEW DUST HOUSE				
NORTH WEST	#2	5/1/78		NO ACCUMULATIONS DUST PICKED UP ON FINGER ONLY
NORTH EAST	#2	5/1/78		" "
SOUTH EAST	#2	5/1/78		" "
SOUTH WEST	#2	5/1/78		" "

L. SMITH ←

DUST COLLECTION SCHEDULE DATA

PLANT DENISON

DATE 4-22-78

COLLECTION IDENTIFICATION	RATING	INSP. DATE	INSP. INITIAL	REMARKS
FORMING DEPT. FIBER SIDE	# 3	4/22/78	BC	# 1 Compartment 1-3 local accumulations. No Visible rupture. Submitted W.D. To E&R to inspect bags
FORMING DEPT. DUST SIDE	# 4	4/22/78	BC	Generally heavy accumulation of dust Overall - Compartment has not been vacuumed since E&R replaced bags - Will have crew vacuum compartment and I will re-inspect.
FINISHING DEPT. LD DUST HOUSE				
WEST	# 3	4/1/78	@	NO ACCUMULATIONS FROM ANY DAMAGED BAGS GOOD CONDITION
EAST	# 3	4/1/78	@	" " "
NEW DUST HOUSE				
NORTH WEST	# 2	4/1/78	@	DUST PICKED UP ON FINGERS ONLY NO ACCUMULATIONS ANY PLACE
NORTH EAST	# 2	4/1/78	@	" " "
SOUTH EAST	# 2	4/1/78	@	" " "
SOUTH WEST	# 2	4/1/78	@	" " "

Carl Wagner
4/1/78

C. Smith ←

DUST COLLECTION CREDITED: 54117

Plant DENISONDate 3-4-78

COLLECTION IDENTIFICATION	RATING	INSP. DATE	INSP. INITIAL	REMARKS
FORMING DEPT. FIBER SIDE	# 2	3/18/78	BC	# 1 Compartment slight visible Fiber general overall. Possible ruptured bag. Work order submitted
FORMING DEPT. DUST SIDE	# 3	3/18/78	BC	# 1 Compartment, one bag down. # 2 Compartment. 1-3 local accumulation of Dust. Work order submitted
FINISHING DEPT. LD DUST HOUSE				
WEST	# 3	3/4/77	@	NO ACCUMULATIONS FROM ANY DAMAGED BAGS GOOD CONDITION
EAST	# 3	3/4/77	@	" " "
NEW DUST HOUSE				
NORTH WEST	# 2	3/4/77	@	DUST PICKED UP ON FINGERS ONLY NO ACCUMULATIONS ANY PLACE
NORTH EAST	# 2	3/4/77	@	" " "
SOUTH EAST	# 2	3/4/77	@	" " "
SOUTH WEST	# 2	3/4/77	@	" " "

Carl Weger
3/4/77

C. Smith

DUST COLLECTION CONDITION REPORT

Plant DENISON

Date 2-1-78

COLLECTION IDENTIFICATION	RATING	INSP. DATE	INSP. INITIAL	REMARKS
FORMING DEPT. FIBER SIDE	II	2/11/78	BC	#3 Compartment slight visible dust - general over all. E & R is to change out the bad bags
FORMING DEPT. DUST SIDE	II	2/11/78	BC	#1 & 3 Compartment slight visible dust - general over all. E & R to remove old bags.
FINISHING DEPT. LD. DUST HOUSE				
WEST	#3	2/1/78	(C)	GOOD CONDITION NO ACCUMULATIONS FROM ANY DAMAGED BAGS
EAST	#3	2/1/78	(C)	" " "
NEW DUST HOUSE				
NORTH WEST	#2	2/1/78	(C)	NO ACCUMULATIONS DUST PICKED UP ON FINGERS ONLY
NORTH EAST	#2	2/1/78	(C)	" " "
SOUTH EAST	#2	2/1/78	(C)	" " "
SOUTH WEST	#2	2/1/78	(C)	" " "

C. Smith

DUST COLLECTOR CONDITIONAL PATROL

Plant DEWISONDate 1-3-78

COLLECTOR IDENTIFICATION	RATING	INSP. DATE	INSP. INITIAL	REMARKS
FORMING DEPT. FIBER SIDE	II	1/13/78	BC	#3 Compartment. slight visible dust-general overall.
FORMING DEPT. DUST SIDE	II	1/13/78	BC	#3 Compartment. slight visible dust-general overall.
FINISHING DEPT. OLD DUST HOUSE				
WEST	#3	1/3/78	Cu	GOOD CONDITION NO ACCUMULATIONS FROM ANY DAMAGED BAGS
EAST	#3	1/3/78	Cu	GOOD CONDITION NO ACCUMULATIONS FROM ANY DAMAGED BAGS
NEW DUST HOUSE				
NORTH WEST	#2	1/3/78	Cu	NO ACCUMULATIONS DUST PICKED UPON FINGERS ONLY
NORTH EAST	#2	1/3/78	Cu	" "
SOUTH EAST	#2	1/3/78	Cu	" "
SOUTH WEST	#2	1/3/78	Cu	" "

DUST COLLECT & CONDITION REPORT

Plant DENISONDate 12-1-77

COLLECTOR IDENTIFICATION	RATING	INSP. DATE	INSP. INITIAL	REMARKS
FORMING DEPT. FIBER SIDE	<u>IV</u>	12/17/77	BC	#3 Compartment. one bag blown off - heavy accumulation Rayland one bag, had compartment close out.
FORMING DEPT. DUST SIDE	<u>IV</u>	12/17/77	BC	#3 Compartment. one bag ruptured, heavy accumulation well localized. Work order turned in to replace bag.
FINISHING DEPT. OLD DUST HOUSE				
WEST	# 3	12/1/77	(Cw)	GOOD CONDITION NO ACCUMULATIONS FROM ANY DAMAGED BAGS
EAST	# 3	12/1/77	(Cw)	" " "
NEW DUST HOUSE				
NORTH WEST	# 2	12/1/77	(Cw)	NO ACCUMULATIONS DUST PICKED UP ON FINGERS ONLY
NORTH EAST	# 2	12/1/77	(Cw)	" "
SOUTH EAST	# 2	12/1/77	(Cw)	" "
SOUTH WEST	# 2	12/1/77	(Cw)	" "

DUST COLLECTION COMPLETION REPORT

Plant DENISON

Date 11-1-77

COLLECTOR IDENTIFICATION	RATING	INSP. DATE	INSP. INITIAL	REMARKS
FORMING DEPT. FIBER SIDE	# 3	11/19/77	BC	one local accumulation in #3 compartment, no ruptured bag noted. Work order turned in to E & R to inspect.
FORMING DEPT. DUST SIDE	# 3	11/19/77	BC	one local accumulation in #2 compartment, no ruptured bag noted. Work order turned in to E & R to inspect.
FINISHING DEPT. LD DUST HOUSE				
WEST	# 3	11/1/77	(C)	GOOD CONDITION NO ACCUMULATIONS FROM ANY DAMAGED BAGS
EAST	# 3	11/1/77	(C)	" " "
NEW DUST HOUSE				
NORTH WEST	# 2	11/1/77	(C)	NO ACCUMULATIONS DUST PICKED UP ON FINGERS ONLY
NORTH EAST	# 2	11/1/77	(C)	" " "
SOUTH EAST	# 2	11/1/77	(C)	" " "
SOUTH WEST	# 2	11/1/77	(C)	" " "
				SOME WATER ON FLOOR FROM RAIN (C)

Mike
Who is handling:
Slopd.

DUST COLLECTION CONDITION REPORT

Plant DEWISON

Date: 10/3/77
@

COLLECTION IDENTIFICATION	RATING	INSP. DATE	INSP. INITIAL	REMARKS
FORMING DEPT. FIBER SIDE	#3	10/22	RC	Heavy accumulation in #1 Compartment. one bag down no ruptured bag noted.
FORMING DEPT. DUST SIDE	#3	10/22	RC	Heavy accumulation in #3 Compartment. noted 1 ruptured bag. Work order turned in to replace bag.
FINISHING DEPT. OLD DUST HOUSE				
WEST	#3	10/3/77	@	GOOD CONDITION NO ACCUMULATIONS FROM ANY DAMAGED BAGS
EAST	#3	10/3/77	@	GOOD CONDITION NO ACCUMULATIONS FROM ANY DAMAGED BAGS
VIEW DUST HOUSE				
NORTH WEST	#2	10/3/77	@	NO ACCUMULATIONS DUST PICKED UP ON FINGERS ONLY
NORTH EAST	#2	10/3/77	@	" "
SOUTH EAST	#2	10/3/77	@	" "
SOUTH WEST	#2	10/3/77	@	" "
				COMMENTS

Firm DEWISONDate 9-2-77

COLLECTOR IDENTIFICATION	RATING	ISS. DATE	HOPI. INITIAL	REMARKS
FORMING DEPT. FIBER SIDE	#3	9/14/77	BC	Heavy accumulation in #1 Compartment. ELR had changed bag two days prior to my inspection. Light out in #2 Comp.
FORMING DEPT. DUST SIDE	#2	9/14/77	BC	Slight visible dust in #3 & 4 compartments. Had all compartments vacuumed this date.
FINISHING DEPT. OLD DUST HOUSE				
WEST	#3	9-2-77	CW	GOOD CONDITION NO ACCUMULATIONS FRO ANY DAMAGED BAGS
EAST	#3	9-2-77	CW	GOOD CONDITION NO ACCUMULATIONS FROM ANY DAMAGED BAGS
NEW DUST HOUSE				
NORTH WEST	#2	9-2-77	CW	NO ACCUMULATIONS DUST PICKED UP ON FINGERS ONLY
NORTH EAST	#2	9-2-77	CW	" "
SOUTH EAST	#2	9-2-77	CW	" "
SOUTH WEST	#2	9-2-77	CW	" "
				COMMENTS TWO LIGHT BULBS BURNED OUT WORK ORDER TAKEN IN (M)

DUST COLLECTION SYSTEMS INSPECTION

PLANT DEVISONDate 8-1-77

COLLECTION IDENTIFICATION	RATING	INSP. DATE	INSP. INITIAL	REMARKS
FORMING DEPT. FIBER SIDE	# 3	8/13/77	BE	Slight visible dust in #2 Compartment. one local accumulations in #1 Compartment. no ruptured bag noted.
FORMING DEPT. DUST SIDE	# 3	8/13/77	BE	Small rupture at bottom of bag in #2 Compartment. Small rupture in #3 Compartment. Noted this to E & R.
FINISHING DEPT. OLD DUST HOUSE				
WEST	# 3	8/1/77	@	GOOD CONDITION NO ACCUMULATIONS FROM ANY DAMAGED BAGS
EAST	# 3	8/1/77	@	GOOD CONDITION NO ACCUMULATIONS FROM ANY DAMAGED BAGS
NEW DUST HOUSE				
NORTH WEST	# 2	8/1/77	@	NO ACCUMULATIONS DUST PICKED UP ON FINGERS ONLY
NORTH EAST	# 2	8/1/77	@	" "
SOUTH EAST	# 2	8/1/77	@	"LIGHT BULB BURNED" OUT. (WORK ORDER IN)
SOUTH WEST	# 2	8/1/77	@	NO ACCUMULATIONS DUST PICKED UP ON FINGERS ONLY

DUST COLLECTOR CONDITION RATING

Plant DENISON

Date 7-5-77

COLLECTION IDENTIFICATION	RATING	INSP. DATE	INSP. INITIAL	REMARKS
FORMING DEPT. FIBER SIDE	# 2	7/15/77	B.C.	Slight visible dust in #1 compartment. Found one bag down. EX R is to replace
FORMING DEPT. DUST SIDE	# 2	7/15/77	B.C.	Slight visible dust - general overall dust picked up on finger
FINISHING DEPT. OLD DUST HOUSE				
WEST	# 3	7/5/77	(C)	GOOD CONDITION NO ACCUMULATIONS FROM ANY DAMAGED BAGS
EAST	# 3	7/5/77	(C)	" " " "
NEW DUST HOUSE				
NORTH WEST	# 1	7/5/77	(C)	NO ACCUMULATIONS. DUST PICKED UP ON FINGERS
NORTH EAST	# 2	7/5/77	(C)	" " " "
SOUTH EAST	# 3	7/5/77	(C)	" " " "
SOUTH WEST	# 4	7/5/77	(C)	" " " "

L. Benjamin
L. Richards

DUST COLLECTOR CONDITION SURVEY

Plant DENISON

Date 6-1-77

COLLECTION IDENTIFICATION	RATING	INSP. DATE	INSP. INITIAL	REMARKS
<u>FORMING DEPT.</u> <u>FIBER SIDE</u>	# 3	6/10/77	RL	1-3 Local accumulation of Fiber. No rupture or blow off bags found.
<u>FORMING DEPT.</u> <u>DUST SIDE</u>	# 2	6/10/77	BL	#3 & 4 Compartmental Slight visible dust. general clean & 1
<u>FINISHING DEPT.</u> <u>OLD DUST HOUSE</u>				
WEST	# 3	6/1/77	@	GOOD CONDITION NO ACCUMULATIONS OF DUST OR DAMAGED BAGS
EAST	# 3	6/1/77	@	GOOD CONDITION NO ACCUMULATIONS OF DUST OR DAMAGED BAGS
<u>NEW DUST HOUSE</u>				
NORTH WEST	# 2	6/1/77	@	NO ACCUMULATIONS DUST PICKED UP ON FINGERS ONLY
NORTH EAST	# 2	6/1/77	@	" "
SOUTH EAST	# 2	6/1/77	@	" "
SOUTH WEST	# 2	6/1/77	@	" "

LIST COLLECTOR CONDITION RATING

Plant: Penicillium

Date 3-5-77

COLLECTION IDENTIFICATION	RATING	INSP. DATE	INSP. INITIAL	REMARKS
FORMING DEPT. FIBER SIDE	# 3	3-5-77	BC	one small pile of Fiber in #1 Compartment, no visible Bag rupture Compartments to be cleaned up Today
FORMING DEPT. DUST SIDE	# 4	3-5-77	BC	#2 Compartment light dust overall. #4 Compartment, Heavy Dust overall No visible Bag rupture. Compartment to be cleaned Today.

DUST COLLECTOR CONDITION RATING

Plant DEPT. 1501

Date 2-8-77

COLLECTOR IDENTIFICATION	RATING	INSP. DATE	INSP. INITIAL	REMARKS
<u>FORMING DEPT.</u> <u>FIBER SIDE</u>	# 2	2-8-77	E.L.	One bag down in #1 Compartment.
<u>FORMING DEPT.</u> <u>DUST SIDE</u>	# 4	2-8-77	CR	#3 Compartment Light Dust overall #4 Comp. Heavy Dust overall. Compartment to be cleaned today.
<u>FINISHING DEPT</u> <u>OLD DUST HOUSE</u> West	# 3	2/7/77	CRJ	No accumulations from any damage bags. Good Condition
East	#3	2/7/77	CRJ	" " "
<u>NEW DUST HOUSE</u> North West	#2	2/7/77	CRJ	Dust picked up on fingers only. No accumulations any place.
North East	#2	2/7/77	CRJ	" " "
South East	#2	2/7/77	CRJ	" " "
South West	2	2/7/77	CRJ	" " "

18m

DUST COLLECTOR CONDITION RATING

Plant DENISON

Date 2-7-77

COLLECTOR IDENTIFICATION	RATING	INSP. DATE	INSP. INITIAL	REMARKS
FORWARD SEPT. Fiber Side #1	2	2-7-77		one bag down in #1 Compartment to be replaced
" #2	2	2-7-77		
" #3	2	2-7-77		
" #4	2	2-7-77		
DUST Side #1	2	2-7-77		#3 Comp light dust overall
" #2	3	2-7-77		#4 Compartment heavy accumulation overall.
" #3	2	2-7-77		Compartments to be cleaned
" #4	4	2-7-77		Found no ruptured bag.

START COPY

INITIALS

DATE

BOX NO./FILE DRAWER NO.

SEGMENT NO.

04-01906

SIGNIFICANT

NOTES