



Bell Laboratories

600 Mountain Avenue
Murray Hill, New Jersey 07974
Phone (201) 582-3000

June 13, 1979

W. Tripp
New Jersey Bell
540 Broad Street
Room 502
Newark, New Jersey 07101

PLAINTIFF'S EXHIBIT

SWB-101

Dear Walt:

The insulation sample labelled "Bloomfield C.O. 428 Bloomfield Avenue" has been analyzed for asbestos. No fibers of any kind were seen by polarized light microscopy. The only crystalline material seen by x-ray diffraction was magnesium sulfate hydrate ($\text{MgSO}_4 \cdot 6 \text{H}_2\text{O}$). Based on these results this sample does not contain any asbestos.

Sincerely,

Charles P. Lichtenwalner

Ref: 1055

Copy to
G. P. Bisgeier, M.D. - NJB
A. B. Goetze
R. L. Beach - AT&T
N. J. DeCapua
J. M. Degen
R. W. Stone, M.D.
W. J. Schreibeis - BTL
G. M. Wilkening

003576

CONFIDENTIAL