State of New York
Department of Labor
DIVISION OF INDUSTRIAL HYGIENE
80 CENTRE STREET
NEW YORK, N.Y. 10013

ADDRESS REPLY TO:
2447 Sheridan Dr.
Tonawanda, N. Y. 14150
DATE October 16, 1973

Georgia-Pacific Corp.
900 S. W. 5th Avenue
Portland, Oregon 97204

Att: Mr. R. J. Fejta

PLAINTIFF'S EXHIBIT
GP-1626

NOTICE OF PLAN APPROVAL

Plan No. BPA-217-73
Location of System BLOOMINGDALE RD., AKRON
Joint Cement Mfg.
Joint Cement Dept.
Fan Sys. 9

We are pleased to advise you that the plans you submitted to the Department of Labor for an exhaust system to be installed or altered have been approved. One set of these plans is returned herewith.

The above approval is granted subject to the following:

1. The blast gates or dampers must be permanently fastened by riveting or welding to prevent any further adjustment after air flow in the system has been properly balanced.

2. Chemical air tests and air flow tests by the Division of Industrial Hygiene. Depending on the results of the tests, modifications to the system, additional ventilation, or both, may be required.

3. It is understood that asbestos will not be used in this process after March 1974.

When the system has been installed or altered, and is ready for test, kindly notify the office of the Division of Industrial Safety Service at the following address: New York State Department of Labor, Division of Industrial Safety Service, 65 Court St., Buffalo, N. Y. - Att: Mr. E. Derner, Supvr.

This approval is based upon conformance to standards and requirements of the Labor Law and to the applicable Industrial Codes of the State of New York. You are responsible for determining whether emissions from the system meet the requirements of any local air pollution ordinances. If any alterations of or additions to the above system are required which change its operating characteristics, it will be necessary for you to submit revised plans to the Division of Industrial Hygiene for approval prior to making such alterations or additions.

Morris Kleinfeld

JJ:MHL
Encl.
c/c JB ED

MORRIS KLEINFELD, M.D.
Director
For The Commissioner

IH-223 (10-6...