



UNITED STATES ENVIRONMENTAL
REGION VI
1201 ELM STREET
DALLAS, TEXAS 75270

RECEIVED
OCT 06 1982

OCT 01 1982

Mr. G. C. Strickler
Plant Manager
PPG Industries, Incorporated
P.O. Box 1000
Lake Charles, Louisiana 70601

Re: NPDES Permit No. LA0000761

Dear Mr. Strickler:

We note that your facility is in violation of the above referenced permit. Specifically, the following violation(s):

<u>Date</u>	<u>Outfall</u>	<u>Parameter</u>	<u>Violation</u>	<u>Permit Limit</u>
✓5/30/82	001	pH max	9.6 S.U.	9.0 S.U.
✓6/3/82	011/017/019	TSS max	2337 lbs/day	2236 lbs/day
✓6/6/82	019	TSS max	2258 lbs/day	2236 lbs/day
6/25/82	014	Lead max	.67 ppm	.5 ppm
6/27/82	005	pH max	✓9.3 S.U.	9.0 S.U.
6/30/82	001	pH max	9.2 S.U.	9.0 S.U.
✓7/4/82	001	pH min	2.3 S.U.	6.0 S.U.
6/82	011/017/019	TSS avg	1651 lbs/day	1118 lbs/day
✓5/82	011/017/019	TSS avg	1540 lbs/day	1118 lbs/day
✓5/18/82	017	Lead max	25.3 lbs/day	10.1 lbs/day
✓5/82	018	TOC avg	1968 lbs/day	1300 lbs/day
4/82	011/017/019	TSS avg	1938 lbs/day	1118 lbs/day
4/82	018	TOC avg	1998 lbs/day	1300 lbs/day
✓8/3/82	001	pH min	3.6 S.U.	6.0 S.U.
✓8/5/82	011/017/019	TSS max	2653 lbs/day	2236 lbs/day
✓8/24/82	001	pH max	9.1 S.U.	9.0 S.U.

Your facility should take whatever remedial action is necessary to prevent the recurrence of the violation(s) noted above.

A report of the above violation will be placed in your file. The report will be used in our consideration of the appropriate action to be taken in the event of future violations of the permit.

SL 026621

OCT 0 REC'D

If you have any questions on this matter please contact Ruth Roberts at the above address or telephone (214) 767-2945.

Sincerely,

Robert G. Stender

for Robert G. Stender, Chief
Administrative Section (6W-EA)

cc: Mr. J. Dale Givens, Administrator
Louisiana Department of Natural Resources

SL 026622