

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME PPG IND.
ADDRESS P. O. BOX 1000
LAKE CHARLES LA 70602

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

(2-16)
LA0000761
PERMIT NUMBER

(17-19)
001
DISCHARGE NUMBER

F - FINAL LIMITS
FINAL OUTFALL

Form Approved
OMB No. 2040-0004
Expires 2-29-84

FACILITY
LOCATION
ATTN: T. G. Brown, Plant Manager

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
FROM 85	08	01	TO 85	08	31
(13-15)	(12-1)	(12-31)	(13-15)	(12-29)	(13-31)

NOTE: Read instructions before completing this form.

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING (46-53)			(4 Card Only) QUALITY OR CONCENTRATION (38-45)			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM			
TEMPERATURE, WATER DEG. FAHRENHEIT 00011 1 0	SAMPLE MEASUREMENT	*****	*****	*****	*****	96	104		NA	CONT
EFFLUENT GROSS VALUE FLOW RATE	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	*****			RECORD
00058 1 0	SAMPLE MEASUREMENT	145,951	191,500		*****	*****	*****		NA	CONT
EFFLUENT GROSS VALUE PH	PERMIT REQUIREMENT	*****	*****	GPM	*****	*****	*****			RECORD
00400 1 0	SAMPLE MEASUREMENT	30DA AVG	DAILY MX		*****	*****	*****			RECORD
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	*****			RECORD
	SAMPLE MEASUREMENT		312		5.9*		10.2**	L = H = SU	0 1	CONT
	PERMIT REQUIREMENT	*****	*****	MIN/MO	6.0	*****	9.0			RECORD
			446		MINIMUM		MAXIMUM			RECORD
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER

T. G. Brown
Works Manager

TYPED OR PRINTED

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN, AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT SEE 18 USC 1001 AND 33 USC 1310. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)

SIGNATURE OF PRINCIPAL EXECUTIVE
OFFICER OR AUTHORIZED AGENT

TELEPHONE

DATE

318 491-4500 85 08 31
AREA CODE NUMBER YEAR MO DAY

REFERENCE TO ANY VIOLATIONS (Reference all attachments here)

HERE SHALL BE NO DISCHARGE OF FLOATING SOLIDS OR VISIBLE FOAM EXCEPT IN TRACE AMOUNTS.
Duration of eersion did not exceed 60 minutes, and so therefore did not constitute a violation.
For pH -- See Attachment I, Letter of September 10, 1985.

047185

DISCHARGE MONITORING REPORT (DMR)

OMB No. 2040-0004

Expires 2-29-84

F - FINAL LIMITS
SURFACE RUNOFF

NAME PPG IND.

ADDRESS P. O. BOX 1000

LAKE CHARLES

LA 70602

LA0000761

PERMIT NUMBER

005

DISCHARGE NUMBER

FACILITY

LOCATION

ATTN: T. G. Brown, Plant Manager

MONIT RING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
85	08	01	85	08	31
(20-21)	(22-23)	(24-25)	(26-27)	(28-29)	(30-31)

NOTE: Read instructions before completing this form.

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING (46-53)			(4 Card Only) QUALITY OR CONCENTRATION (38-45)			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM			
TEMPERATURE, WATER DEG. FAHRENHEIT 00011 1 0	SAMPLE MEASUREMENT	*****	*****	*****	*****	82	84	NA	3/7	GRAB
EFFLUENT GROSS VALUE FLOW RATE	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	*****	DEG.F	THREE/	GRAB WEEK
00058 1 0	SAMPLE MEASUREMENT	393	680	GPM	*****	*****	*****	NA	3/7	G
EFFLUENT GROSS VALUE PH	PERMIT REQUIREMENT	30DA AVG	DAILY MX		*****	*****	*****	*****	THREE/	GRAB WEEK
00400 1 0	SAMPLE MEASUREMENT	*****	*****	*****	7.3	*****	8.9	L = H = 0	3/7	GRAB
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	*****	6.0 MINIMUM	*****	9.0 MAXIMUM	SU	THREE/	GRAB WEEK
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER

T. G. Brown
Works Manager

TYPED OR PRINTED

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN, AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 USC § 1001 AND 33 USC § 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)

SIGNATURE OF PRINCIPAL EXECUTIVE
OFFICER OR AUTHORIZED AGENT

TELEPHONE

DATE

318

491-4500

85

08

31

AREA
CODE

NUMBER

YEAR

MO

DAY

THERE SHALL BE NO DISCHARGE OF FLOATING SOLIDS OR VISIBLE FOAM EXCEPT IN TRACE AMOUNTS.

SL 047186

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME PPG IND.

ADDRESS P. O BOX 1000
LAKE CHARLES LA 70602

FACILITY

LOCATION

ATTN: T. G. Brown, Plant Manager

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

(2-16)

(17-19)

LA0000761

010

PERMIT NUMBER

DISCHARGE NUMBER

F - FINAL LIMITS

AREA B UNCONTAMINATED CT80

Form Approved
OMB No. 2040-0004
Expires 2-29-84

MONITORING PERIOD

FROM

YEAR MO DAY
85 08 01

TO

YEAR MO DAY
85 08 31

(20-31)

(22-31)

(24-31)

(26-31)

(28-31)

(30-31)

NOTE: Read instructions before completing this form.

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING (46-53)			(4 Card Only) QUALITY OR CONCENTRATION (54-61)				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
FLOW RATE	SAMPLE MEASUREMENT	281	899		*****	*****	*****	*****	NA	CONT	RECORD
00058 1 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	***** 30DA AVG	***** DAILY MX	GPM	*****	*****	*****	*****		CONT	RECORD
CHROMIUM, TOTAL (AS CR)	SAMPLE MEASUREMENT	.027	.151		*****	*****	*****	*****	0	3/7	2 IC
01034 1 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	***** DAILY AV	***** DAILY MX	LBS/DY	*****	*****	*****	*****		THREE/	COMP2
CHLORINATED HYDRO- CARBONS, GENERAL	SAMPLE MEASUREMENT	*	*		*****	*****	*****	*****	--	---	---
74052 1 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	***** DAILY AV	***** DAILY MX	LBS/DY	*****	*****	*****	*****		THREE/	COMP2
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER

T. G. Brown
Works Manager

TYPED OR PRINTED

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN, AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT SEE 18 USC § 1001 AND 33 USC § 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)

SIGNATURE OF PRINCIPAL EXECUTIVE
OFFICER OR AUTHORIZED AGENT

TELEPHONE

DATE

318
AREA
CODE

491-4500
NUMBER

85
YEAR

08
M

31
DAY

CHLORINATED HYDROCARBONS LIMIT IS SUM OF 010 & 018.

See Outfall 018.

SL 047187

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME **PPG IND.**

ADDRESS **P. O. BOX 1000**

LAKE CHARLES

LA 70602

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

(2-16)

(17-19)

LA000761

PERMIT NUMBER

011

DISCHARGE NUMBER

F - FINAL LIMITS
MERCURY CELLS SEWER

Form Approved
OMB No. 2040-0004
Expires 2-29-84

FACILITY

LOCATION

ATTN: **T. G. Brown, Plant Manager**

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
85	08	01	85	08	31
(10-11)	(12-11)	(10-11)	(10-11)	(12-11)	(10-11)

FROM

TO

NOTE: Read instructions before completing this form.

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING (34-53)			(4 Card Only) QUALITY OR CONCENTRATION (38-43)				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
FLOW RATE	SAMPLE MEASUREMENT	163	241	GPM	*****	*****	*****	*****	NA	CONT	RECORD
00058 1 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****		*****	*****	*****	*****		CONTINUOUS	RECORD
MERCURY, TOTAL (AS HG)	SAMPLE MEASUREMENT	.018	.052	LBS/DY	*****	*****	*****	*****	0	3/7	2 JC
71900 1 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	.21 DAILY AV	.42 DAILY MX		*****	*****	*****	*****		THREE WEEK	COMP 24
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER

T. G. Brown
Works Manager

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 USC § 1001 AND 33 USC § 1315. (Penalties under these statutes may include fines up to \$10,000 and/or imprisonment for between 6 months and 5 years.)

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

B. Conrad

TELEPHONE

DATE

318 491-4500

85 08 31

AREA CODE NUMBER YEAR MO DAY

HERE SHALL BE NO DISCHARGE OF FLOATING SOLIDS OR VISIBLE FOAM EXCEPT IN TRACE AMOUNTS.
G IS SUM OF 011 AND 111.

L 047188

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

OMB No. 2040-0004
Expires 2-29-84

NAME PPG IND.
ADDRESS P. O. BOX 1000
LAKE CHARLES LA 70602

DISCHARGE MONITORING REPORT (DMR)

(2-16)

(17-19)

LA0000761

111

PERMIT NUMBER

DISCHARGE NUMBER

F - FINAL LIMITS
MERCURY TRACE SEWER

FACILITY
LOCATION
ATTN: T. G. Brown, Plant Manager

MONITORING PERIOD								
YEAR			MO			DAY		
FROM	85	08	01	TO	85	08	31	
	(20-21)	(22-23)	(24-25)		(26-27)	(28-29)	(30-31)	

NOTE: Read instructions before completing this form.

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING (46-53)			(4 Card Only) QUALITY OR CONCENTRATION (54-61)				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
FLOW RATE	SAMPLE MEASUREMENT	392	501	GPM	*****	*****	*****	*****	NA	CONT	RECORD
00058 1 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	***** 30DA AVG	***** DAILY MX		*****	*****	*****	*****		CONTINUOUS	RECORD
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER

T. G. Brown
Works Manager

TYPED OR PRINTED

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT SEE 18 USC § 1001 AND 33 USC § 1319. (Penalty under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE

DATE

318 491-4500 85 08 31
AREA CODE NUMBER YEAR MO DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

SL 047189

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME PPG IND.

ADDRESS P. O. BOX 1000

LAKE CHARLES

LA 70602

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

(2-16)

LA0000761

PERMIT NUMBER

(17-19)

012

DISCHARGE NUMBER

F - FINAL LIMITS

HG CELL COOLING TWR BLOWDOWN

Form Approved

OMB No. 2040-0004

Expires 2-29-84

FACILITY

LOCATION

LINE T. G. Brown, Plant Manager

MONITORING PERIOD								
FROM	YEAR	MO	DAY	TO	YEAR	MO	DAY	
	85	08	01		85	08	31	
	(18-21)	(22-24)	(25-31)		(26-28)	(29-31)	(10-31)	

NOTE: Read instructions before completing this form.

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING (46-53)			(4 Card Only) QUALITY OR CONCENTRATION (38-45)			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM			
FLOW RATE	SAMPLE MEASUREMENT				*****	*****	*****	*****	NA	24 HT
00058 1 0	PERMIT REQUIREMENT	*****	*****	GPM	*****	*****	*****	*****	THREE/CALCT	
EFFLUENT GROSS VALUE		30DA AVG	DAILY MX						WEEK	
MERCURY, TOTAL (AS HG)	SAMPLE MEASUREMENT				*****	*****	*****	*****	NA	2 IC
71900 1 0	PERMIT REQUIREMENT	*****	*****	LBS/DY	*****	*****	*****	*****	THREE/COMP2A	
EFFLUENT GROSS VALUE		NO							WEEK	
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER

T. G. Brown
Works Manager

TYPED OR PRINTED

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT SEE 18 USC § 1001 AND 33 USC § 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)

SIGNATURE OF PRINCIPAL EXECUTIVE
OFFICER OR AUTHORIZED AGENT

TELEPHONE

DATE

318 491-4500

85 08 31

AREA
CODE

NUMBER

YEAR

M

DAY

SAMPLE PRIOR TO DISCUSSION WITH OTHER STREAM(S).

THERE SHALL BE NO DISCHARGE OF FLOATING SOLIDS OR VISIBLE FOAM EXCEPT IN TRACE AMOUNTS.

MERCURY SAMPLE TYPE LINEAR OR TIME COMPOSITE

SL 047190

NAME PPG IND.
 ADDRESS P. O. BOX 1000
LAKE CHARLES LA 70602

LA0000761
 PERMIT NUMBER

013
 DISCHARGE NUMBER

F - FINAL LIMITS
 SUM OF 013,015,016 FLOW

FACILITY
 LOCATION
 TTN: T. G. Brown, Plant Manager

MONITORING PERIOD								
YEAR			MO			DAY		
FROM	85	08	01	TO	85	08	31	
	(20-21)	(22-23)	(24-25)		(26-27)	(28-29)	(30-31)	

NOTE: Read instructions before completing this form.

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING (46-53)			(4 Card Only) QUALITY OR CONCENTRATION (38-43)			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM			
FLOW RATE	SAMPLE MEASUREMENT	141,916	160,237	GPM	*****	*****	*****	*****	NA	CONT RECORD
00058 1 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	***** 30DA AVG	***** DAILY MX		*****	*****	*****	*****		CONTINUED
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER
T. G. Brown
Works Manager
 TYPED OR PRINTED

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN, AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT SEE 18 USC § 1001 AND 33 USC § 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)

B. Brown
 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE
318 491-4500
 AREA CODE NUMBER
 DATE
85 08 31
 YEAR MO DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004
Expires 2-29-84

NAME PPG IND.
ADDRESS P. O. BOX 1000
LAKE CHARLES LA 70602

(2-16)
LA0000761
PERMIT NUMBER

(17-19)
017
DISCHARGE NUMBER

F - FINAL LIMITS
LEAD TREATMENT DISCHARGE

FACILITY
LOCATION
ATTN: T. G. Brown, Plant Manager

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
FROM 85	08	01	TO 85	08	31
(10-11)	(12-13)	(14-15)	(16-17)	(18-19)	(20-21)

NOTE: Read instructions before completing this form.

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING (46-53)				(4 Card Only) QUALITY OR CONCENTRATION (46-53)			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS		MINIMUM	AVERAGE	MAXIMUM			
FLOW RATE	SAMPLE MEASUREMENT	14	60	GPM		*****	*****	*****	*****	NA	CONT RECORD
00058 1 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	***** 30DA AVG	***** DAILY MX			*****	*****	*****	*****		CONTINUED
SOLIDS, TOTAL SUSPENDED	SAMPLE MEASUREMENT	2	4	LBS/DY		*****	*****	*****	*****	NA	3/7 2 JC
00530 1 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****			*****	*****	*****	*****		THREE/COMP24 WEEK
LEAD, TOTAL (AS PB)	SAMPLE MEASUREMENT	.002	.003	LBS/DY		*****	*****	*****	*****	0	3/7 24 HC
01051 1 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	5.1 DAILY AV	10.1 DAILY MX			*****	*****	*****	*****		THREE/COMP24 WEEK
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER
T. G. Brown
Works Manager

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN, AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT SEE 18 U.S.C. § 1001 AND 33 U.S.C. § 1919. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT
B. P. [Signature]

TELEPHONE
318 491-4500
DATE
85 08 31
AREA CODE NUMBER YEAR M DAY

SEE ATTACHMENTS FOR DISCHARGE MONITORING DATA (See page 2 of attachments here)

THERE SHALL BE NO DISCHARGE OF FLOATING SOLIDS OR VISIBLE FOAM EXCEPT IN TRACE AMOUNTS.

SI 47192

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME **PPG IND.**

ADDRESS **P. O. BOX 1000**

LAKE CHARLES

LA 70602

FACILITY

LOCATION

ATTN: **T. G. Brown, Plant Manager**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

(2-16)

(17-19)

LA0000761

PERMIT NUMBER

018

DISCHARGE NUMBER

**F - FINAL LIMITS
PROCESS WASTEWATER**

Form Approved
OMB No. 2040-0004
Expires 2-29-84

MONITORING PERIOD

YEAR	MO	DAY	TO	YEAR	MO	DAY
85	08	01		85	08	31
(120-21)	(122-23)	(124-25)		(126-27)	(128-29)	(130-31)

NOTE: Read instructions before completing this form.

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING (46-53)			(4 Card Only) QUALITY OR CONCENTRATION (54-61)				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
FLOW RATE	SAMPLE MEASUREMENT	3,990	5,587		*****	*****	*****	*****	NA	CONT	RECORD
00058 1 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	***** 30DA AVG	***** DAILY MX	GPM	*****	*****	*****	*****		CONTINUOUS	RECORD
800, 5-DAY (20 DEG. C)	SAMPLE MEASUREMENT	85	148		*****	*****	*****	*****	0	1/7	2' HC
00310 1 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	***** 774 DAILY AV	***** 1298 DAILY MX	LBS/DY	*****	*****	*****	*****		WEEKLY	CL..P2
SOLIDS, TOTAL SUSPENDED	SAMPLE MEASUREMENT	2,008	*****		*****	*****	*****	*****	0	3/7	24 HC
00530 R 0 SEE COMMENTS BELOW	PERMIT REQUIREMENT	***** 3100 30DA AV	*****	LBS/DY	*****	*****	*****	*****		THREE/COMP2 WEEK	
SOLIDS, TOTAL SUSPENDED	SAMPLE MEASUREMENT	1,905	3,834		*****	*****	*****	*****	0	3/7	24 HC
00530 1 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	***** 4500 DAILY AV	***** 8700 DAILY MX	LBS/DY	*****	*****	*****	*****		THREE/COMP2 WEEK	
TOTAL ORGANIC CARBON (TOC)	SAMPLE MEASUREMENT	679	1,295		*****	*****	*****	*****	0	3/7	24 HC
00680 1 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	***** 1300 DAILY AV	***** 2600 DAILY MX	LBS/DY	*****	*****	*****	*****		THREE/COMP2 WEEK	
CHLORINATED HYDRO- CARBONS, GENERAL	SAMPLE MEASUREMENT	39	143		*****	*****	*****	*****	0	3/7	2' HC
74052 1 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	***** 684 DAILY AV	***** 1368 DAILY MX	LBS/DY	*****	*****	*****	*****		THREE/CL..P2 WEEK	
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER

**T. G. Brown
Works Manager**

TYPED OR PRINTED

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN, AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT SEE 18 USC § 1001 AND 33 USC § 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)

B. [Signature]

SIGNATURE OF PRINCIPAL EXECUTIVE
OFFICER OR AUTHORIZED AGENT

TELEPHONE

DATE

318
AREA
CODE

491-4500
NUMBER

85
YEAR

08
MO

31
DAY

CHLORINATED HYDROCARBONS LIMIT IS THE SUM OF 018 AND 010. TSS IS ANNUAL AVERAGE.

SL 047193

PERMITTEE NAME/ADDRESS (Include
Facility Name/Location if different)

NAME **PPG IND.**

ADDRESS **P. O. BOX 1000**

LAKE CHARLES

LA 70602

FACILITY

LOCATION

ATTN: **T. G. Brown, Plant Manager**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

(2-16)

(17-19)

LA0000761

PERMIT NUMBER

019

DISCHARGE NUMBER

F - FINAL LIMITS

SUM OF 011,017,019, FLOW & TSS

Form Approved
OMB No. 2040-0004
Expires 2-29-84

MONITORING PERIOD

FROM	YEAR	MO	DAY	TO	YEAR	MO	DAY
	85	08	01		85	08	31
	(20-21)	(22-24)	(25-31)		(32-37)	(38-39)	(40-31)

NOTE: Read instructions before completing this form.

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING (46-53)			(4 Card Only) QUALITY OR CONCENTRATION (54-61)			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM			
FLOW RATE	SAMPLE MEASUREMENT	246	379	GPM	*****	*****	*****	*****	NA	CONT
00058 1 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****		*****	*****	*****	*****	CONT	RECORD
SOLIDS, TOTAL SUSPENDED	SAMPLE MEASUREMENT	42	252	LBS/DY	*****	*****	*****	*****	0	3/7
00530 1 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	1118	2236		*****	*****	*****	*****	THREE	COMP2
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER

T. G. Brown
Works Manager

TYPED OR PRINTED

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN, AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT SEE 18 USC 1001 AND 33 USC 1318. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)

SIGNATURE OF PRINCIPAL EXECUTIVE
OFFICER OR AUTHORIZED AGENT

TELEPHONE

318 491-4500

AREA
CODE

NUMBER

DATE

85 08 31

YEAR

MO

DAY

33 IS THE SUM OF 011,017 AND 019.

047194

Facility Name (Location if different)

NAME **PPG IND**ADDRESS **P. O. BOX 1000****LAKE CHARLES****LA 70602**

FACILITY

LOCATION

T. G. Brown, Plant Manager

DISCHARGE MONITORING REPORT (DMR)

(2-16)

(17-19)

LA0000761**021**

PERMIT NUMBER

DISCHARGE NUMBER

F - FINAL LIMITS**COOLING WATER**

OMB No. 2040-0004

Expires 2-29-84

MONITORING PERIOD

FROM	YEAR	MO	DAY	TO	YEAR	MO	DAY
	85	08	01		85	08	31
	(17-21)	(22-24)	(24-29)		(16-21)	(22-29)	(10-31)

NOTE: Read instructions before completing this form.

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING (46-53)			(4 Card Only) QUALITY OR CONCENTRATION (54-63)				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
TEMPERATURE, WATER DEG. FAHRENHEIT 00011 1 0	SAMPLE MEASUREMENT	*****	*****	*****	*****	92	105		NA	CONT	RECORD
EFFLUENT GROSS VALUE FLOW RATE	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	*****	DEG. F		CONTINUOUS	RECORD
00058 1 0	SAMPLE MEASUREMENT	25,522	34,900		*****	*****	*****	*****	NA	CONT	RECORD
EFFLUENT GROSS VALUE PH	PERMIT REQUIREMENT	*****	*****	GPM	*****	*****	*****	*****		CONTINUOUS	ADDITIONAL
00400 1 0	SAMPLE MEASUREMENT	*****	*****	*****	6.6	*****	9.6		NA	CONT	RECORD
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	*****	MINIMUM	*****	MAXIMUM	SU		CONTINUOUS	RECORD
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER

T. G. Brown
Works Manager

TYPED OR PRINTED

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN, AND BASED ON MY KNOWLEDGE OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT SEE 18 USC § 1001 AND 33 USC § 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)

SIGNATURE OF PRINCIPAL EXECUTIVE
OFFICER OR AUTHORIZED AGENT

TELEPHONE

DATE

318 491-4500

85 08 31

AREA
CODE

NUMBER

YEAR

MO

DAY

THERE SHALL BE NO DISCHARGE OF FLOTTING SOLIDS OR VISIBLE FOAM EXCEPT IN TRACE AMOUNTS.

SL 047195

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME EPC IND.
ADDRESS P. O. BOX 1000
LAKE CHARLES LA 70602

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

(2-16)

(17-19)

LA0000761

PERMIT NUMBER

024

DISCHARGE NUMBER

F - FINAL LIMITS
SURFACE DRAINAGE - PRODN STRG

Form Approved
OMB No. 2040-0004
Expires 2-29-84

FACILITY
LOCATION
TINS T. G. Brown, Plant Manager

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
FROM <u>85</u>	<u>08</u>	<u>01</u>	TO <u>85</u>	<u>08</u>	<u>31</u>
(20-21)	(22-24)	(24-25)	(26-27)	(28-29)	(30-31)

NOTE: Read instructions before completing this form.

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING (46-53)			(4 Card Only) QUALITY OR CONCENTRATION (46-53)			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM			
PH	SAMPLE MEASUREMENT	*****	*****	*****	7.6	*****	8.9	L = 0 H = 0	5/7*	GRAB
00400 1 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	*****	6.0 MINIMUM	*****	11.0 MAXIMUM	SU	WEEK-DAYS	GRAB
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER <u>T. G. Brown</u> <u>Works Manager</u>	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN, AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT SEE 18 USC § 1001 AND 33 USC § 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT <u>B. Paul</u>	TELEPHONE 318 491-4500	DATE 85 08 31
TYPED OR PRINTED		AREA CODE	NUMBER	YEAR

INDICATE INSTANCES OF NONCOMPLIANCE (Reference all attachments here)

When flowing.
low indicate times.

047196

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME PPG IND.
 ADDRESS P. O. BOX 1000
LAKE CHARLES LA 70602

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)

(2-16)

(17-19)

LA0000761

025

PERMIT NUMBER

DISCHARGE NUMBER

F - FINAL LIMITS

STORM DRAINAGE 1500 T/D CHLRN

Form Approved
 OMB No. 2040-0004

Expires 2-29-84

T/D CHLRN

FACILITY
 LOCATION
 ITNS T. G. Brown, Plant Manager

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
FROM 85	08	01	TO 85	08	31
(12-31)	(12-31)	(12-31)	(12-31)	(12-31)	(12-31)

NOTE: Read instructions before completing this form.

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING (46-53)			(4 Card Only) QUALITY OR CONCENTRATION (54-61)				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
FLOW RATE	SAMPLE MEASUREMENT	4,411	67,320		*****	*****	*****	*****	NA	5/7*	GRAB
00058 1 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	GPM	*****	*****	*****	*****		DAILY	GRAB
PH	SAMPLE MEASUREMENT	*****	*****	*****	8.2	*****	9.6		NA	5/7*	()
00400 1 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	*****	SU		DAILY	GRAB
	SAMPLE MEASUREMENT				MINIMUM		MAXIMUM				
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER

T. G. Brown
Works Manager

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN, AND BASED ON MY KNOWLEDGE OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT SEE 18 USC § 1001 AND 33 USC § 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE

DATE

318
AREA CODE

491-4500
NUMBER

85
YEAR

08
MO

31
DAY

TYPED OR PRINTED

SEE PPG DMS 204-15774-16 (Reference all attachments here)

THERE SHALL BE NO DISCHARGE OF FLOATING SOLIDS OR VISIBLE FOAM EXCEPT IN TRACE AMOUNTS.

MONITOR WHILE FLOWING ALL PARAMETERS.

When flowing.

SL 047197

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME PPG IND.
 ADDRESS P. O. BOX 1000
LAKE CHARLES LA 70602

FACILITY
 LOCATION
 TITLES T. G. Brown, Plant Manager

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)

(2-16) LA000761
 PERMIT NUMBER
 (1-19) 026
 DISCHARGE NUMBER

F - FINAL LIMITS
 STORM DRAINAGE

Form Approved
 OMB No. 2040-0004
 Expires 2-29-84

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
FROM 85	08	01	TO 85	08	31
(12-21)	(12-21)	(12-21)	(12-21)	(12-21)	(12-21)

NOTE: Read instructions before completing this form.

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING (46-53)			(4 Card Only) QUALITY OR CONCENTRATION (54-61)			N EX (62-63)	FREQUENCY ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM			
FLOW RATE	SAMPLE MEASUREMENT	46	506	GPM	*****	*****	*****	*****	NA	5/7*
00058 1 0	PERMIT REQUIREMENT	*****	*****		*****	*****	*****	*****	WEEK-DAYS	GRAB
EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	30DA AVG	DAILY MX	*****	7.6	*****	8.7	*****	NA	5/7*
PH	PERMIT REQUIREMENT	*****	*****		*****	*****	*****	*****	WEEK-DAYS	GRAB
00400 1 0	SAMPLE MEASUREMENT			*****	MINIMUM	*****	MAXIMUM	SU		
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT			*****						
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT			*****						
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT			*****						
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT			*****						
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT			*****						
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT			*****						
	PERMIT REQUIREMENT									

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER

T. G. Brown
 Works Manager

TYPED OR PRINTED

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY KNOWLEDGE OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT SEE 18 USC § 1001 AND 33 USC § 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)

SIGNATURE OF PRINCIPAL EXECUTIVE
 OFFICER OR AUTHORIZED AGENT

TELEPHONE

DATE

318 | 491-4500 | 85 | 08 | 31
 AREA CODE NUMBER YEAR MO DAY

MONITOR FLOW WHEN FLOWING (Reference all attachments here)

*When flowing

SL 047198

Attachment I

pH CONTROL (Outfall 001). There was one pH excursion in August, reported as follows:

August 2, 1985 for 1 hr. 40 min. (+0.6) . A faulty level indication system resulted in the overflow of alkaline material to the pH control system causing neutralization capacity to be exceeded. The faulty instrumentation was replaced.