NOTICE: If the film image below is less clear than this notice, it is due to the quality of the document being filmed

CONFIDENTIAL 51

#8407

DOCUMENTS PRODUCED DALLAS COUNTY CASES 3/18/92

MATERIAL 8407 (Stating Dash Number) (O.C.3500) June 5, 1946
CEMENT, HEAT INSULATING (PLASTIC INSULATION) X
SPECIAL MATERIAL FOR SOUTH PHILADELPHIA ONLY
FURNISHED BY -
(For 8407-1)(A)Baldwin-Hill Co, 800 Klagg Ave, Trenton (2), N.J.
(B)Eagle Picher Sales Co, American Bldg, Cincinnati(1).
ORDER FROM SUPPLIER AS
(For 8407-1 (A) Baldwin-Hill #1 Insulating Cement.
(B) Eagle-Picher Super 66 Plastic Insulation.
CHARACTERISTICS (8407-1) A loose fibrous heat insulating cement, composed of black mineral wool derived from slag, asbestos fiber and clay binder, applied by mixing with water and throwing into position by hand, and troweling smooth as desired.
Serviceable to 900 C (1800 F) and is 100% reclaimable for reapplication when a temperature of 645 C (1200 F) has not been exceeded.

APPLICATION - Plastic heat insulating cement for steam turbines and steam piping.
SPECIFY AS - CEMENT 8407-1

Issued by Mtls & Stds Sec, Eng Labs & Stds Dept, East Pgh, Pa.
Supersedes card 8407 Dated 6-20-41
Printed in U.S.A.

DOCUMENTS PRODUCED DALLAS COUNTY CASES 3/18/92

PLAINTIFF'S EXHIBIT WH-57