

MONITOR Young SHIFT 4:20 DATE 11/22/79
OVA CALIBRATION 1.0 BACKGROUND 5pm OVA NO. 3
PERMIT TO ENTER BUILDING 121 WITH OVA. FOREMAN 2.12 TIME 4:30
PERMIT TO ENTER LPA AND TANK FARM WITH OVA. FOREMAN RJD TIME 8:00

[illegible][illegible]

TAG	TAINFUL AREA
	NO HIGH READINGS RECORDED ON GC DURING SHIFT. CL1A CL2A COLUMNS FLUTTERING SOME TIMES FROM AROUND DENIN AREA. FIL 1B LIQUID OILY FILTRER EMITTING SOME FUMES FROM BOTTOM BLEED OFF (TIGHTENED BLEED OFF). CHECKED CULF CONDENSOR ATOP TK4B, PIPE FITTER'S WORKED ON 3/4 MAINHEAD (OK). Rupture Disc leaking @ flange, Bennett tried to tighten; still leaks. also CP 3F also have Relief valve blown @ RED BALL ASSEMBLY, 1/2 to change when 3F is down.
	NUMBER OF RADIO PAGE CALLS TO INVESTIGATE A ALARM

TAG	NO LEAKS FOUND IN AREA
NO. OF PAGE CALLS TO INVESTIGATE A FLARM	2