OFFICE OF THE SECRETARY

New York, N.Y., December 28, 1970

Mr. W. R. Kelly A/M

EP552

At a meeting of the Advisory Committee held on December 16, 1970, there was approved El Paso Plant application for property appropriation, New York No. 2212, Plant No. 552, in the amount of $6,500 for Ventilation of Wedge Roaster Building.

J. F. Hornbostel, Jr

Encl.
KDLoughridge w/encl.
JPHarrison w/encl.
HQStringham w/encl.
LCTravis
EHHaug
AOMarsh, Jr.

New York Wire
JAN 5, 1971
Jan 4, 1971

PLAINTIFF'S EXHIBIT

ASA-603

November 5, 1970
El Paso, Texas

Mr. Lee C. Travis, General Manager
Western Department
Salt Lake City, Utah

APPLICATION FOR PROPERTY APPROPRIATION
VENTILATION OF CALCINE HAULAGE FLOOR - WEDGE ROASTER BUILDING
EL PASO PLANT NO. 552 - $6,500

In September the calcine haulage floor under Nos. 1 and 3 wedge roasters was enclosed and a ventilating pipe installed to remove calcine in the air when cars were being filled. This project has proven to be satisfactory in capturing the particulate matter and avoiding its escape into the atmosphere below the plant.

In order to complete this job it will be necessary to enclose the haulage floor on roasters Nos. 2 and 4. The ventilating system will be connected to the same outlet pipe and will be controlled by dampers dependent upon which roasters are being used to fill the calcine cars. This installation will allow us to get into compliance with the State Air Control Board regulations on particulate emission.

I recommend proceeding with this project.

W. R. KELLY

WRK:gp
Encls.
cc: E. Haug - Encls.

FORM 302 (REVISED 1964)

Approp. No. 2212
Plant No. 552

APPLICATION FOR PROPERTY APPROPRIATION

November 5 ..... 19 70 ..... El Paso ..... Plant

DESCRIPTION:

Ventilation of Calcine Haulage Floor - Wedge Roaster Building

If work contemplates replacement or improvement of structures or equipment now in place, insert:-1.Original cost $..... 2.Date erected or installed.....

Total estimated cost (FORM 302A ATTACHED) $6,500.....
Estimated annual net saving $.....
Estimated completion date Dec. 31 1970
MONTH YEAR

ADVANTAGES TO BE DERIVED:

The ventilating system will precent calcine from escaping to the atmosphere, and will allow us to get into compliance with the Texas Air Control Board regulations on particulate emissions.

Reviewed by..... ACCT. FOR CHIEF ACCT.

Approved by..... COMPTROLLER

Account Chargeable to..... TO BE FILLED IN BY COMPTROLLER

Recommended by..... MANAGER

Approved by ..... VICE PRESIDENT

Approved by Advisory Committee
DEC. 16 1970 ..... 19.....

Approved by Board of Directors
.....19.....
..... SECRETARY