PLAINTIFF'S EXHIBIT
WH-254

111
4-30-91

To: BROWN.B.B (1039:WMS1955)
To: WALLS.R.E (1039:WTX2574)
To: JORDAN.A.E (1039:WTX2622)
To: WERNER.R.T (1039:WTX3100)
To: STIFFLER.C.R (1039:WTX4390)
To: TUCKER.JIM (1047:WNH1111)
To: LAMBERT.S.M (1047:WNH1344)
To: TALBERT.S.J (1047:WNH1467)
To: VOIGT.R.E (1047:WNH1515)
To: RAMSEAU.E.S (1047:WNH1999)
To: TODD.M.S (1047:WNH3112)
To: HAMRIN.M.S (1049:WST2112)
To: DICK.T.D (1049:WST2549)
To: ROTHAS.B.S (1049:WST5622)
To: WALSH.S.M (1049:WST5325)
To: MILLER.L.E (1049:WST5873)
To: BRANTON.D.R (1049:WST5991)
To: BAMOY.S.T (1049:WST7067)
To: MCCANN.J.L (1049:WST7341)
To: WOODALL.S.A (1049:WST7493)
To: SMITH.TE (1049:WST8427)
To: INSKEEP.R.E (WES2948)
To: NAVEY.W.R (WES3270)
To: MCRAE.W.L (WES4192)
Cc: KROSEL.LORI (1039:WTX4200)
Bc: PERKINS.TERRY (WES4155)
From: PERKINS.TERRY (WES4163) Delivered: Tue 30-Apr-91 19:18 EDT Sys 104
8 (47)
Subject: DAILY REPORT 4-30-91
Mail Id: IPM-1048-910430-193700

CUSTOMER: TVA GALLATIN
UNIT: 1-2-3-4
DATE OF REPORT: 4-30-91
.....
SCHEDULE STATUS:
ORIG START DATE U-4 12-90 UNIT 1-3 READY FOR SEAR....
ORIG END U-4 2-25-91
ORIG END U-3 3-11-91
ORIG END U-2 3-12-91
ORIG END U-4 3-31-91
ACTUAL START U-3-4 2-8-91 ORIG END JOB AUG-91
.....
MAJOR ACCOMPLISHMENTS:
FINISHED CHECKING U-3 ROW 3 BLADE 24 IN ROTOR FOR CTO
U-3 ROW 4 BLADE 23 IN ROTOR FOR CTO
CONTINUE UNIT 4 INNER STAGE SEAL HOUSING MOD
START INSTALLING GEN ROTOR UNIT 4
START WELD TEST PIPEFITTERS AND MILLWRIGHT - USED BILL MCRAE (W)
CONTINUE FUEL AND LUBE MODS
CONTINUE MDPF UNIT 2
RECEIVED UNIT 2 ROW 4 TURBINE BLADES
.....
CONTINUE ABOVE:

CONFIDENTIAL
DALLAS DOCUMENT PRODUCED IN RAINIER V. TVA
PRODUCED BY TVA IN CASES 3/89-92
ELECTRIC COURT TESTINGHOUSE
CONFIDENTIAL

.....
SAFETY:
DATE OF LAST MEETING: 4-30-91 NUMBER OF ACCIDENTS(0)
TOPIC: SHE SECURITY,RIGGING ,ELECTRICAL
COMMENTS: STATE MAN ON SITE TODAY CONCERNING ASBESTOS.
.....
ACTION ITEMS:
CTO-- FUEL HEATER ENCLOSURE---- NEED ANSWER SO FOUNDATION CAN
BE PREPARED - REBAR BENT , FORMS ETC. AND PRICING CAN BE
ENTERED IN ESTIMATE ON SUN .....
CTO-- NEED ANSWER ON NEW COMPRESSOR MOUNTING ???
PLEASE CALL T.C.PERKINS AND GIVE ME UPDATE ON TWO ITEMS ABOVE..
.....
CONCERNS:
STATE REP BOBBY JERNIGAN ON SITE AGAIN TODAY,CONCERNING ASBESTOS.
E-MAIL SENT TO S.T. BRADY ON MEETING NOTES..PLUS WRITER ALSO
SENT COPIES OF ALL TEST RESULTS-TVA AND STATE....
.....
COMMENTS: WEATHER GOOD DRY

Disposition:

DOCUMENTS TESTINGROUSE - RAINIER
PRODUCED BY TVA
ELECTRIC CORP.
DALLAS COUNTY CASES 3/18/92