

milinches per foot or 600 milinches for 4 ft. If the first floor radiators are located 3 ft above the mains, second floor radiators 12 ft above the mains, third floor 21 ft, and fourth floor 30 ft, the heads are 450, 1800, 3150, and 4500 milinches respectively.

In *forced circulation* systems flow is produced mechanically by means of a pump driven by electricity, steam, or other source of energy. As

