DOW CHEMICAL U.S.A.

PLAINTIFF'S EXHIBIT

DOW-2951

March 10, 1976

TO: JOHN GALLOWAY

CC: M. W. HEALY
R. P. HEEND
T. E. WERKEMA
J. S. LAING
R. R. ADOLF

RE: STYROFOAM© FOR BEACH HOUSES

Dear John:

At the last Fire Committee meeting I reviewed the application where STYROFOAM SM brand insulation is applied to the underside of beach houses built on pilings.

After considerable discussion, it was decided that a 15 minute thermal barrier would be required as the exterior finish. The following materials would be acceptable:

5/8" exterior grade plywood
1/2" exterior grade gypsum board

Cement asbestos board, 1/4" thick, will not be acceptable.

It would be appropriate for you to convey this information to your distributors via a broadcast.

If you have any need for further discussion, please give me a call.

Best regards,

Dave

Dave Ledvinka

rw

ST0367855

XY 42755

LIFE IS FRAGILE · HANDLE WITH CARE ·