

MON-1964

RT14

Monsanto

FROM (NAME & LOCATION) R. C. Baca - Texas City, Texas

DATE: January 30, 1984 CC: A. H. Conrad - 0-6A
SUBJECT: 4th Quarterly Competitive Safety & Tom Ryan - 0-5
Housekeeping Inspection - Power II 1984 SHAC
REFERENCE: Inspection Team
File
TO: G. A. Orum - 2PD

Power 2 was inspected January 25, and received an overall rating of good. Specific items on safety & housekeeping are as follows:

Safety

- No safety chains on chain operated valves in plant air.
- Sign missing from safety shower top of #2 clarifier.
- 954-18 fire extinguisher box needs latch.
- Sign missing from eye bath northwest side of #3 clarifier.
- Ladder blocking safety shower at south of alum tank.
- Safety chain off chain operated valve on raw water line west side of water treating.
- Good safety logbook.
- Handrail off on scaffold south of water treating.
- #18 ladder needs to be tagged.
- N₂ station needs sign north of water treating.
- Several valve stems need protectors.
- Could not find procedure for blocking in natural gas in case of emergency.

Housekeeping

- Maintenance Shop needs attention.
- Loose boards, pipe, & fittings on top deck.

Please respond to these items to Tom Ryan with a carbon copy to me for SHAC by 2/21/84.


For the Inspection Team
R. C. Baca

Inspection Team:
R. C. Baca
Keith Mathis
Tom Ryan
J. W. Hughes
Harry Anderson

SC

000610

LAM001808