

CEMENT ASBESTOS PRODUCTS COMPANY

Woodward, Alabama

PLAINTIFF'S
EXHIBIT

CAP-16

TO: Mr. E. R. Smitherman

Date February 14, 1972

FROM: Mr. S. D. Weaver


SUBJECT: Improved Risk Mutual

- 71-1. The vents will be installed immediately.
- 71-2. We have no paint drying booths, this recommendation has no merit.
- 71-3. Vents on gas pressure regulators will be piped outside.
- 71-4. Means will be provided to make tightness test.

SDE/bh
cc: Charlie Cobb

P. S. Charles, Please have these recommendations accomplished by 2-19-72 and report back to E. R. Smitherman and myself of work accomplished.

HER 0008893



Please place with the following
memo to C.R. Smithman
in memo

To: C.R. Smithman
From: L.S.W.
Subject: Imperial risk noted

- 71-1 The water will be installed immediately,
- 71-2 We have no paint buying orders, this recommendation is now in effect.
- 71-3 Union gas pressure very high, pipe outside
- 71-4 Room will be provided to meet tightness test

C.C. C. with footnote.

Check please have these recommendations
accomplished by 2-19-72, and report
back to C.R. Smithman and
notify of work completed.

Holiday Inn THE WORLD'S INNKEEPER®

HER 0008894