PLAINTIFF'S EXHIBIT

CAP-698

STATE OF NEVADA
DEPARTMENT OF HUMAN RESOURCES
DIVISION OF HEALTH
BUREAU OF CONSUMER HEALTH PROTECTION SERVICES
CAPITOL COMPLEX
CARSON CITY, NEVADA 89710

TELEPHONE
(702) 885-4750

May 29, 1979

Mr. P. J. Gartly, Manager
Regional Corporate Marketing Services
Johns-Manville
2600 Campus Drive
San Mateo, California 94403

RE: A/C PIPE DOMESTIC WATER SYSTEMS, STATE OF NEVADA

Dear Mr. Gartly:

The Nevada Division of Health requires that materials used for domestic water systems meet AWWA standards, be approved by NSF for potable water systems, etc.

Asbestos-cement pipe meeting AWWA Standard C400-77 is acceptable for use in potable water systems in Nevada.

Sincerely,

L. H. Dodgion
Supervisor
Public Health Engineering

LHD:dcm