

TABLE 1. THERMODYNAMIC PROPERTIES OF MOIST AIR^a (STANDARD ATMOSPHERIC PRESSURE, 29.921 IN. HG)

FAHR. TEMP. (°F)	HUMIDITY RATIO $W_a \times 10^3$	VOLUME CU FT/LB DRY AIR			ENTHALPY BTU/LB DRY AIR			ENTROPY BTU PER (°F) (LB DRY AIR)			CONDENSED WATER			FAHR. TEMP. (°F)
		v_a	v_{as}	v_s	h_a	h_{as}	h_s	s_a	s_{as}	s_s	Enthalpy Btu/Lb h_w	Entropy Btu/(Lb) (°F) s_w	Van. Press In. Hg $p_s \times 10^3$	
-160	0.2120	7.520	0.000	7.520	-38.504	0.000	-38.504	-0.10300	0.00000	-0.10300	-222.00	-0.4907	0.1009	-160
-159	0.2304	7.545	0.000	7.545	-38.262	0.000	-38.262	-0.10219	0.00000	-0.10219	-221.68	-0.4896	0.1158	-159
-158	0.2703	7.571	0.000	7.571	-38.021	0.000	-38.021	-0.10139	0.00000	-0.10139	-221.36	-0.4885	0.1286	-158
-157	0.3049	7.596	0.000	7.596	-37.779	0.000	-37.779	-0.10059	0.00000	-0.10059	-221.04	-0.4874	0.1450	-157
-156	0.3435	7.622	0.000	7.622	-37.538	0.000	-37.538	-0.09980	0.00000	-0.09980	-220.72	-0.4864	0.1635	-156
-155	0.3869	7.647	0.000	7.647	-37.296	0.000	-37.296	-0.09901	0.00000	-0.09901	-220.40	-0.4853	0.1842	-155
-154	0.4354	7.673	0.000	7.673	-37.055	0.000	-37.055	-0.09822	0.00000	-0.09822	-220.07	-0.4843	0.2073	-154
-153	0.4897	7.699	0.000	7.699	-36.813	0.000	-36.813	-0.09743	0.00000	-0.09743	-219.75	-0.4832	0.2331	-153
-152	0.5502	7.724	0.000	7.724	-36.572	0.000	-36.572	-0.09664	0.00000	-0.09664	-219.42	-0.4822	0.2620	-152
-151	0.6178	7.750	0.000	7.750	-36.330	0.000	-36.330	-0.09586	0.00000	-0.09586	-219.10	-0.4811	0.2942	-151
-150	0.6932	7.775	0.000	7.775	-36.088	0.000	-36.088	-0.09508	0.00000	-0.09508	-218.77	-0.4800	0.3301	-150
-149	0.7772	7.801	0.000	7.801	-35.847	0.000	-35.847	-0.09430	0.00000	-0.09430	-218.44	-0.4789	0.3701	-149
-148	0.8709	7.826	0.000	7.826	-35.606	0.000	-35.606	-0.09352	0.00000	-0.09352	-218.11	-0.4779	0.4146	-148
-147	0.9750	7.851	0.000	7.851	-35.364	0.000	-35.364	-0.09274	0.00000	-0.09274	-217.78	-0.4768	0.4641	-147
-146	1.091	7.876	0.000	7.876	-35.123	0.000	-35.123	-0.09198	0.00000	-0.09198	-217.45	-0.4758	0.5194	-146
-145	1.219	7.902	0.000	7.902	-34.881	0.000	-34.881	-0.09121	0.00000	-0.09121	-217.12	-0.4747	0.5807	-145
-144	1.362	7.927	0.000	7.927	-34.640	0.000	-34.640	-0.09044	0.00000	-0.09044	-216.78	-0.4737	0.6488	-144
-143	1.521	7.953	0.000	7.953	-34.399	0.000	-34.399	-0.08967	0.00000	-0.08967	-216.45	-0.4726	0.7243	-143
-142	1.698	7.978	0.000	7.978	-34.157	0.000	-34.157	-0.08892	0.00000	-0.08892	-216.11	-0.4716	0.8082	-142
-141	1.893	8.004	0.000	8.004	-33.916	0.000	-33.916	-0.08816	0.00000	-0.08816	-215.78	-0.4705	0.9011	-141
-140	2.109	8.029	0.000	8.029	-33.674	0.000	-33.674	-0.08740	0.00000	-0.08740	-215.44	-0.4695	1.004	-140
-139	2.348	8.054	0.000	8.054	-33.433	0.000	-33.433	-0.08664	0.00000	-0.08664	-215.11	-0.4684	1.118	-139
-138	2.613	8.079	0.000	8.079	-33.192	0.000	-33.192	-0.08589	0.00000	-0.08589	-214.77	-0.4674	1.244	-138
-137	2.906	8.105	0.000	8.105	-32.951	0.000	-32.951	-0.08514	0.00000	-0.08514	-214.43	-0.4663	1.383	-137
-136	3.229	8.130	0.000	8.130	-32.709	0.000	-32.709	-0.08440	0.00000	-0.08440	-214.09	-0.4653	1.537	-136
-135	3.586	8.156	0.000	8.156	-32.468	0.000	-32.468	-0.08365	0.00000	-0.08365	-213.75	-0.4642	1.707	-135
-134	3.980	8.181	0.000	8.181	-32.226	0.000	-32.226	-0.08291	0.00000	-0.08291	-213.41	-0.4632	1.895	-134
-133	4.414	8.207	0.000	8.207	-31.985	0.000	-31.985	-0.08217	0.00000	-0.08217	-213.07	-0.4621	2.102	-133
-132	4.893	8.232	0.000	8.232	-31.744	0.000	-31.744	-0.08144	0.00000	-0.08144	-212.72	-0.4611	2.330	-132
-131	5.419	8.258	0.000	8.258	-31.503	0.000	-31.503	-0.08070	0.00000	-0.08070	-212.38	-0.4600	2.581	-131
-130	6.000	8.283	0.000	8.283	-31.262	0.000	-31.262	-0.07997	0.00000	-0.07997	-212.03	-0.4589	2.858	-130
-129	6.637	8.309	0.000	8.309	-31.021	0.000	-31.021	-0.07924	0.00000	-0.07924	-211.68	-0.4579	3.182	-129

^aCompiled by John A. Goff and S. Gratch.TABLE 1. THERMODYNAMIC PROPERTIES OF MOIST AIR^a (STANDARD ATMOSPHERIC PRESSURE, 29.921 IN. HG) (Continued)

FAHR. TEMP. (°F)	HUMIDITY RATIO $W_a \times 10^3$	VOLUME CU FT/LB DRY AIR			ENTHALPY BTU/LB DRY AIR			ENTROPY BTU PER (°F) (LB DRY AIR)			CONDENSED WATER			FAHR. TEMP. (°F)
		v_a	v_{as}	v_s	h_a	h_{as}	h_s	s_a	s_{as}	s_s	Enthalpy Btu/Lb h_w	Entropy Btu/(Lb) (°F) s_w	Van. Press In. Hg $p_s \times 10^3$	
-128	0.7339	8.334	0.000	8.334	-30.780	0.000	-30.780	-0.07851	0.00000	-0.07851	-211.33	-0.4569	0.3492	-128
-127	0.8111	8.360	0.000	8.360	-30.539	0.000	-30.539	-0.07778	0.00000	-0.07778	-210.98	-0.4559	0.3863	-127
-126	0.8958	8.385	0.000	8.385	-30.298	0.000	-30.298	-0.07707	0.00000	-0.07707	-210.63	-0.4548	0.4267	-126
-125	0.9887	8.411	0.000	8.411	-30.057	0.000	-30.057	-0.07634	0.00000	-0.07634	-210.28	-0.4538	0.4710	-125
-124	1.091	8.436	0.000	8.436	-29.816	0.000	-29.816	-0.07562	0.00000	-0.07562	-209.93	-0.4527	0.5197	-124
-123	1.202	8.461	0.000	8.461	-29.575	0.000	-29.575	-0.07490	0.00000	-0.07490	-209.58	-0.4517	0.5730	-123
-122	1.325	8.486	0.000	8.486	-29.334	0.000	-29.334	-0.07419	0.00000	-0.07419	-209.23	-0.4506	0.6314	-122
-121	1.469	8.512	0.000	8.512	-29.093	0.000	-29.093	-0.07348	0.00000	-0.07348	-208.88	-0.4496	0.6953	-121
-120	1.608	8.537	0.000	8.537	-28.852	0.000	-28.852	-0.07277	0.00000	-0.07277	-208.52	-0.4485	0.7653	-120
-119	1.767	8.563	0.000	8.563	-28.611	0.000	-28.611	-0.07206	0.00000	-0.07206	-208.17	-0.4475	0.8419	-119
-118	1.942	8.588	0.000	8.588	-28.370	0.000	-28.370	-0.07135	0.00000	-0.07135	-207.81	-0.4464	0.9256	-118
-117	2.134	8.613	0.000	8.613	-28.129	0.000	-28.129	-0.07064	0.00000	-0.07064	-207.45	-0.4454	1.017	-117
-116	2.343	8.639	0.000	8.639	-27.889	0.000	-27.889	-0.06994	0.00000	-0.06994	-207.09	-0.4444	1.117	-116
-115	2.571	8.664	0.000	8.664	-27.648	0.000	-27.648	-0.06924	0.00000	-0.06924	-206.73	-0.4433	1.226	-115
-114	2.820	8.690	0.000	8.690	-27.407	0.000	-27.407	-0.06854	0.00000	-0.06854	-206.37	-0.4423	1.345	-114
-113	3.092	8.715	0.000	8.715	-27.166	0.000	-27.166	-0.06784	0.00000	-0.06784	-206.01	-0.4412	1.475	-113
-112	3.388	8.741	0.000	8.741	-26.926	0.000	-26.926	-0.06715	0.00000	-0.06715	-205.65	-0.4402	1.617	-112
-111	3.711	8.766	0.000	8.766	-26.685	0.000	-26.685	-0.06646	0.00000	-0.06646	-205.29	-0.4392	1.771	-111
-110	4.063	8.792	0.000	8.792	-26.444	0.000	-26.444	-0.06577	0.00000	-0.06577	-204.92	-0.4381	1.939	-110
-109	4.445	8.817	0.000	8.817	-26.204	0.000	-26.204	-0.06508	0.00000	-0.06508	-204.56	-0.4371	2.121	-109
-108	4.861	8.842	0.000	8.842	-25.963	0.001	-25.963	-0.06439	0.00000	-0.06439	-204.19	-0.4360	2.320	-108
-107	5.314	8.868	0.000	8.868	-25.722	0.001	-25.722	-0.06370	0.00000	-0.06370	-203.83	-0.4350	2.556	-107
-106	5.806	8.893	0.000	8.893	-25.481	0.001	-25.481	-0.06302	0.00000	-0.06302	-203.46	-0.4339	2.771	-106
-105	6.340	8.919	0.000	8.919	-25.240	0.001	-25.239	-0.06234	0.00000	-0.06234	-203.09	-0.4329	3.026	-105
-104	6.920	8.944	0.000	8.944	-25.000	0.001	-24.999	-0.06167	0.00000	-0.06167	-202.72	-0.4318	3.303	-104
-103	7.549	8.970	0.000	8.970	-24.759	0.001	-24.758	-0.06099	0.00000	-0.06099	-202.35	-0.4308	3.603	-103
-102	8.232	8.995	0.000	8.995	-24.518	0.001	-24.517	-0.06032	0.00000	-0.06032	-201.98	-0.4298	3.929	-102
-101	8.972	9.020	0.000	9.020	-24.278	0.001	-24.277	-0.05964	0.00000	-0.05964	-201.61	-0.4287	4.283	-101
-100	9.772	9.046	0.000	9.046	-24.037	0.001	-24.036	-0.05897	0.00000	-0.05897	-201.23	-0.4277	4.666	-100
-99	10.63	9.071	0.000	9.071	-23.797	0.001	-23.796	-0.05830	0.00000	-0.05830	-200.86	-0.4266	5.081	-99
-98	11.57	9.097	0.000	9.097	-23.556	0.001	-23.555	-0.05764	0.00000	-0.05764	-200.48	-0.4256	5.530	-98
-97	12.59	9.122	0.000	9.122	-23.316	0.001	-23.315	-0.05697	0.00000	-0.05697	-200.11	-0.4245	6.016	-97

^aCompiled by John A. Goff and S. Gratch.