PLAINTIFF'S
EXHIBIT
DUP-2027

cc: [redacted]
F. O'Shaughnessy
S. E. Searle
I. M. Singer
W. W. Sinclair
[redacted]

October 4, 1979

TO: L. L. BRUMFIELD
G. M. RICHARDSON
N. M. SABATELLI
J. C. WALKER
G. T. WILLIAMS

file

FROM: L. T. FREELAND

WASTE ASBESTOS DUMPSTER INSPECTION

An unscheduled inspection (Freeland and O'Shaughnessey) of the above dumpster was conducted in the afternoon of 10/1/79. The condition found outisde the dumpster was totally unsatisfactory. Many (at least 10) bags of asbestos-looking insulation were lying on the ground on the north and west ends of the dumpster. Several of the bags were broken and loose insulation spread about in the area.

The dumpster was opened for inspection and contents were found in good condition, but the dumpster was completely filled. Some loose insulation and gloves were found on top of the dumpster.

It is imperative that, whenever the asbestos dumpster is filled, W. W. Sinclair (9346) be notified immediately. Any excess bagged asbestos waste should be carefully stored north of the dumpster until an empty dumpster is available. Any broken bags should be placed into new bags and all loose insulation carefully recovered and repackaged. Construction and contractor supervision should be made aware that the procedure for handling asbestos materials (EDM 7.6) must be rigorously enforced.

Please discuss this serious situation with all concerned to prevent recurrence. Unscheduled inspections will be continued in order to aid you in insuring compliance with the procedure.

If you have any questions or if I can assist in any way, please contact me at 9529.

LTF/fb