



Shell Oil Company
Interoffice Memorandum

JULY 22, 1987

187-706

PLAINTIFF'S EXHIBIT

SH-1434

FROM: J. D. RANDELL, STAFF INDUSTRIAL HYGIENIST, HS&E/S&IH
TO: C. BAUGHMAN, R. N., TULSA CREDIT CARD CENTER
SUBJECT: TULSA CREDIT CARD CENTER ASBESTOS SURVEY

Attached is the final report on the above subject.

L.H. Kusnetz for J.D. Randell

LDH:BVR

cc: H. L. Kusnetz
HS&E-AS (2)

~~HS&E-AS - TSCA 8(d)~~

Jul 24 12 53 PM '87
RECEIVED
INDUSTRIAL HYGIENE
SECTION

LAM 023981

CAV8716702

ABS-007163

I87-706



Shell Oil Company
Interoffice Memorandum

JULY 22, 1987

FROM: L. D. HEUGATTER, SR. INDUSTRIAL HYGIENE ASSISTANT, HS&E/S&IH
TO: J. D. RANDELL, STAFF INDUSTRIAL HYGIENIST, HS&E/S&IH
SUBJECT: TULSA CREDIT CARD CENTER ASBESTOS SURVEY

LAM 023982

CAV8716702

ABS-007164

ASBESTOS

A sample of building insulation collected from the ceiling plenum area indicated a composition of 20 percent chrysotile asbestos. Shell's Interim Recommendations for Working With Asbestos-Containing Materials in Office Facilities has already been sent to you on an information basis. The sample of insulation is being reanalyzed to eliminate the possibility of a false positive result. Industrial Hygiene Services will continue to be in contact regarding further sampling and work practices.

L.D. Hengatter

LDH:BVR

Attachments

LAM 023983

CAV8716702

ABS-007165