


Bldg 9



July 12, 1961
21000

Re: Albany Campus Site
Taxation & Finance Bldg. #9
Specification No. 15492 M

E. W. Tompkins Company, Inc.
158 Orange Street
Albany, New York

Gentlemen:

In reply to your letter of July 7, 1961 the Mandet Corp.'s Insulation Schedule dated June 28, 1961 is approved as noted with the understanding; all contract requirements will be met.

The following insulation samples are approved provided the thickness and jacketing material is furnished as shown on the approved insulation schedule.

Mandet's 85% Magnesia Block insulation.
Mandet's Superglas pipe covering.
Mandet's 1/2" thick foam plastic pipe covering.
Mandet's 6 lb. density spun mineral wool duct insulation with vapor barrier jacket.

Samples of expanded polystyrene and 1 lb. density fiberglass insulation are not being checked as this material is not included on your insulation schedule.

Very truly yours,

CARL W. LARSON
State Architect

JFC: EM
cc: Mr. Haase
Mr. Dugan - 2
Mr. Clarke (Tilley)