PLAINTIFF'S EXHIBIT WRG-690

UNDERWRITERS' LABORATORIES, INC.
333 PFINGSTEN ROAD · NORTHBROOK, ILLINOIS 60062
*an independent, not-for-profit organization testing for public safety*

RECEIVED
NOV 29 1972
CAMBRIDGE

November 22, 1972

R4339
71NK270

Zonolite Construction Products Div.
W.R. Grace & Company
62 Whittemore Avenue
Cambridge, Mass. 02140

Attention: Mr. Thomas P. Feit, Manager
Fire Protection Products

Subject: Fire Hazard Properties of MK-5
Cementitious Material

Dear Mr. Feit:

During the course of our investigation of MK-5 material, its formulation was reviewed and compared to MK-3 and MK-4 cementitious material. Based upon this review it was decided that the fire hazard properties of all three materials were similar. To confirm this opinion tunnel tests were conducted.

As a result of our investigation, MK-3, MK-4 and MK-5 cementitious materials will appear in our Building Materials Directory with the following ratings: Flame Spread 10, Fuel Contributed 5, and Smoke Developed 0.

Very truly yours,

R. M. Berhinig

R. M. BERHINIG
Engineering Group Leader
Fire Protection Dept.

RMB:CS