

bcc: NTJ/SS
R. C. Meyer - CINCINNATI
J. R. Fallon - DETROIT

December 26, 1968

Mr. Nord Kroger
Imperial Adhesives Company
6315 Wiehe Street
Cincinnati, Ohio

Dear Mr. Kroger:

The attached table lists Therminol FR-1 sample results from your heating system.

I am pleased to report that the fluid in your system analyzes to new fluid specifications after one year of operation. If we can be of any further assistance, please feel free to contact Dick Meyer in Cincinnati or me in St. Louis.

Very truly yours,

D. E. Roush
Engineering Specialist
Functional Fluids

DER:FKE

Enclosure

DSW 435015

STLCOPCB4088075

IMPERIAL ADHESIVES COMPANY

Therminol FR-1

<u>Test</u>	<u>Therminol Sample</u>	<u>Therminol FR-1 New Fluid Specifications</u>
Viscosity @ 100°F, c.s.	18.7	17-18
Acid Number, mg KOH/g	0.01	<0.01
Moisture, ppm	55	<50

DSW 435016

STLCOPCB4088076