

WV-0039 #15



INTERNAL
CORRESPONDENCE

PLAINTIFF'S EXHIBIT

UC-3182

UNION CARBIDE CORPORATION TECHNICAL CENTER
P.O. BOX 8361 SOUTH CHARLESTON WV 25303

To: C. K. Campbell

Date: April 16, 1986

From:

Organization: HS&EA

Subject:

Topic: Industrial Hygiene

Address:

Copy to:

J. H. Barna
W. L. Browning
C. P. Maxwell
B. R. McMakin

Subject:

Asbestos

At your request, insulation samples were collected from three lines near the Construction sandblasting shop located at the Institute plant. Your concern was that the protective coating has weathered from the insulation in question, and the insulation is crumbling and could allow it to become airborne. Since these lines are very close to the lunch trailer and close to the sandblasting area, there was concern of asbestos exposure to the employees assigned to this area.

The three samples were analyzed and two of the three (see attached) were determined to contain asbestos.

We feel that the concerns are well founded and we recommend working closely with the Institute plant's Area Maintenance Supervisor in removing the Asbestos, therefore eliminating the possible exposure hazard to our employees.

If you have any questions or need our assistance, please feel free to give us a call on extension 4779 or 3750.

PREPARED BY:

APPROVED BY:

Vance E. Stover

Manhar A. Patel

Attachment

VES:MAP:rab
1204P

UCC 000376

INSULATION ASBESTEST RESULTS FORM

<u>No.</u>	<u>Date</u>	<u>Sample Submitted By</u>	<u>Sample Source</u>	<u>Mg Test</u>	<u>Fe Test</u>	<u>By</u>	<u>Remarks</u>
PS-1	4-9-86	Charlie Campbell	Institute - behind paint paint shop - lunch trailer near ground level.	-	+	VES	Very dark red, immediately.
PS-2	4-9-86	Charlie Campbell	Taken behind sandblasting shop near tank no. 1265.	-	+	VES	
PS-3	4-10-86	Charlie Campbell	6" line going overhead - behind trailer - over roadway.	-	-	VES	

1204P