


Blitz 9



July 12, 1961
21000

Re: Albany Campus Site
Taxation & Finance Bldg. #9
Specification No. 15492 H

E. W. Tompkins Company, Inc.
158 Orange Street
Albany, New York

Gentlemen:

In reply to your letter of July 7, 1961 the Mundet Corp.'s Insulation Schedule dated June 28, 1961 is approved as noted with the understanding all contract requirements will be met.

The following insulation samples are approved provided the thickness and jacketing material is furnished as shown on the approved insulation schedule.

Mundet's 85% Magnesia Block insulation.
Mundet's Superglas pipe covering.
Mundet's 1/2" thick foam plastic pipe covering.
Mundet's 6 lb. density spun mineral wool duct insulation with vapor barrier jacket.

Samples of expanded polystyrene and 1 lb. density fiberglass insulation are not being checked as this material is not included on your insulation schedule.

Very truly yours,

CARL W. LARSON
State Architect

JFC: ml
cc: Mr. Haase
Mr. Dugan - 2
Mr. Clarke (Tilley)