

TABLE III

ABERDEEN PVC PLANT EFFLUENT WATER
10-11 SEPTEMBER 1979

	Metals Data ($\mu\text{g/ml}$)											
	Al	Ba	Ca	Cd*	Cr*	Cu*	Fe	Mg	Mn	Mo	Ni*	Pb*
Influent to Treatment	<.15	.15	24.6	<.015	<.03	<.015	.40	5.1	.057	<.05	<.075	<.25
Effluent	<.15	.12	23.6	<.015	<.03	<.015	<.03	4.6	.02	<.05	<.075	<.25

	Sn	Tl*	V	Zn*	Na	Ag*	Be*	Sb*	Hg*	Se*	As*
Influent to Treatment	<.10	<.5	<.025	<.025	239.3	<.02	<.01	<.2	<.0125	<.002	<.002
Effluent	<.10	<.5	<.025	<.025	89.3	<.02	.01	<.2	<.0125	<.002	<.002

*Priority pollutants