IN-10
MCC 950920

Monsanto

PLAINTIFF'S EXHIBIT

MON-1207

FROM (NAME & LOCATION) G. A. Orum - P2

DATE : October 31, 1985

SUBJECT : Third Quarter Safety and Housekeeping Inspection

REFERENCE :

cc: Doug Barfoot
D. Shotwell
D. Davidson
J. McPhail
J. Gaul

TO : File

Two items were noted as needing attention in Environmental Control.

1. The temporary maintenance buildings have been given the housekeeping attention needed.

2. Dept. 513 is short two five minute escape masks. The Safety Dept. has informed us that a change is planned regarding this equipment and that we are not to purchase additional masks at this time. We are working with Safety to resolve this.

The status of the items noted in Utilities is as follows:

1. A procedure for preventing empty or practically empty tanks from floating should a hurricane hit the area has been written.

2. JSA training was completed prior to October 1 as planned.

3. Two relief valves having block valves underneath have been added to the list of such relief valves on the weekly check list.

4. The barricade tape at Water Treating was put up while #3 clarifier was being painted. After completion of that job it was removed.

5. Housekeeping needed on the west side of #3 boiler has been taken care of.

6. The one utility hose found without tape has been inspected and properly marked.

George Orum

George Orum

/bmcl

LAM001452

SC 000255