

—EDS

Yes there are problems & no - we don't comply:

- 1st - let me assume our Contractors are reviewing these standards and someday we will officially inform them they must comply.
- 2nd we've been using Unibestos (the worst from dust angle) but it is going off the market. When I believe we will be using Johns-Manville & Klege which is somewhat better.
- 3rd CRL & WNE say we shouldn't (& don't plan) to use "Asbestospray" again. Also ditto power saws. Perhaps we should put out memos to Humble Supervisors & insulators saying don't use Asbestospray or power saws w/o clearance from CRL.
- 4th This new Std. says hand or power tools should be provided with local exhaust ventilation & dust collectors. I don't see how you provide these on a hand saw & I don't see the need in the field.
- 5th This std. requires much more use of respirators - such as when knocking off insulation. In some instances pressure supplied respirators are indicated. I suggest Safety revise our Saf. Std and re-issue to all mech. people.
- 6th we don't mix in closed bags as called for.
- 7th we don't bag waste as called for.
- 8th we don't vacuum as called for & I'm sure we dry sweep which is taboo.

ROL and

12/28/71 003.