

PLAINTIFF'S
EXHIBIT

04877-00

40

Handwritten notes and signatures

MORTON CORN, Ph.D., B. Ch. E.
CONSULTING ENGINEER
310 BOWER HILL ROAD
PITTSBURGH, PENNSYLVANIA 15226

INDUSTRIAL HYGIENE
AIR POLLUTION

April 24, 1969

TELEPHONE
412-861-6237

MEMORANDUM



TO: J. L. Hyde
W. F. Yellig
W. J. Binder

FROM: Morton Corn

TOPIC: Decision to Retain Butler Building in Unibestos Plant.
(Memo from J. L. Hyde: April 21, 1969).

I cannot endorse the decision to retain the largest present source of dust in the Unibestos plant. Furthermore, the success of all design efforts to capture asbestos dust by new hood and system design is in jeopardy. As indicated earlier, I will not hesitate to assume responsibility for the system recommended to you. However, I will not assume responsibility for the success of a system which includes the present Butler Scrap Building. My thoughts on this subject were clearly expressed to plant and to central engineering personnel. We are defeating control efforts by trying to "doctor up" this ill-suited Butler facility.

I will continue with system lay-out in preparation for a plant visit on Wednesday, April 30. My design will merely exhaust air from the Butler Building in an effort to maintain a negative pressure, with respect to surroundings.

Morton Corn, Ph.D.
Consultant

MC:ng

HIGHLY CONFIDENTIAL
SUBJECT TO PROTECTIVE ORDER

Handwritten: R0001267

PLAINTIFF'S
EXHIBIT

WR-009792