



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY

REGION 1

5 POST OFFICE SQUARE, SUITE 100
BOSTON, MA 02109-3912

Sent via Electronic Mail (*Dated as shown on electronic signature*)

Jon Lalrochelle, Owner
John's Shafts and Stuff
518 Silver St.
Manchester, NH 03103

Subject: November 2, 2022, EPA Inspection

Dear Mr. Lalrochelle:

On November 2, 2022, the U.S. Environmental Protection Agency (EPA) performed a Clean Water Act inspection of the industrial activities located at 518 Silver St, Manchester, NH 03103. EPA and New Hampshire Department of Environmental Service representatives corresponded with representatives of Mid-City Body and Frame Inc., who claimed to be the landlord of your business, John's Shafts and Stuff, operated out of the same address.

Observations were made regarding compliance with the National Pollutant Discharge Elimination System program of the Clean Water Act. A copy of the inspection report is included as an attachment to this letter along with a photo album.

John's Shafts and Stuff was observed to have containers, including drums and/or plastic totes, with an above-ground oil storage capacity above the applicability threshold (1,320 gallons) of the Oil Pollution Prevention Regulations (40 C.F.R. Part 112). Oil storage containers at your facility did not have secondary containment. Based on observations made on the day of the inspection, your facility is required to have prepared and implemented a Spill Control and Countermeasures (SPCC) plan consistent with the Oil Pollution Prevention Regulations, or you must bring the facility's above-ground oil storage capacity below the regulatory threshold.

Please report the following to the EPA in an electronic format to Alex Rosenberg within 30 days of receiving this letter, at Rosenberg.alex@epa.gov.

1. Provide either (a) a copy of the facility's current SPCC plan,¹ or (b) evidence that the Facility's total above-ground oil-storage capacity is below 1,320 gallons.
2. Describe where the floor drain located within your garage discharges into.

Please refer any questions related to technical issues in this letter to me at 617-918-1709 or at Rosenberg.alex@epa.gov. Legal issues may be directed to Jeff Kopf, Senior Enforcement Counsel, at (617) 918-1796 or at kopf.jeff@epa.gov.

¹ EPA has a tier-1 SPCC plan template available at: <https://www.epa.gov/oil-spills-prevention-and-preparedness-regulations/tier-i-qualified-facility-spcc-plan-template>

Sincerely,

 Digitally signed
by ALEX
ROSENBERG
Date: 2022.12.19
16:17:26 -05'00'

Alex Rosenberg, Inspector
Water Compliance Section
Enforcement and Compliance Assurance Division

Enclosures:

Inspection Report for November 2, 2022, EPA Inspection
Inspection Photo Album

CCs (electronic only):

Jeff Kopf, Senior Counsel, US EPA
Laurel Pushee, NHDES