DATA FOR TURBINE BLANKETS
INSULATION FOR HORIZONTAL FLANGES

KW RATING	625-750	1000-2500	3000-6000	7500	10000-12500
BLANKET LENGTH	35"	40"	42"	45"	52"
GROUP NUMBER	1	2	3	4	5

NOTE: UNLESS OTHERWISE SPECIFIED, EACH TURBINE WILL BE SUPPLIED WITH FOUR (4) BLANKETS 12" WIDE × 2" THICK WITH LENGTHS ORDERED TO ABOVE GROUP NUMBERS.

BLANKETS TO HAVE BOXED ENDS, MADE FROM V.S.-2710-98% ASBESTOS CLOTH, MONEL WIRE INSERTED, FILLED WITH AMOSITE ASBESTOS FIBRE, AND TO HAVE MONEL LACING HOOKS AT EDGES OF ONE FACE ON APPROXIMATELY 5" CENTERS.

PENGAD-Bayonne, N. J.
EXHIBIT
18
S 1501 Attach
DT

ET-000024

JOHNS-MANVILLE INSULATION
USED BY
ELLIOTT COMPANY

S-647431 D.E.M.

PLAINTIFF'S EXHIBIT
ET-51